



## AIR CLEANING FOR AIRBORNE ALLERGENS CHECKLIST

School Name / ID _____	Date _____
Location _____	Investigators _____
_____	_____
_____	_____

### **HVAC Air Filters**

- The highest efficiency air filters compatible with equipment capabilities are installed
- Air filters in air handling equipment are inspected monthly and cleaned if necessary, or replaced at a minimum every 3 months
- Filters are properly installed and kept dry

### **Portable Air Cleaners**

- If portable air cleaners are in use:
  - \_\_\_\_\_ They are adequately sized for the room volume and estimated particle generation rate
  - \_\_\_\_\_ The devices use high efficiency HEPA filters or electrostatic precipitators
  - \_\_\_\_\_ Filters are inspected monthly and replaced as necessary
  - \_\_\_\_\_ Ozone is not produced by the device