



PREFACE

Authority: The Washington State Building Code Council adopted the 1994 Washington State Energy Code pursuant to RCW 19.27A.020. This code provides minimum level of energy efficiency, but allows flexibility in building design, construction and heating equipment efficiencies. The design of this code allows space heating equipment efficiencies to offset or substitute for building envelope thermal performance.

Code Precedence: The 1994 Washington State Energy Code (WSEC) amends the 1991 WSEC Second Edition, Chapter 51-11 WAC as published in the Washington State Administrative Code.

Organization and Numbering: Chapters 1 through 10 of this code set forth the residential energy code requirements and follow the model Energy Code format. Chapters 11 through 20 of the code set forth the nonresidential energy code requirements and follow the ASHRAE numbering system.

Effective Date: These regulations shall be effective April 1, 1994.

Copies and Comments: The Department of Community, Trade and Economic Development provides staff and administrative services to the Council. Copies of WAC 51-11 and information on amendments to codes adopted by the State Building Code Council may be obtained from:

> Department of Community, Trade and Economic Development Washington State Building Code Council 906 Columbia Street SW P.O. Box 48300 Olympia, Washington 98504-8300 (206) 586-2251

> > First Edition Titled 1994 Washington State Energy Code First Edition First Edition Based on: WSR 93-21-052 and 94-05-059 Effective April 1, 1994 Printed March 1994



1994 WASHINGTON STATE ENERGY CODE FIRST EDITION TABLE OF CONTENTS

-

Ì

CHAPTER 1 ADMINISTRATION AND ENFORCEMENT	1
SECTION 101 - SCOPE AND GENERAL REQUIREMENTS	
101 1 Title	1
101.2 Purpose and Intent	1
101.3 Scone	1
101.3.1 Exempt Buildings	1
101.3.1.1	2
101.3.1.2	2
101.3.1.3	2
101.3.2 Application to Existing Buildings	2
101.3.2.1 Additions to Existing Buildings	2
101.3.2.2 Historic Buildings	3
101.3.2.3 Change of Occupancy or Use	3
101.3.2.4 Alterations and Repairs	3
101.3.2.5 Building Envelope	3
101.3.2.6 Building Mechanical Systems	4
101.3.2.7 Service Water Heating	4
101.3.2.8 Reserved	4
101.3.3 Mixed Occupancy	4
101.4 Amendments By Local Government	4
SECTION 102 - MATERIALS AND EQUIPMENT	4
102.1 Identification	4
102.2 Maintenance Information	4
SECTION 103 - ALTERNATE MATERIALS-METHOD OF	
CONSTRUCTION DESIGN OR INSULATING SYSTEMS	4
SECTION 104 PLANS AND SPECIFICATIONS	5
104.1 General	5
104.2 Details	5
	-
SECTION 105 INSPECTIONS AND ENFORCEMENT	5
105.1 General	5
105.2 Approvals Required	5
105.2.1 Required Inspections	5
105.3 Reinspection	6
SECTION 106 VIOLATIONS	6
	0
SECTION 107 LIABILITY	6
RECTION IN CONFLICTS WITH OTHER CORPO	
SECTION 108 CONFLICTS WITH OTHER CODES	0
SECTION 109 SEVERABILITY	6
	-

CHAPTER 2 DEFINITIONS
SECTION 201 GENERAL DEFINITIONS
CHAPTER 3 DESIGN CONDITIONS
SECTION 301 DESIGN CRITERIA
SECTION 302 THERMAL DESIGN PARAMETERS
SECTION 303 - MECHANICAL VENTILATION
CHAPTER 4 BUILDING DESIGN BY SYSTEMS ANALYSIS
SECTION 401 SCOPE
SECTION 402 - SYSTEMS ANALYSIS.21402.1 Special Requirements for All Group R Occupancies21402.1.1 Energy Budgets21402.1.2 Calculation of Energy Consumption21402.1.3 Input Values21402.1.4 Solar Shading and Access22402.1.5 Infiltration22402.1.6 Heat Pumps22402.3 Design23402.4 Analysis Procedure23402.5 Calculation Procedure24402.6 Documentation24CHAPTER 5 BUILDING DESIGN BY COMPONENT
PERFORMANCE APPROACH
SECTION 501 SCOPE
SECTION 502 - BUILDING ENVELOPE REQUIREMENTS 25 502.1 General 25 502.1.1 25 502.1.2 26 502.1.3 26 502.1.4 Insulation 26 602.1.4 Insulation 26
502.1.4.1 General

•

	502.1.4.3 Clearances	.26
	502.1.4.4 Access Hatches and Doors	.26
	502.1.4.5 Roof/Ceiling Insulation	.27
	502.1.4.6 Wall Insulation	27
	502.1.4.7 Floor Insulation	27
	502.1.4.8 Slab-On-Grade	27
	502.1.4.9 Radiant Slabs	28
	502.1.4.10 Below-Grade Walls	28
	502.1.5 Glazing and Door U-Values	28
	502.1.5.1 Standard Procedure for Determination of	
	Glazing U-Values	29
	502.1.5.2 Standard Procedure for Determination of	
	Door U-Values	29
	502.1.6 Moisture Control	30
	502.1.6.1 Vapor Retarders	30
	502.1.6.2 Floors	30
	502.1.6.3 Roof/Ceilings	30
	502.1.6.4	30
	502.1.6.5	30
	502.1.6.6 Walls	30
	502.1.6.7 Ground Cover	30
	502.2 Thermal Criteria for Group R Occupancy	31
	502.2.1 UA Calculations	31
	502.2.2 Space Heat Type	31
	502.3 Reserved	31
	502.4 Air Leakage	31
	502.4.1 General	31
	502.4.2 Doors and Windows, General	31
	502.4.3 Seals and Weatherstripping	31
	502.4.4 Recessed Lighting Fixtures	32
		-
I	ION 503 - BUILDING MECHANICAL SYSTEMS	32
	503.1 General	32
	503.2 Calculations of Heating/Cooling Loads and	
	System Sizing Limits	32
	503.2.1 Calculation Procedures	32
	503.2.2 Space Heating and Space Cooling System	
	Sizing Limits	32
	503.3 Simultaneous Heating and Cooling	33
	503.4 HVAC Equipment Performance Requirements	34
	503.4.1 Equipment Components	34
	503.4.1.1 General	34
	503.4.1.2 Assembled Components	34
	503.4.2 HVAC System Heating Equipment, Heat Pump.	
	Heating Mode	34
	503.4.2.1 Application	34
	503.4.2.2 Reserved	34
	503.4.2.3 Supplementary Heater	34
	503.4.2.4 Heat Pump Controls	34
	503.4.3 HVAC System Combustion Equipment	35
		-

Ì

SEC

	503.4.4 Packaged and Unitary HVAC System Equipment,	
	Electrically Operated, Cooling Mode	
	503.4.4.1 Application	
	503.4.5 Reserved	
	503.4.6 Reserved	
	503.5 Reserved	
	503.6 Balancing	
	503.7 Cooling with Outdoor Air (Economizer Cycle)	
	503.8 Controls	
	503.8.1 Temperature Control	
	503.8.1.1	
	503.8.1.2	
	503.8.1.3	
	503.8.2 Humidity Control	
	503.8.3 Zoning for Temperature Control	
	503.8.3 1 One and Two-Family Dwellings	
	503.0.3.1 One- and Two Failings	
	503.8.3.2 Multitanity Dwennigs	
	503.8.3.5 Reserved Sathack and Shut-Off 37	
	503.8.3.4 Control Setback and Shar-Ort	
	503.8.5.5 Heat Pump Controls	
	503.9 Air Handling Duct System Insulation	
	503.10 Duct Construction	
	503.10.1 Leakage Testing	
	503.10.2 Seams and Joints	
	503.10.3 Dampers	
	503.11 Piping Insulation	
	503.11.1 Other Insulation Thickness	
EC	TION 504 SERVICE WATER HEATING	
EC	504 1 Score	
	504.2 Water Heaters Storage Tanks and Boilers	
	504.2 1 Derformance Efficiency	
	504.2.2 Ferriormance Efficiency	
	504.2.2 Insulation Service Water Heating/Space	
	Vestice Beilger 39	
	Heating Bollers	
	504.5 Automatic Controls	
	504.4 Snutdown	
	504.5 Swimming Pools	
	504.5.1 Controls	
	504.5.2 Pool Covers	
	504.6 Pump Operation	
	504.7 Pipe Insulation	
	504.8 Conservation of Hot water	
	504.8.1 Showers and Lavatories	
	504.8.2 Lavatories in Rest Rooms of Public Pacifices	
	504.8.2.1 Controls	
	504.8.2.2 Temperature40	
E	CTION 505 RESERVED	
* B.a. 1		

EQUATION 1 GROUP R OCCUPANCY TARGET UA	. 41
EQUATION 2 ALL OCCUPANCIES	. 42
EQUATION 3 - GROUP R OCCUPANCY PROPOSED UA	.43
EQUATION 4 RESERVED	. 44
EQUATION 5 RESERVED	. 44
TABLE 5-1 TARGET COMPONENT VALUES FOR GROUP R OCCUPANCY	.45
TABLE 5-2 Reserved	. 46
TABLE 5-3 Reserved	. 46
TABLE 5-4 HVAC SYSTEM HEATING EQUIPMENT (HEAT PUMPS) ELECTRICALLY OPERATED STANDARD RATING CONDITIONS	. 47
TABLE 5-5 HVAC SYSTEM EQUIPMENT, ELECTRICALLY DRIVEN STANDARD RATING CONDITIONSCOOLING	.47
TABLE 5-6 APPLIED HVAC SYSTEM COMPONENTS ELECTRICALLY DRIVEN STANDARD RATING CONDITIONS COOLING	48
TABLE 5-7 MINIMUM HEAT PUMP EFFICIENCIES, HEATING MODE	49
TABLE 5-8 MINIMUM EFFICIENCY FOR ELECTRIC HVAC EQUIPMENT, COOLING	49
TABLE 5-9 RESERVED	50
TABLE 5-10 RESERVED	50
TABLE 5-11 INSULATION OF DUCTS	51
TABLE 5-12 MINIMUM PIPE INSULATION REQUIREMENTS	52
TABLE 5-13 RESERVED	53
CHAPTER 6 BUILDING DESIGN BY PRESCRIPTIVE REQUIREMENTS APPROACH	55
SECTION 601 SCOPE	55 55
SECTION 602 BÜILDİNG ENVELOPE REQUIREMENTS FOR GROUP R OCCUPANCY	55 55 55
Out.5 Exterior walls (below Grade)	S

602.4 Slab-on-Grade Floors	
602.5 Floors Over Unconditioned Space	
602.6 Exterior Doors	
602.6.1 Exterior Door Area	
602.0.2 Exterior Door O. value	
602.7.1 Glazing Area	
602.7.2 Glazing U-Value	
602.8 Air Leakage for Group R Occupancy	
SECTION 602 PULL DING MECHANICAL SYSTEMS	
FOR GROUP R OCCUPANCY	
603.1	
57	
SECTION 604 RESERVED	
SECTION 605 RESERVED	
SECTION (OF DESERVED	
SECTION 606 RESERVED	
SECTION 607 RESERVED	
SECTION 608 RESERVED	
TABLE 6-1 PRESCRIPTIVE REQUIREMENTS FOR	
GROUP R OCCUPANCE, CLIMATE LONE 1, HEATING BY ELECTRIC RESISTANCE	
HEATING BT ELECTRIC RESISTANCE	
TABLE 6-2 PRESCRIPTIVE REQUIREMENTS FOR	
GROUP R OCCUPANCY, CLIMATE ZONE 1,	
HEATING BY OTHER FUELS	
TABLE 6-3 PRESCRIPTIVE REQUIREMENTS FOR	
GROUP R OCCUPANCY, CLIMATE ZONE 2,	
HEATING BY ELECTRIC RESISTANCE	
TABLE 6-4 PRESCRIPTIVE REQUIREMENTS FOR	
GROUP R OCCUPANCY, CLIMATE ZONE 2,	
HEATING BY OTHER FUELS61	
TABLE 6.5 LOG HOMES PRESCRIPTIVE REQUIREMENTS.	
HEATING BY ELECTRIC RESISTANCE	
THE ALL OF HOUSE PRESCRIPTIVE PROLUDEMENTS	
TABLE 6-6 LOG HOMES PRESCRIPTIVE REQUIREMENTS,	
HEATING BY OTHER FOELS	
TABLE 6-7 RESERVED	
APTER 7 STANDARDS	
SECTION 701 STANDARDS	
ACCREDITED AUTHORITATIVE AGENCIES	

CI

CHAPTER 8 SUGGESTED SOFTWARE FOR CHAPTER 4
SYSTEMS ANALYSIS APPROACH FOR GROUP R
000017470174111111111111111111111111111
CHAPTER 9 PRESCRIPTIVE HEATING SYSTEM SIZING
CHAPTER 10 DEFAULT HEAT LOSS COEFFICIENTS
SECTION 1001 - GENERAL
1001.1 Scope
1001.2 Description
SECTION 1002 BELOW GRADE WALLS AND SLABS
1002.1 General
1002.2 Component Description
1002.3 Insulation Description
TABLE 10-1 DEFAULT WALL U-VALUES AND
SLAB F-VALUES FOR BASEMENTS75
SECTION 1003 ON-GRADE SLAB FLOORS
1003.1 General
1003.2 Component Description76
1003.3 Insulation Description
TABLE 10-2DEFAULT F-VALUES FOR ON-GRADE SLABS
SECTION 1004 CRAWLSPACE FLOORS
1004.1 General
1004.2 Crawlspace Description77
1004.3 Construction Description \mathcal{T}
TABLE 10-3 DEFAULT U-VALUES FOR FLOORS OVER
VENTED CRAWLSPACE OR UNHEATED BASEMENT
TABLE 10-4 DEFAULT U-VALUES FOR FLOORS OVER
HEATED PLENUM CRAWLSPACES
SECTION 1005 ABOVE GRADE WALLS 79
1005.1 General
1005.2 Framing Description79
1005.3 Component Description
TABLE 10-5 DEFAULT U-VALUES FOR
ABOVE-GRADE WALLS
SECTION 1006 DEEALILY IL VALUES FOR CLAZING
AND DOORS 88
1006.1 Untested Glazing and Doors
TABLE TO-OA: WINDOW DEPAULT TABLE
TADLE 10 CD. ADDDOVED WINDOW AND SEVELICIT

•

DEFAULT TABLE

TABLE 10-6C: TRANSMISSION COEFFICIENTS (U) FOR WOOD AND STEEL DOORS	92
TABLE 10-6D: APPROVED GLAZED DOOR DEFAULT U-VALUES	93
SECTION 1007 CEILINGS 1007.1 General 1007.2 Component Description	95 95 95
TABLE 10-7 DEFAULT U-VALUES FOR CEILINGS	.97
SECTION 1008 AIR INFILTRATION 1008.1 General	. 98 . 98
TABLE 10-8 ASSUMED EFFECTIVE AIR CHANGES PER HOUR	.98
TABLE 10-9 DEFAULT HEAT CAPACITY/DENSITY PRODUCT FOR AIR	. 98
SECTION 1009 MASS 1009.1 General 1009.2 Mass Description 1009.3 Component Description	99 99 99 99
TABLE 10-10 DEFAULT MASS VALUES	100

х

CHAPTER 11 ADMINISTRATION AND ENFORCEMENT	101
SECTION 1100 TITLE	101
SECTION 1100 PURPOSE AND INTENT	101
SECTION 1120 SCOPE	101
SECTION 1130 APPLICATION TO EXISTING BUILDINGS	101
1131 Additions to Existing Buildings	101
1132 Alterations and Repairs	102
1132.1 Building Envelope	102
1132.2 Building Mechanical Systems	102
1132.3 Lighting and Motors	103
1133 Change of Occupancy or Use	103
1134 Historic Buildings	103
SECTION 1140 ENFORCEMENT	103
1141 Plans and Specifications	103
1141.1 General	103
1141.2 Details	104
1141.3 Alternate Materials and Method of Construction	104
1141.4 Systems Analysis Approach for the Entire	
Building	104
1142 Materials and Equipment	104
1142.1 Identification	104
1142.2 Maintenance Information	104
1143 Inspections	105
1143.1 General	105
1143.2 Required Inspections	105
1143.2.1 Envelope	105
1143.2.2 Mechanical	105
1143.2.3 Lighting and Motors	105
1143.3 Re-inspection	105
1144 Violations	105
SECTION 1150 CONFLICTS WITH OTHER CODES	106
SECTION 1160 SEVERABILITY & LIABILITY	06
1161 Severability	106
1162 Liability	00
······································	00
CHAPTER 12 DEFINITIONS 1	07
1201 Scope 1	07
SECTION 1210 APPLICATION OF TERMS 1	07
CHAPTER 13 BUILDING ENVELOPE	10
1301 Scope	10
1302 Space Heat Type	19
1303 Climate Zones	19
1000 Chillate Zones	19

•

SECTION 1310 GENERAL REQUIREMENTS 12	0
1310.1 Conditioned Spaces 12	0
1310.2 Semi-Heated Spaces 12	0
The second secon	1
Figure 13A Building Envelope Compliance Options	1
1311 Insulation	1
1311.7 Recof/Ceiling Insulation	1
1311.3 Wall Insulation	22
1311.4 Floor Insulation	2
1311.5 Slab-On-Grade Floor 12	2
1311.6 Radiant Floors (on or below grade) 12	22
1312 Glazing and Doors 12	22
1312.1 Standard Procedure for Determination	22
of Glazing and Door U-Factors	12
1312.2 Solar Heat Gain Coefficient and	22
Shading Coefficient	23
1313 Moisture Control	23
1313.1 Vapor Retarders	23
1313.2 Root/Centing Assemblies	23
1313.5 Walls	23
1313 5 Crawl Spaces	23
1314 Air Leakage	23
1314.1 Building Envelope	23
1314.2 Glazing and Doors 1	24
1314.3 Building Assemblies Used as Ducts or Plenums 1	24
ARCTION 1220 PRESCRIPTIVE BUILDING	
SECTION 1320 PRESCRIPTIVE BOILDING	24
1321 General	24
1322 Onaque Envelope	24
1323 Glazing	24
1323.1 Area 1	25
1323.2 U-Factor 1	25
1323.3 Solar Heat Gain Coefficient 1	25
COMPONENT DEDEODMANCE	
SECTION 1330 COMPONENT PERFORMANCE	25
BUILDING ENVELOPE OPTION	25
1331 General	26
1333 UA Calculations	26
1334 Solar Heat Gain Coefficient 1	126
100100001000	127
Equation 13-1 Target UAt	121
Equation 13-2 Proposed UAp 1	129
Edución 15 % (report of the	120
Table 13-1 Building Envelope Requirements For Climate Zone 1	130
Table 13-2 Building Envelope Requirements For Climate Zone 2	131

CHAPTER 14 BUILDING MECHANICAL SYSTEMS	133
1401 Scope	133
1402 Mechanical Ventilation	133
SECTION 1410 GENERAL REQUIREMENTS	133
Figure 144 Machanizal Guatama Come l'and But	
Figure 14A Mechanical Systems Compliance Paths	134
1411 HVAC Equipment Performance Requirements	135
1411.1 General	135
1411.2 Rating Conditions	135
1411.3 Combination Space and Service Water Heating	135
1411.4 Packaged Electric Heating and	-
Cooling Equipment	135
1412 Controls	135
1412.1 Temperature Controls	135
1412.2 Deadband Controls	135
1412.3 Humidity Controls	135
1412.4 Setback and Shut-Off	136
1412.4.1 Dampers	136
1412.5 Heat Pump Controls	136
1412.6 Combustion Heating Equipment Controls	136
1412.7 Balancing	136
1413 Air Economizers	136
1413.1 Operation	136
1413.2 Control	137
1413.3 Integrated Operation - Building Heating Energy	137
1414 Ducting Systems	137
1414.1 Sealing	137
1414.2 Insulation	137
1415 Piping Systems	137
1415.1 Insulation	137
	157
Section 1420 Simple Systems (Packaged Unitary Equipment)	138
1421 System Type	138
1422 Controls	138
1423 Economizers	138
1424 Senarate Air Distribution Systems	138
	150
SECTION 1430 COMPLEX SYSTEMS	138
1431 System Type	138
1431.1 Field-Assembled Equipment and Components	138
1432 Controls	139
1432.1 Setback and Shut-Off.	139
1432.2 Systems Temperature Reset Controls	139
1432.2.1 Air Systems for Multiple Zones	139
1432.2.2 Hydronic Systems	139
1433 Economizers	139
1434 Separate Air Distribution Systems	40
1435 Simultaneous Heating and Cooling	140
1436 Heat Recovery	41
1437 Electric Motor Efficiency	41
1438 Variable Flow Systems	143
radio randole riow systems	42

P

	SECTION 1440 - SERVICE WATER HEATING
	1441 Water Heater Installation
	SECTION 1450 HEATED POOLS
	1451 General
	1453 Controls
	1454 Pool Covers 142
	TABLE 14-1 Standard Rating Conditions and Minimum
	Performance for Air Cooled Unitary Air Conditioners,
	Heat Pumps, Packaged Terminal Air Conditioners, Warm Air
	Furnaces, Duct Furnaces and Unit Heaters
	TABLE 14-2 Standard Rating Conditions and Minimum
	Performance for Water and Evaporatively Cooled Unitary
	Air Conditioners, Heat Pumps, Water Source and Ground Source
	Heat Pumps, Condensing Units and water Chinning Packages
	TABLE 14-3 Standard Rating Conditions and Minimum
	Performance, Gas- and Oil-Fired Boilers 145
	TABLE 14-4 Energy Efficient Electric Motors Minimum
	Nominal Full-Load Efficiency 145
	TABLE 14-5 Duct Insulation 146
	TABLE 14-6 Minimum Pipe Insulation 147
H/	APTER 15 LIGHTING AND MOTORS 149
	1501 Scope 149
	SECTION 1510 GENERAL REQUIREMENTS 149
	Figure 15A Lighting and Motor Compliance Options
	1511 Electric Motors 150
	1512 Exempt Lighting 150
	1512.1 Exempt Spaces
	1512.2 Exempt Lighting Equipment
	1513 L Local Control and Accessibility
	1513.2 Area Controls
	1513.3 Daylight Zone Control 151
	1513.4 Display, Exhibition, and Specialty Lighting
	Controls
	1513.5 Automatic Shut-off Controls, Exterior
	1513.6 1 Occupancy Sensors
	1513.6.2 Automatic Time Switches

C



SECTION 1520 DEECODEDINE LOUTING OFFICE	
SECTION 1520 PRESCRIPTIVE LIGHTING OPTION	152
1521 Prescriptive Interior Lighting Requirements	152
1322 Prescriptive Exterior Lighting Requirements	152
SECTION 1530 LIGHTING POWER ALLOWANCE OPTION	152
1531 Interior Lighting Power Allowance	153
1532 Exterior Lighting Power Allowance	153
	155
TABLE 15-1 Unit Lighting Power Allowance (LPA)	154
CHAPTER 16 (RESERVED)	159
	150
CHAPTER 17 STANDARDS	159
1701 Scope	159
CHAPTER 18 (RESERVED)	101
	101
CHAPTER 19 (RESERVED)	161
CHAPTER 20 DEFAULT HEAT LOSS COEFFICIENTS	167
2001 General	167
2001 1 Scope	162
2001 2 Description	163
2001 3 Air Films	103
2001 A Compression of Insulation	103
2001.4 Compression of insulation	103
TABLE 20-A - R-Value of Fiberglass Batts Compressed Within	
Various Depth Cavities	163
2002 Below Grade Walls And Slabs	164
2002.1 General	164
2002.2 Component Description	164
2002.3 Insulation Description	164
	104
TABLE 20-1 Default Wall U-Factors and Slab F-Factors	
for Basements	165
2003 On-Grade Slab Floors	166
2003.1 General	166
2003.2 Component Description	166
2003.3 Insulation Description	166
TABLE 20-2 Default F-Factors for On-Grade Slabs	166
2004 Floors Over Unconditioned Space	167
2004.1 General.	167
2004.2 Category Description	167
2004.3 Construction Description	167
TABLE 20-3 Default U-Pactors for Ploors Over Crawlspace	-
or Unneated Basement 1	68
TABLE 20-4 Default U-factors for Floors Over Heated Plenum	
Crawlspace	68
	00

TABLE 20-4A Exposed Floors	168
2005 Above Grade Walls	169
2005.1 General	169
2005.2 Framing Description	169
2005 3 Component Description	170
Loopin company i.	
TABLE 20-5 Default U-factors for Above-Grade Walls	1/1
The state of the s	
TABLE 20-5A Default U-Factors and Effective R- values	177
for Metal Stud Walls	
TADLE 20 SP Default II-Factors for Concrete and	
TABLE 20-5B - Detadir C-1 actors for Commence	178
2006 Default LI-Factors for Glazing and Doors	180
2006 L Uptested Glazing and Doors	180
2000.1 Oncored Onlying and Deere the	
TABLE 20-6 Default U-Factors for Vertical Glazing, Overhead	
Glazing and Opaque Doors	180
2007 Ceilings	181
2007.1 General	181
2007.2 Component Description	181
	197
TABLE 20-7 Default U-factors for Ceilings	102
Default IL factors for Ceilings	183
TABLE 20-7 (Continued) Default O-factors for Certifies	183
2008 (Reserved)	183
2009 Mass	183
2009.1 General	
TARLE 20-10 HEAT CAPACITY	183

SECTION 101 -- SCOPE AND GENERAL REQUIREMENTS

101.1 Title: Chapters 1 through 10 of this Code shall be known as the "Washington State Residential Energy Code" and may be cited as such; and will be referred to herein as "this Code."

101.2 Purpose and Intent: The purpose of this Code is to provide minimum standards for new or altered buildings and structures or portions thereof to achieve efficient use and conservation of energy.

The purpose of this Code is not to create or otherwise establish or designate any particular class or group of persons who will or should be especially protected or benefitted by the terms of this Code.

It is intended that these provisions provide flexibility to permit the use of innovative approaches and techniques to achieve efficient use and conservation of energy. These provisions are structured to permit compliance with the intent of this Code by any one of the following three paths of design:

- A systems analysis approach for the entire building and its energyusing sub-systems which may utilize renewable energy sources; Chapter 4.
- A component performance approach for various building elements and mechanical systems and components; Chapter 5.
- 3. A prescriptive requirements approach; Chapter 6.

Compliance with any one of these approaches meets the intent of this Code. This Code is not intended to abridge any safety or health requirements required under any other applicable codes or ordinances.

The provisions of this Code do not consider the efficiency of various energy forms as they are delivered to the building envelope. A determination of delivered energy efficiencies in conjunction with this Code will provide the most efficient use of available energy in new building construction.

101.3 Scope: This Code sets forth minimum requirements for the design of new buildings and structures that provide facilities or shelter for residential occupancies by regulating their exterior envelopes and the selection of their HVAC and service water heating systems for efficient use and conservation of energy.

Buildings shall be designed to comply with the requirements of either Chapter 4, 5, or 6 of this Code.

101.3.1 Exempt Buildings: Buildings and structures or portions thereof meeting

any of the following criteria shall be exempt from the building envelope requirements of Section 502 and Sections 602 and 605, but shall comply with all other requirements for building mechanical systems, and service water heating.

101.3.1.1: Buildings and structures or portions thereof whose peak design rate of energy usage is less than 3.4 Btu/h per ft² or 1.0 watt per ft² of floor area for space conditioning requirements.

101.3.1.2: Buildings and structures or portions thereof which are neither heated according to the definition of heated space in Chapter 2, nor cooled by a non-renewable energy source, provided that the non-renewable energy use for space conditioning complies with requirements of Section 101.3.1.1.

101.3.1.3: Greenhouses isolated from any conditioned space and not intended for occupancy.

101.3.2 Application to Existing Buildings: Additions, historic buildings, changes of occupancy or use and alterations or repairs shall comply with the requirements in the subsections below.

Exception: The building official may approve designs of alterations or repairs which do not fully conform with all of the requirements of this Code where in the opinion of the building official full compliance is physically impossible and/or economically impractical and:

- 1. The alteration or repair improves the energy efficiency of the building; or
- The alteration or repair is energy efficient and is necessary for the health, safety and welfare of the general public.

In no case shall building envelope requirements or mechanical system requirements be less than those requirements in effect at the time of the initial construction of the building.

101.3.2.1 Additions to Existing Buildings: Additions to existing buildings or structures may be made to such buildings or structures without making the entire building or structure comply, provided that the new additions shall conform to the provisions of this Code.

Exception: New additions which do not fully comply with the requirements of this Code and which have a floor area which is less than seven hundred fifty square feet shall be approved provided that improvements are made to the existing occupancy to compensate for any deficiencies in the new addition. Compliance shall be demonstrated by

either systems analysis or component performance calculations. The nonconforming addition and upgraded, existing occupancy shall have an energy budget or heat loss which is less than or equal to the unimproved existing building, with the addition designed to comply with this Code.

101.3.2.2 Historic Buildings: The building official may modify the specific requirements of this Code for historic buildings and require in lieu thereof alternate requirements which will result in a reasonable degree of energy efficiency. This modification may be allowed for those buildings which have been specifically designated as historically significant by the state or local governing body, or listed in The National Register of Historic Places or which have been determined to be eligible for listing.

101.3.2.3 Change of Occupancy or Use: Any Other than Group R Occupancy which is converted to Group R Occupancy shall be brought into full compliance with this Code.

101.3.2.4 Alterations and Repairs: All alterations and repairs to buildings or portions thereof originally constructed subject to the requirements of this Code shall conform to the provisions of this Code without exception. For all other existing buildings, initial tenant alterations shall comply with the new construction requirements of this Code. Other alterations and repairs may be made to existing buildings and moved buildings without making the entire building comply with all of the requirements of this Code for new buildings, provided the following requirements are met:

101.3.2.5 Building Envelope: The result of the alterations or repairs both:

- 1. Improves the energy efficiency of the building, and
- Complies with the overall average thermal transmittance values of the elements of the exterior building envelope in Table 5-1 of Chapter 5, or the nominal R-values and glazing requirements of the reference case in Tables 6-1 to 6-6.

Exceptions:

- 1. Untested storm windows may be installed over existing glazing for an assumed U-value of 0.90, however, where glass and sash are being replaced in Group R Occupancy, glazing with a maximum area weighted average U-value of 0.40 shall be installed where there is an electric resistance space heating system and glazing with a maximum U-value of 0.65 (Climate Zone I) and 0.60 (Climate Zone II) shall be installed where there is any other space heating system.
- 2. Where the structural elements of the altered portions of roof/ceiling, wall or floor are not being replaced, these elements shall be deemed to comply with this Code if all existing framing cavities which are exposed during construction are filled to the full depth with batt insulation or insulation having an equivalent nominal R-value while, for roof/ceilings, maintaining

the required space for ventilation. Existing walls and floors without framing cavities need not be insulated. Existing roofs shall be insulated to the requirements of this Code if:

- a. The roof is uninsulated or insulation is removed to the level of the sheathing, or
- b. All insulation in the roof/ceiling was previously installed exterior to the sheathing or non-existent.

101.3.2.6 Building Mechanical Systems: Those parts of systems which are altered or replaced shall comply with Section 503 of this Code.

101.3.2.7 Service Water Heating: Those parts of systems which are altered or replaced shall comply with Section 504 of this Code.

101.3.2.8 : Reserved

101.3.3 Mixed Occupancy: When a building houses more than one occupancy, each portion of the building shall conform to the requirements for the occupancy housed therein. Where approved by the building official, where minor accessory uses do not occupy more than 10% of the area of any floor of a building, the major use may be considered the building occupancy.

101.4 Amendments By Local Government: Except as provided in RCW 19.27A.020(7), this Code shall be the maximum and minimum energy Code for Group R Occupancies in each town, city and county, no later than July 1, 1991.

SECTION 102 - MATERIALS AND EQUIPMENT

102.1 Identification: All materials and equipment shall be identified in order to show compliance with this Code.

102.2 Maintenance Information: Required regular maintenance actions shall be clearly stated and incorporated on a readily accessible label. Such label may be limited to identifying, by title or publication number, the operation and maintenance manual for that particular model and type of product. Maintenance instructions shall be furnished for any equipment which requires preventive maintenance for efficient operation.

SECTION 103 -- ALTERNATE MATERIALS--METHOD OF CONSTRUCTION, DESIGN OR INSULATING SYSTEMS

The provisions of this Code are not intended to prevent the use of any material, method of construction, design or insulating system not specifically prescribed herein, provided that such construction, design or insulating system has been approved by the building official as meeting the intent of this Code. The building official may approve any such alternate provided he finds the proposed alternate meets or exceeds the provisions of this Code and that the material, method, design or work offered is for the purpose intended, at least the equivalent of that prescribed in this Code, in quality, strength, effectiveness, fire-resistance, durability, safety and efficient use and conservation of energy. The building official may require that sufficient evidence of proof be submitted to substantiate any claims that may be made regarding performance capabilities.

SECTION 104 -- PLANS AND SPECIFICATIONS

104.1 General: If required by the building official, plans and specifications shall be submitted in support of an application for a building permit. If required by the building official, plans and specifications shall be stamped and authenticated by a registered design professional currently licensed in the state of Washington. All plans and specifications, together with supporting data, shall be submitted to the building official prior to issuance of a building permit.

104.2 Details: The plans and specifications shall show in sufficient detail all pertinent data and features of the building and the equipment and systems as herein governed including, but not limited to: design criteria, exterior envelope component materials, U-values of the envelope systems, R-values of insulating materials, size and type of apparatus and equipment, equipment and systems controls and other pertinent data to indicate compliance with the requirements of this Code.

The building official may accept the professional stamp of an architect or engineer licensed to do business by the state in lieu of a plan and specification check if the engineer or architect stipulates to the best of his knowledge, understanding and belief, the design meets the requirements of this Code.

SECTION 105 -- INSPECTIONS AND ENFORCEMENT

105.1 General: All construction or work for which a permit is required shall be subject to inspection by the building official and all such construction or work shall remain accessible and exposed for inspection purposes until approved by the building official.

105.2 Approvals Required: No work shall be done on any part of the huilding or structure beyond the point indicated in each successive inspection without first obtaining the approval of the building official.

105.2.1 Required Inspections: The building official, upon notification, shall make the following inspection in addition to those inspections required in Section 305(e) of the Washington State Uniform Building Code:

 Wall Insulation Inspection: To be made after all wall insulation and air vapor retarder sheet or film materials are in place, but before any wall covering is placed.

105.3 Reinspection: The building official may require a structure to be reinspected.

SECTION 106 -- VIOLATIONS

It shall be unlawful for any person, firm, or corporation to erect or construct any building, or remodel or rehabilitate any existing building or structure in the state, or allow the same to be done, contrary to or in violation of any of the provisions of this Code.

SECTION 107 - LIABILITY

Nothing contained in this Code is intended to be nor shall be construed to create or form the basis for any liability on the part of any city or county or its officers, employees or agents for any injury or damage resulting from the failure of a building to conform to the provisions of this Code.

SECTION 108 - CONFLICTS WITH OTHER CODES

In addition to the requirements of this Code, all occupancies shall conform to the provisions included in the State Building Code (Chapter 19.27 RCW) and Uniform Building Code and Standards Adoption and Amendment rules (Chapter 51-20 and 51-21 WAC). In case of conflicts among Codes enumerated in RCW 19.27.031 subsections (1), (2), (3) and (4) and this Code, the first named Code shall govern over the following. Provided, in the case of conflict between the duct insulation requirements of this Code and the duct insulation requirements of Section 1005 of the Uniform Mechanical Code (Chapter 51-22 WAC), the duct insulation requirements of this Code, or where applicable, a local jurisdiction's energy Code shall govern.

Where, in any specific case, different sections of this Code specify different materials, methods of construction or other requirements, the most restrictive shall govern. Where there is a conflict between a general requirement and a specific requirement, the specific requirement shall be applicable. Wherever in this Code reference is made to the appendix, the provisions in the appendix shall not apply unless specifically adopted.

SECTION 109 - SEVERABILITY

6

If any provision of this Code or its application to any person or circumstance is held invalid, the remainder of this Code or the application of the provision to other persons or circumstances is not affected.

CHAPTER 2 DEFINITIONS

SECTION 201 - GENERAL DEFINITIONS

201.1 Application of Terms: For the purposes of this Code, certain abbreviations, terms, phrases, words and their derivatives, shall be as set forth in this chapter. Where terms are not defined, they shall have their ordinary accepted meanings within the context with which they are used. In the event there is a question about the definition of a term, the definitions for terms in the Codes enumerated in RCW 19.27.031 and the edition of Webster's dictionary referenced therein shall be considered as the sources for providing ordinarily accepted meanings.

AAMA: American Architectural Manufacturers Association.

ADDITION: See the Washington State Building Code.

۲

ADVANCED FRAMED CEILING: Advanced framing assumes full and even depth of insulation extending to the outside edge of exterior walls. (See Standard Framing and Section 1007.2 of this Code.)

ADVANCED FRAMED WALLS: Studs framed on 24 inch centers with double top plate and single bottom plate. Corners use two studs or other means of fully insulating corners, and one stud is used to support each header. Headers consist of double 2X material with R-10 insulation between the header and exterior sheathing. Interior partition wall/exterior wall intersections are fully insulated in the exterior wall.

AFUE - ANNUAL FUEL UTILIZATION EFFICIENCY: Unlike steady state conditions, this rating is based on average usage including on and off cycling as set out in the standardized Department of Energy Test Procedures.

AIR CONDITIONING, COMFORT: The process of treating air to control simultaneously its temperature, humidity, cleanliness and distribution to meet requirements of the conditioned space.

ASHRAE: American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

ASTM: American Society for Testing and Materials.

AUTOMATIC: Self-acting, operating by its own mechanism when actuated by some impersonal influence, as for example, a change in current strength, pressure, temperature or mechanical configuration. (See Manual.)

BELOW GRADE WALLS: Walls or the portion of walls which are entirely below the finished grade or which extend two feet or less above the finished grade.

BUILDING, EXISTING: See the Washington State Building Code.

BOILER CAPACITY: The rate of heat output in Btu/h measured at the boiler outlet, at the design inlet and outlet conditions and rated fuel/energy input.

BUILDING ENVELOPE: The elements of a building which enclose conditioned spaces through which thermal energy may be transferred to or from the exterior or to or from spaces exempted by the provisions of Section 101.3.1.

BUILDING OFFICIAL: The official authorized to act in behalf of a jurisdiction code enforcement agency or its authorized representative.

BUILDING PROJECT: A building or group of buildings, including on-site energy conversion or electric-generating facilities, which utilize a single submittal for a construction permit or are within the boundary of a contiguous area under one ownership.

COMFORT ENVELOPE: The area on a psychometric chart enclosing all those conditions described in Standard RS-4, Figure No. 1, as being comfortable.

CONDITIONED SPACE: All spaces which are provided with heated and/or cooled air or which are capable of being maintained at temperatures over 50°F during the heating season, including adjacent connected spaces separated by an uninsulated component (e.g., basements, utility rooms, garages, corridors).

COOLED SPACE: Space within a building which is provided with a positive cooling supply.

COP - COEFFICIENT OF PERFORMANCE: The ratio of the rate of net heat output (heating mode) or heat removal (cooling mode) to the rate of total on-site energy input to the heat pump, expressed in consistent units and under designated rating conditions. (See Net Heat Output, Net Heat Removal, Total On-Site Energy Input.)

DEADBAND: The temperature range in which no heating or cooling is used.

DEGREE DAY, HEATING: A unit, based upon temperature difference and time, used in estimating fuel consumption and specifying nominal heating load of a building in winter. For any one day when the mean temperature is less than 65°F there exist as many degree days as there are Fahrenheit degrees difference in temperature between the mean temperature for the day and 65°F.

9

DOOR: An operable opening area in the shell of a conditioned space, excluding sliding glass doors, which is designed and used as a means of ingress and egress. A door may also include a double door one of which is fixed and one of which is operable.

DOOR AREA: Total area of door measured using the rough opening and including the door and frame.

DWELLING UNIT: See the Washington State Building Code.

EER - ENERGY EFFICIENCY RATIO: The ratio of net equipment cooling capacity in Btu/h to total rate of electric input in watts under designated operating conditions.

EFFICIENCY, HVAC SYSTEM: The ratio of useful energy (at the point of use) to the energy input for a designated time period, expressed in percent.

EMISSIVITY: The ability to absorb infrared radiation. A low emissivity implies a higher reflectance of infrared radiation.

ENERGY: The capacity for doing work; taking a number of forms which may be transformed from one into another, such as thermal (heat), mechanical (work), electrical and chemical; in customary units, measured in kilowatt-hours (Kwh) or British thermal units (Btu). (See New Energy.)

ENERGY, RECOVERED: (See Recovered Energy.)

EXTERIOR ENVELOPE: (See Building Envelope.)

FLOOR OVER UNCONDITIONED SPACE: A floor which separates a conditioned space from an unconditioned space which is buffered from exterior ambient conditions including vented crawlspaces and unconditioned basements or other similar spaces, or exposed to exterior ambient conditions including open parking garages and enclosed garages which are mechanically ventilated.

F-VALUE: The perimeter heat loss factor expressed in Btu/h•ft•°F.

GLAZING: All areas, including the frames, in the shell of a conditioned space that let in natural light including windows, clerestories, skylights, sliding glass doors and glass block walls. The daylight opening area in all other doors shall be considered glazing for the purpose of calculating glazing area. The daylight opening area in all other doors is included in the door U-value and shall not be considered in calculations of glazing U-values.

GLAZING AREA: Total area of the glazing measured using the rough opening, and including the glazing, sash and frame. For sliding glass doors the glazing area is the rough opening area. For all other doors the glazing area is the daylight opening area.

GROSS CONDITIONED FLOOR AREA: The horizontal projection of that portion of interior space which is contained within exterior walls and which is conditioned directly or indirectly by an energy-using system, and which has an average height of five feet or greater, measured from the exterior faces.

GROSS EXTERIOR WALL AREA: The normal projection of the building envelope wall area bounding interior space which is conditioned by an energyusing system; includes opaque wall, window and door areas. The gross area of walls consists of all opaque wall areas, including foundation walls, between floor spandrels, peripheral edges of floors, window areas including sash, and door areas, where such surfaces are exposed to exterior ambient conditions and enclose a conditioned space including interstitial areas between two such spaces.

GROSS FLOOR AREA: The sum of the areas of the several floors of the building, including basements, cellars, mezzanine and intermediate floored tiers and penthouses of headroom height, measured from the exterior faces of exterior walls or from the center line of walls separating buildings, but excluding: Covered walkways, open roofed-over areas, porches and similar spaces, pipe trenches, exterior terraces or steps, chimneys, roof overhangs and similar features.

GROSS ROOF/CEILING AREA: The sum of the areas of the roof/ceiling assembly, consisting of the total interior surface area of all elements, including skylights, which enclose a conditioned space.

GUEST ROOM: See the Washington State Building Code.

HEAT: The form of energy that is transferred by virtue of a temperature difference.

IIEAT STORAGE CAPACITY: The physical property of materials (mass) located inside the building envelope to absorb, store and release heat.

IIEATED SPACE: Space within a building which is provided with a positive heating supply. Finished living space within a basement or registers or heating devices designed to supply heat to a basement space shall automatically define that space as heated space. (See Positive Heating Supply.)

HSPF - HEATING SEASON PERFORMANCE FACTOR: The total heating output (Btu) of a heat pump during its normal annual usage period for heating divided by the total electric power input (watt hour) during the same period, as determined by test procedures consistent with the U.S. Department of Energy "Test Procedure for Central Air Conditioners, Including Heat Pumps," published in the December 27, 1979, Federal Register, Vol. 44, No. 24, 10 CFR 430. When specified in Btu per watt hour an HSPF of 6.826 is equivalent to a COP of 2.0.

HUMIDISTAT: A regulatory device, actuated by changes in humidity, used for automatic control of relative humidity.

HVAC: Heating, ventilating and air conditioning.

HVAC SYSTEM COMPONENTS: HVAC system components provide, in one or more factory-assembled packages, means for chilling and/or heating water with controlled temperature for delivery to terminal units serving the conditioned spaces of the buildings. Types of HVAC system components include, but are not limited to, water chiller packages, reciprocating condensing units and water source (hydronic) heat pumps. (See IIVAC System Equipment.)

HVAC SYSTEM EFFICIENCY: (See Efficiency, HVAC System.)

HVAC SYSTEM EQUIPMENT: HVAC system equipment provides, in one (single package) or more (split system) factory-assembled packages, means for air circulation, air cleaning, air cooling with controlled temperature and dehumidification; and optionally, either alone or in combination with a heating plant, the functions of heating and humidifying. The cooling function may be either electrically or heat operated and the refrigerant condenser may be air, water or evaporatively cooled. Where the equipment is provided in more than one package, the separate packages shall be designed by the manufacturer to be used together. The equipment may provide the heating function as a heat pump or by the use of electric elements. (The word "equipment" used without modifying adjective may, in accordance with common industry usage, apply either to HVAC system equipment or HVAC system components.)

ILLUMINATION: The density of the luminous flux incident on a surface; it is the quotient of the luminous flux by the area of the surface when the latter is uniformly illuminated.

INFILTRATION: The uncontrolled inward air leakage through cracks and interstices in any building element and around windows and doors of a building caused by the pressure effects of wind and/or the effect of differences in the indoor and outdoor air density.

INSULATION BAFFLE: A rigid material, resistant to wind driven moisture, the purpose of which is to allow air to flow freely into the attic or crawl space and to prevent insulation from blocking the ventilation of these spaces, or the loss of insulation. Example materials for this purpose are sheet metal or wax impregnated cardboard.

LUMINAIRE: A complete lighting unit consisting of a lamp or lamps together with the parts designed to distribute the light, to position and protect the lamps and to connect the lamps to the electric power supply.

MANUAL: Capable of being operated by personal intervention. (See Automatic.)

NET HEAT OUTPUT: The change in the total heat content of the air entering and leaving the equipment (not including supplementary heat and heat from boilers).

NET HEAT REMOVAL: The total heat content of the air entering and leaving the equipment (without heat) or the difference in total heat content of the water or refrigerant entering and leaving the component.

NEW ENERGY: Energy, other than recovered energy, utilized for the purpose of heating or cooling. (See Energy.)

NOMINAL R-VALUE: The thermal resistance of insulation as specified by the manufacturer according to recognized trade and engineering standards.

NONRENEWABLE ENERGY SOURCES: All energy sources that are not renewable energy sources including natural gas, oil, coal, wood, liquified petroleum gas, steam and any utility-supplied electricity.

OCCUPANCY: See the Washington State Uniform Building Code.

OPAQUE ENVELOPE AREAS: All exposed areas of a building envelope which enclose conditioned space, except openings for windows, skylights, doors, glazing and building service systems.

OPEN BLOWN: Loose fill insulation pneumatically installed in an unconfined attic space.

OUTDOOR AIR: Air taken from the outdoors and, therefore, not previously circulated through the system.

PACKAGED TERMINAL AIR CONDITIONER: A factory-selected combination of heating and cooling components, assemblies or sections intended to serve a room or zone. (For the complete technical definition, see Standard RS-10.) PACKAGED TERMINAL HEAT PUMP: A factory-selected combination of heating and cooling components, assemblies or sections intended for application in an individual room or zone. (For the complete technical definition, see Standard RS-21.)

PERMEANCE (PERM): The ability of a material of specified thickness to transmit moisture in terms of amount of moisture transmitted per unit time for a specified area and differential pressure (grains per hour*ft²*inches of HG). Permeance may be measured using ASTM E-96-72 or other approved dry cup method as specified in Standard RS-1.

POOL COVER: A vapor-retardant cover which lies on or at the surface of the pool.

POSITIVE COOLING SUPPLY: Mechanical cooling deliberately supplied to a space, such as through a supply register. Also, mechanical cooling indirectly supplied to a space through uninsulated surfaces of space cooling components, such as evaporator coil cases and cooling distribution systems which are capable of maintaining air temperatures within the space of 85°F, or lower, at the exterior design conditions specified in Section 302.1. To be considered exempt from inclusion in this definition, such surfaces shall comply with the insulation requirements of this Code.

POSITIVE HEATING SUPPLY: Heat deliberately supplied to a space by design, such as a supply register, radiator or heating element. Also, heat indirectly supplied to a space through uninsulated surfaces of service water heaters and space heating components, such as furnaces, boilers and heating and cooling distributions systems which are capable of maintaining air temperature within the space of 50°F, or higher, at the exterior design conditions specified in Section 302.1. To be considered exempt from inclusion in this definition, such surfaces shall comply with the insulation requirements of this Code.

POWER: In connection with machines, the time rate of doing work. In connection with the transmission of energy of all types, the rate at which energy is transmitted; in customary units, it is measured in watts (W) or British Thermal Units per hour (Btu/h).

PUBLIC FACILITY REST ROOM: A rest room used by the transient public on a regular (rather than casual) basis. Examples include rest rooms in service stations, airports, train terminals and convention halls. Rest rooms incorporated with private guest rooms in hotels, motels or dormitories and rest room facilities intended for the use of employees and not usually used by the general public are not considered public facility rest rooms.

RADIANT SLAB: A slab on grade containing heated pipes, ducts, or electric heating cables that constitute a radiant slab or portion thereof for a complete or partial heating of the structure.

READILY ACCESSIBLE: See the Washington State Mechanical Code.

RECOOLING: The removal of heat by sensible cooling of the supply air (directly or indirectly) that has been previously heated above the temperature to which the air is to be supplied to the conditioned space for proper control of the temperature of that space.

RECOVERED ENERGY: Energy utilized which would otherwise be wasted (i.e., not contribute to a desired end use) from an energy utilization system.

REHEAT: The application of sensible heat to supply air that has been previously cooled below the temperature of the conditioned space by either mechanical refrigeration or the introduction of outdoor air to provide cooling.

RENEWABLE ENERGY SOURCES: Renewable energy sources of energy (excluding minerals) are derived from: (1) incoming solar radiation, including but not limited to, natural daylighting and photosynthetic processes; (2) energy sources resulting from wind, waves and tides, lake or pond thermal differences; and (3) energy derived from the internal heat of the earth, including nocturnal thermal exchanges.

RESET: Adjustment of the set point of a control instrument to a higher or lower value automatically or manually to conserve energy.

ROOF/CEILING ASSEMBLY: A roof/ceiling assembly shall be considered as all components of the roof/ceiling envelope through which heat flows, thus creating a building transmission heat loss or gain, where such assembly is exposed exterior ambient conditions to and encloses a conditioned space. The gross area of a roof/ceiling assembly consists of the total interior surface of such assembly, including skylights.

SEQUENCE: A consecutive series of operations.

SERVICE SYSTEMS: All energy-using systems in a building that are operated to provide services for the occupants or processes housed therein, including HVAC, service water heating, illumination, transportation, cooking or food preparation, laundering or similar functions.

SERVICE WATER HEATING: Supply of hot water for domestic or commercial purposes other than comfort heating.

SHADED: Glazed area which is externally protected from direct solar radiation by use of devices permanently affixed to the structure or by an adjacent building, topographical feature, or vegetation.

SHALL: Denotes a mandatory Code requirement.

SINGLE FAMILY: One and two family residential dwelling units with no more than two units in a single building.

SKYLIGHT: A glazing surface that has a slope of less than 60° from the horizontal plane.

SLAB-ON-GRADE, EXTERIOR: Any portion of a slab floor in contact with the ground which is less than or equal to 24 inches below the final elevation of the nearest exterior grade.

SLAB-BELOW-GRADE: Any portion of a slab floor in contact with the ground which is more than 24 inches below the final elevation of the nearest exterior grade.

SMALL BUSINESS: Any business entity (including a sole proprietorship, corporation, partnership or other legal entity) which is owned and operated independently from all other businesses, which has the purpose of making a profit, and which has fifty or fewer employees, or which has a million dollars or less per year in gross sales, of window products.

SOLAR ENERGY SOURCE: Source of natural daylighting and of thermal, chemical or electrical energy derived directly from conversion of incident solar radiation.

STANDARD FRAMING: All framing practices not defined as "intermediate" or "advanced" shall be considered standard. (See Advanced Framed Ceiling, Advanced Framed Walls, Intermediate Framed Wall and Section 1005.2.)

SUBSTANTIAL CONTACT: A condition where adjacent building materials are placed in a manner that proximal surfaces are contiguous, being installed and supported as to eliminate voids between materials, without compressing or degrading the thermal performance of either product.

SYSTEM: A combination of central or terminal equipment or components and/or controls, accessories, interconnecting means and terminal devices by which energy is transformed so as to perform a specific function, such as HVAC, service water heating or illumination.

TAPERING: Installation of a reduced level of ceiling insulation at the eaves, due to reduced clearance.

THERMAL BY-PASS: An area where the envelope surrounding the conditioned space is breached, or where an ineffective application compromises the performance of a thermal or infiltration barrier, increasing the structure's energy consumption by exposing finished surfaces to ambient conditions and additional heat transfer.

THERMAL CONDUCTANCE (C): Time rate of heat flow through a body (frequently per unit area) from one of its bounding surfaces to the other for a unit temperature difference between the two surfaces, under steady conditions ($Btu/h^{*}ft^{2*}$ °F).

THERMAL RESISTANCE (R): The reciprocal of thermal conductance (hr*ft²* °F/Btu).

THERMAL TRANSMITTANCE (U): The coefficient of heat transmission (air to air). It is the time rate of heat flow per unit area and unit temperature difference between the warm side and cold side air films (Btu/h*ft²* °F). The Uvalue applies to the fractional combinations of different materials used in series along the heat flow path.

THERMAL TRANSMITTANCE, OVERALL (U_o) : The overall (average) heat transmission of a gross area of the exterior building envelope $(Btu/h^{\circ} ft^{2 \circ} \circ F)$. The U_o -value applies to the combined effect of the time rate of heat flows through the various parallel paths, such as windows, doors and opaque construction areas, comprising the gross area of one or more exterior building components, such as walls, floors or roof/ceiling.

THERMOSTAT: An automatic control device actuated by temperature and designed to be responsive to temperature.

TOTAL ON-SITE ENERGY INPUT: The combination of all the energy inputs to all elements and accessories as included in the equipment components, including but not limited to, compressor(s), compressor sump heater(s), circulating pump(s), purge device(s), fan(s) and the HVAC system component control circuit.

TRANSMISSION COEFFICIENT: The ratio of the solar heat gain through a glazing system to that of an unshaded single pane of double strength window glass under the same set of conditions.

U-VALUE: (See Thermal Transmittance.)

UNIFORM BUILDING CODE: The Washington State Uniform Building Code as modified by the Washington State Building Code Council. UNIFORM MECHANICAL CODE: The Washington State Uniform Mechanical Code as modified by the Washington State Building Code Council.

UNITARY COOLING AND HEATING EQUIPMENT: One or more factorymade assemblies which include an evaporator or cooling coil, a compressor and condenser combination, and may include a heating function as well. Where such equipment is provided in more than one assembly, the separate assemblies shall be designed to be used together.

UNITARY HEAT PUMP: One or more factory-made assemblies which include an indoor conditioning coil, compressor(s) and outdoor coil or refrigerant-towater heat exchanger, including means to provide both heating and cooling functions. When such equipment is provided in more than one assembly, the separate assemblies shall be designed to be used together.

VAPOR RETARDER: A layer of low moisture transmissivity material (not more than 1.0 perm dry cup) placed over the warm side (in winter) of insulation, over the exterior of below grade walls, and under floors as ground cover to limit the transport of water and water vapor through exterior walls, ceilings and floors. Vapor retarding paint, listed for this application, also complies with this Code.

VAULTED CEILINGS: All ceilings where enclosed joist or rafter space is formed by ceilings applied directly to the underside of roof joists or rafters.

VENTILATION: The process of supplying or removing air by natural or mechanical means to or from any space. Such air may or may not have been conditioned.

VENTILATION AIR: That portion of supply air which comes from outside (outdoors) plus any recirculated air that has been treated to maintain the desired quality of air within a designated space.

WALLS (EXTERIOR): Any member or group of members which defines the exterior houndaries or courts of a building and which have a slope of 60° or greater with the horizontal plane, and separates conditioned from unconditioned space. Band joists between floors are to be considered a part of exterior walls.

ZONE: A space or group of spaces within a building with heating and/or cooling requirements sufficiently similar so that comfort conditions can be maintained throughout by a single controlling device. Each dwelling unit in residential buildings shall be considered a single zone.
CHAPTER 3 DESIGN CONDITIONS

SECTION 301 - DESIGN CRITERIA

301.1 General: The criteria of this chapter establish the design conditions upon which the minimum thermal design requirements of the building envelope and the design of the HVAC system are to be based.

301.2 Heating and Cooling: A building that is designed to be both heated and cooled shall meet the more stringent of the heating or cooling requirements as required in this Code when requirements of the exterior envelope differ.

SECTION 302 -- THERMAL DESIGN PARAMETERS

302.1 Exterior Design Conditions: The heating or cooling outdoor design temperatures shall be selected from 0.6% column for winter and 0.5% column for summer from the Puget Sound Chapter of ASHRAE publication "Recommended Outdoor Design Temperatures, Washington State, ASHRAE." (See also Washington State Energy Code Manual.)

302.2 Interior Design Conditions

302.2.1 Indoor Design Temperature: Indoor design temperature shall be 70°F for heating and 78°F for cooling.

Exception: Other design temperatures may be used for equipment selection if it results in a lower energy usage.

302.2.2 Humidification: If humidification is provided during heating, it shall be designed for a maximum relative humidity of 30%. When comfort air conditioning is provided, the actual design relative humidity within the comfort envelope as defined in Standard RS-4, listed in Chapter 7, shall be selected for minimum total HVAC system energy use.

302.3 Climate Zones: All buildings shall comply with the requirements of the appropriate climate zone as defined herein.

- ZONE 1: Climate Zone 1 shall include all counties not included in Climate Zone 2.
- ZONE 2: Climate Zone 2 shall include: Adams, Chelan, Douglas, Ferry, Grant, Kittitas, Lincoln, Okanogan, Pend Oreille, Spokane, Stevens and Whitman counties.

SECTION 303 -- MECHANICAL VENTILATION

For all Occupancies, the minimum requirements for ventilation shall comply with the Washington State Ventilation and Indoor Air Quality Code (WAC 51-13).

CHAPTER 4 BUILDING DESIGN BY SYSTEMS ANALYSIS

SECTION 401 - SCOPE

401.1 General: This chapter establishes design criteria in terms of total energy use by a building, including all of its systems. Analysis of design for all Group R Occupancies shall comply with Section 402.1 to 402.6.

SECTION 402 - SYSTEMS ANALYSIS

402.1 Special Requirements for All Group R Occupancies

402.1.1 Energy Budgets: Proposed buildings designed in accordance with this section shall be designed to use no more energy from non-renewable sources for space heating and domestic hot water heating than a standard building whose enclosure elements and energy consuming systems are designed in accordance with Section 502.2 of this Code for the appropriate climate zone and heating system type. Energy derived from renewable sources may be excluded from the total annual energy consumption attributed to the alternative building.

402.1.2 Calculation of Energy Consumption: The application for a building permit shall include documentation which demonstrates, using a calculation procedure as listed in Chapter 8, or an approved alternate, that the proposed building's annual space heating energy use does not exceed the annual space heating and water heating energy use of a standard building conforming to Chapter 5 of this Code for the appropriate climate zone. The total calculated annual energy consumption shall be shown in units of kWh/ft²/year or Btu/ft²/year of conditioned area.

402.1.3 Input Values: The following standardized input values shall be used in calculating annual space heating budgets:

	VALUE
Thermostat	
Thermostat set point, heating	65°F
Thermostat set point, cooling	78°F
Thermostat night set back	65°F
Thermostat night set back period	0 hours
Internal Gain	
R-3 units	3000 Btu/h
R-1 units	1500 Btu/h

PARAMETER

and the state

Domestic Hot Water Heater Setpoint

Domestic Hot Water Consumption

Minimum Heat Storage

Site Weather Data

VALUE

120°F

20 gallons/person/day.

Calculated using standard engineering practice for the actual building or as approved.

Typical meteorological year (TMY) or ersatz TMY data for the closest appropriate TMY site or other sites as approved.

Heating Equipment Efficiency

Electric resistance heat	1.00
Heat Pumps	6.80 HSPF
Other Fuels	0.78 AFUE

The standard building shall be modeled with glazing area distributed equally among the four cardinal directions. Parameter values that may be varied by the building designer to model energy saving options include, but are not limited to, the following:

- Overall thermal transmittance, U_o, of building envelope or individual building components.
- 2. Heat storage capacity of building.
- 3. Glazing orientation; area; and shading coefficients.
- 4. Heating system efficiency.

402.1.4 Solar Shading and Access: Building designs using passive solar features with 8% or more south facing equivalent glazing to qualify shall provide to the building official a sun chart or other approved documentation depicting actual site shading for use in calculating compliance under this section. The building shall contain at least 45 Btu/°F for each square foot of south facing glass.

402.1.5 Infiltration: Infiltration levels used shall be set at 0.35 air changes per hour for thermal calculation purposes only.

402.1.6 Heat Pumps: The heating season performance factor (HSPF) for heat pumps shall be calculated using procedures consistent with Section 5.2 of the U.S. Department of Energy "Test Procedure for Central Air Conditioners, Including Heat Pumps," published in the December 27, 1979, Federal Register, Vol. 44, No. 24 10 CFR 430. Climate data as specified above, the proposed buildings overall thermal performance value (Btu/°F) and the standardized input assumptions specified above shall be used to model the heat pump's HSPF.

402.2 Energy Analysis: Compliance with this chapter will require an analysis of the annual energy usage, hereinafter called an annual energy analysis.

Exception: Chapters 5 and 6 of this Code establish criteria for different energyconsuming and enclosure elements of the building which will eliminate the requirement for an annualsystems energy analysis while meeting the intent of this Code.

A building designed in accordance with this chapter will be deemed as complying with this Code if the calculated annual energy consumption is not greater than a similar building (defined as a "standard design") whose enclosure elements and energy-consuming systems are designed in accordance with Chapter 5.

For an alternate building design to be considered similar to a "standard design," it shall utilize the same energy source(s) for the same functions and have equal floor area and the same ratio of envelope area to floor area, environmental requirements, occupancy, climate data and usage operational schedule.

402.3 Design: The standard design, conforming to the criteria of Chapter 5 and the proposed alternative design shall be designed on a common basis as specified herein:

The comparison shall be expressed as kBtu or kWh input per square foot of conditioned floor area per year at the building site.

402.4 Analysis Procedure: The analysis of the annual energy usage of the standard and the proposed alternative building and system design shall meet the following criteria:

- a. The building heating/cooling load calculation procedure used for annual energy consumption analysis shall be detailed to permit the evaluation of effect of factors specified in Section 402.5.
- b. The calculation procedure used to simulate the operation of the building and its service systems through a full-year operating period shall be detailed to permit the evaluation of the effect of system design, climatic factors, operational characteristics and mechanical equipment on annual energy usage. Manufacturer's data or comparable field test data shall be used when available in the simulation of systems and equipment. The calculation procedure shall be based upon 8,760 hours of operation of the building and its service systems.

402.5 Calculation Procedure: The calculation procedure shall cover the following items:

- a. Design requirements--Environmental requirements as required in Chapter 3.
- b. Climatic data--Coincident hourly data for temperatures, solar radiation, wind and humidity of typical days in the year representing seasonal variation.
- c. Building data--Orientation, size, shape, mass, air, moisture and heat transfer characteristics.
- d. Operational characteristics--Temperature, humidity, ventilation, illumination, control mode for occupied and unoccupied hours.
- e. Mechanical equipment--Design capacity, part load profile.
- f. Building loads--Internal heat generation, lighting, equipment, number of people during occupied and unoccupied periods.

Exception: Group R Occupancy shall comply with the calculation procedures in Chapter 8, or an approved alternate.

402.6 Documentation: Proposed alternative designs, submitted as requests for exception to the standard design criteria, shall be accompanied by an energy analysis comparison report. The report shall provide technical detail on the two building and system designs and on the data used in and resulting from the comparative analysis to verify that both the analysis and the designs meet the criteria of Chapter 4 of this Code.

CHAPTER 5 BUILDING DESIGN BY COMPONENT PERFORMANCE APPROACH

SECTION 501 - SCOPE

501.1 General: Buildings that are heated or mechanically cooled shall be constructed so as to provide the required thermal performance of the various components. A building that is designed to be both heated and cooled shall meet the more stringent of the heating or cooling requirements as provided in this Code when requirements of the exterior envelope differ.

SECTION 502 - BUILDING ENVELOPE REQUIREMENTS

502.1 General

502.1.1: The stated U- or F-value of any component assembly, listed in Table 5-1 or 5-2, such as roof/ceiling, opaque wall or opaque floor may be increased and the U-value for other components decreased, provided that the total heat gain or loss for the entire building envelope does not exceed the total resulting from compliance to the U-values specified in this section.

The U-values for typical construction assemblies are included in Chapter 10. These values shall be used for all calculations. Where proposed construction assemblies are not represented in Chapter 10, values shall be calculated in accordance with Chapters 19-27 in Standard RS-1 listed in Chapter 7, using the framing factors listed in Chapter 10 where applicable.

For envelope assemblies containing metal framing, the U-value shall be determined by one of the following methods:

- 1. Results of laboratory or field measurements.
- Standard RS-25, listed in Chapter 7, where the metal framing is bonded on one or both sides to a metal skin or covering.
- The zone method as provided in Chapter 22 of Standard RS-1, listed in Chapter 7.
- Effective framing/cavity R-values as provided from the following table for metal stud walls:

WALL FRAMING	CAVITY INSULATION		
	R-11	R-19	
2 x 4 @ 16" o.c.	5.50		
2 x 4 @ 24" o.c.	6.60		
2 x 6 @ 16" o.c.		7.60	
2 x 6 @ 24" o.c.		8.55	

502.1.2: For consideration of thermal mass effects, see Section 402.4.

502.1.3: When return air ceiling plenums are employed, the roof/ceiling assembly shall:

- a. For thermal transmittance purposes, not include the ceiling proper nor the plenum space as part of the assembly; and
- b. For gross area purposes, be based upon the interior face of the upper plenum surface.

502.1.4 Insulation

502.1.4.1 General: All insulating materials shall comply with Sections 1713 and/or 1714 of the Uniform Building Code. Substantial contact of the insulation with the surface being insulated is required. All insulation materials shall be installed according to the manufacturer's instructions to achieve proper densities and maintain uniform R-values. To the maximum extent possible, insulation shall extend over the full component area to the intended R-value.

502.1.4.2 Insulation Materials: All insulation materials including facings such as vapor barriers or breather papers installed within floor/ceiling assemblies, roof/ceiling assemblies, walls, crawl spaces, or attics shall have a flame spread rating of less than 25 and a smoke density not to exceed 450 when tested in accordance with UBC Standard 42-1.

Exceptions:

- Foam plastic insulation shall comply with Section 1713 of the Uniform Building Code.
- . 2. When such materials are installed in concealed spaces of Types III, IV and V construction, the flame spread and smoke developed limitations do not apply to facing, provided that the facing is installed in substantial contact with the unexposed surface of the ceiling, floor or wall finish.
- Cellulose insulation shall comply with Section 1714 of the Uniform Building Code.

502.1.4.3 Clearances: Where required, insulation shall be installed with clearances according to manufacturer's specifications. Insulation shall be installed so that required ventilation is unobstructed. For blown or poured loose fill insulation, clearances shall be maintained through installation of a permanent retainer.

502.1.4.4 Access Hatches and Doors: Access doors from conditioned spaces to unconditioned spaces (e.g., attics and crawl spaces) shall be weatherstripped and insulated to a level equivalent to the insulation on the surrounding surfaces. Access shall be provided to all equipment which prevents damaging or compressing the insulation. A wood framed or equivalent baffle or retainer must

be provided when loose fill insulation is installed, the purpose of which is to prevent the loose fill insulation from spilling into the living space when the attic access is opened, and to provide a permanent means of maintaining the installed R-value of the loose fill insulation.

502.1.4.5 Roof/Ceiling Insulation: Open-blown or poured loose fill insulation may be used in attic spaces where the slope of the ceiling is not more than 3 feet in 12 and there is at least 30 inches of clear distance from the top of the bottom chord of the truss or ceiling joist to the underside of the sheathing at the roof ridge. When eave vents are installed, baffling of the vent openings shall be provided so as to deflect the incoming air above the surface of the insulation. Baffles shall be, rigid material, resistant to wind driven moisture. Requirements for baffles for ceiling insulation shall meet the Uniform Building Code Section 3205(c) for minimum ventilation requirements. When feasible, the baffles shall be installed from the top of the outside of the exterior wall, extending inward, to a point 6 inches vertically above the height of noncompressed insulation, and 12 inches vertically above loose fill insulation.

502.1.4.6 Wall Insulation: Insulation installed in exterior walls shall comply with the provisions of this section. All wall insulation shall fill the entire cavity. Exterior wall cavities isolated during framing shall be fully insulated to the levels of the surrounding walls. All faced insulation shall be face stapled to avoid compression.

502.1.4.7 Floor Insulation: Floor insulation shall be installed in a permanent manner in substantial contact with the surface being insulated. Insulation supports shall be installed so spacing is no more than 24 inches on center. Foundation vents shall be placed so that the top of the vent is below the lower surface of the floor insulation.

Exception: Insulation may be omitted from floor areas over heated basements, heated garages or underfloor areas used as HVAC supply plenums. See Uniform Mechanical Code Section 1008 for underfloor supply plenum requirements. When foundation walls are insulated, the insulation shall be attached in a permanent manner. The insulation shall not block the airflow through foundation vents when installed. When foundation vents are not placed so that the top of the vent is below the lower surface of the floor insulation, a permanently attached baffle shall be installed at an angle of 30° from horizontal, to divert air flow below the lower surface of the floor insulation.

502.1.4.8 Slab-On-Grade: Slab-on-grade insulation, installed inside the foundation wall, shall extend downward from the top of the slab for a minimum distance of 24 inches or downward and then horizontally beneath the slab for a minimum combined distance of 24 inches. Insulation installed outside the foundation shall extend downward to a minimum of 24 inches or to the frostline. Above grade insulation shall be protected.

Exception: For monolithic slabs, the insulation shall extend downward from the top of the slab to the bottom of the footing.

502.1.4.9 Radiant Slabs: The entire area of a radiant slab shall be thermally isolated from the soil with a minimum of R-10 insulation. The insulation shall be an approved product for its intended use. If a soil gas control system is present below the radiant slab, which results in increased convective flow below the radiant slab, the radiant slab shall be thermally isolated from the sub-slab gravel layer.

502.1.4.10 Below-Grade Walls: Below grade exterior wall insulation used on the exterior (cold) side of the wall shall extend from the top of the below grade wall to the top of the footing and shall be approved for below grade use. Above grade insulation shall be protected.

Insulation used on the interior (warm) side of the wall shall extend from the top of the below grade wall to the below grade floor level.

502.1.5 Glazing and Door U-Values: Glazing and door U-values shall be determined in accordance with Sections 502.1.5.1 and 502.1.5.2. All products shall be labeled with the NFRC certified or default U-value. The labeled U-value shall be used in all calculations to determine compliance with this Code. Sealed insulating glass shall conform to, or be in test for, ASTM E-774-81 class A.

Exceptions:

 Until December 31, 1994, the following products may be assigned a U-value of 0.40 for the purposes of determining compliance with the electric resistance component performance path as determined by Equation 3 in this Chapter:

A vinyl or wood double pane window, excluding sliding glass doors, constructed with a minimum 1/2 inch air space between glazings and either a low-e glazing or an argon fill of no less than 90%.

The only labeling requirement for products using this exception shall be a description of the product and a label stating: "This product is deemed to satisfy the electric resistance path in the Washington State Energy Code."

2. Until December 31, 1994, the following products may be assigned a U-value of 0.65 for the purposes of determining compliance with the other fuels component performance path as determined by Equation 3 in this Chapter:

An aluminum, double pane window, excluding sliding glass doors, constructed with a minimum 7/16 inch air space between glazings. .

The only labeling requirement for products using this exception shall be a description of the product and a label stating: "This product is deemed to satisfy the other fuels path in the Washington State Energy Code."

3. Log homes, in addition to the exceptions above, may utilize the following: until December 31, 1994, the following products may be assigned a U-value of 0.31 for the purposes of determining compliance with the electric resistance or other fuels component performance path as determined by Equation 3 in this Chapter:

A vinyl or wood double pane window, excluding sliding glass doors, constructed with a minimum 1/2 inch air space between glazings and a low-e glazing and an argon fill of no less than 90%.

The only labeling requirement for products using this exception shall be a description of the product and a label stating: "This product is deemed to satisfy either the electric resistance path or the other fuels path for log homes in the Washington State Energy Code."

502.1.5.1 Standard Procedure for Determination of Glazing U-Values: U-values for glazing shall be determined, certified and labeled in accordance with the National Fenestration Rating Council (NFRC) Product Certification Program (PCP), as authorized by an independent certification and inspection agency licensed by the NFRC. Compliance shall be based on Model Size AA. Product samples used for U-value determinations shall be production line units or representative of units as purchased by the consumer or contractor. Products that are listed in the NFRC Certified Products Directory or certified to the NFRC standard shall not use default values.

Exceptions:

- Untested glazing products may be assigned default U-values from Table 10-6A.
- Overhead glazing and units produced by a small business may be assigned default U-values from Table 10-6B.
- 3. Passive air inlets are not required to be part of the tested assembly.
- Compliance for tested overhead glazing shall be based on NFRC Model Size BB.

502.1.5.2 Standard Procedure for Determination of Door U-Values: Halflite and full-lite doors, including fire doors, shall be assigned default U-values from Table 10-6D. All other doors, including fire doors, shall be assigned default U-values from Table 10-6C.

Exceptions:

 U-values determined, certified and labeled in accordance with the National Fenestration Rating Council (NFRC) Product Certification Program (PCP), as authorized by an independent certification and inspection agency licensed by the NFRC.

- 2. The default values for the opaque portions of doors shall be those listed in Table 10-6C, provided that the U-value listed for a door with a thermal break shall only be allowed if both the door and the frame have a thermal break.
- 3. One unlabeled or untested exterior swinging door with the maximum area of 24 square feet may be installed for ornamental, security or architectural purposes. Products using this exception shall not be included in either the U-value or glazing area calculation requirements.

502.1.6 Moisture Control

502.1.6.1 Vapor Retarders: Vapor retarders shall be installed on the warm side (in winter) of insulation as specified in the following cases.

Exception: Vapor retarder installed with not more than 1/3 of the nominal R-value between it and the conditioned space.

502.1.6.2 Floors: Floors separating conditioned space from unconditioned space shall have a vapor retarder installed. The vapor retarder shall have a one perm dry cup rating or less (i.e. four mil [0.004 inch thick] polyethylene or kraft faced material).

502.1.6.3 Roof/Ceilings: Roof/Ceiling assemblies where the ventilation space above the insulation is less than an average of 12 inches shall be provided with a vapor retarder. Faced batt insulation where used as a vapor retarder shall be face stapled. Single rafter joist vaulted ceiling cavities shall be of sufficient depth to allow a minimum one inch vented air space above the insulation.

502.1.6.4: Vapor retarders shall not be required in roof/ceiling assemblies where the ventilation space above the insulation averages 12 inches or greater.

502.1.6.5: Vapor retarders shall not be required where all of the insulation is installed between the roof membrane and the structural roof deck.

502.1.6.6 Walls: Walls separating conditioned space from unconditioned space shall have a vapor retarder installed. Faced batt insulation shall be face stapled.

502.1.6.7 Ground Cover: A ground cover of six mil (0.006 inch thick) black polyethylene or approved equal shall be laid over the ground within crawl spaces. The ground cover shall be overlapped 12 inches minimum at the joints and shall extend to the foundation wall.

Exception: The ground cover may be omitted in crawl spaces if the crawl space has a concrete slab floor with a minimum thickness of 3-1/2 inches.

wet cavitus 23.17.10



502.2 Thermal Criteria for Group R Occupancy

502.2.1 UA Calculations: The proposed UA as calculated using Equations 2 and 3 shall not exceed the Target UA as calculated using Equation 1. For the purpose of determining equivalent thermal performance, the glazing area for the target UA shall be calculated using figures in Table 5-1, and all the glazing shall be located in the wall area. The opaque door area shall be the same in the target UA and the proposed UA.

502.2.2 Space Heat Type: The following two categories comprise all space heating types:

 Electric Resistance: Space heating systems which include baseboard units, radiant units and forced air units as either the primary or secondary heating system.

Exception: Electric resistance systems for which the total electric heat capacity in each individual dwelling unit does not exceed the greater of: 1) One thousand watts (1000 W)per dwelling unit, or; 2) One watt per square foot (1 W/ft^2) of the gross floor area.

 Other: All gas, wood, oil and propane space heating systems, unless electric resistance is used as a secondary heating system, and all heat pump space heating systems. (See EXCEPTION, Electric Resistance, Section 502.2.2 above.)

502.3 Reserved

502.4 Air Leakage

502.4.1 General: The requirements of this section shall apply to all buildings and structures, or portions thereof, and only to those locations separating outdoor ambient conditions from interior spaces that are heated or mechanically cooled.

502.4.2 Doors and Windows, General: Exterior doors and windows shall be designed to limit air leakage into or from the building envelope. Site-constructed doors and windows shall be sealed in accordance with Section 502.4.3.

502.4.3 Seals and Weatherstripping: a. Exterior joints around windows and door frames, openings between walls and foundation, between walls and roof and wall panels; openings at penetrations of utility services through walls, floors and roofs; and all other openings in the building envelope for all occupancies and all other openings in between units in R-1 occupancy shall be sealed, caulked, gasketed or weatherstripped to limit air leakage.

b. All exterior doors or doors serving as access to an enclosed unheated area shall be weatherstripped to limit leakage around their perimeter when in a closed position.

c. Site built windows are exempt from testing but shall be made tight fitting. Fixed lites shall have glass retained by stops with sealant or caulking all around. Operating sash shall have weatherstripping working against overlapping trim and a closer/latch which will hold the sash closed. The window frame to framing crack shall be made tight with caulking, overlapping membrane or other approved technique.

d. Openings that are required to be fire resistive are exempt from this section.

502.4.4 Recessed Lighting Fixtures: When installed in the building envelope, recessed lighting fixtures shall meet one of the following requirements:

- Type IC rated, manufactured with no penetrations between the inside of the recessed fixture and ceiling cavity and sealed or gasketed to prevent air leakage into the unconditioned space.
- Type IC rated, installed inside a sealed box constructed from a minimum 1/2 inch thick gypsum wall board, or constructed from a preformed polymeric vapor barrier, or other air tight assembly manufactured for this purpose.
- 3. Type IC rated, certified under ASTM E283 to have no more than 2.0 cfm air movement from the conditioned space to the ceiling cavity. The lighting fixture shall be tested at 75 Pascals or 1.57 lbs/ft² pressure difference and have a label attached, showing compliance.

SECTION 503 - BUILDING MECHANICAL SYSTEMS

503.1 General: This section covers the determination of design requirements, system and component performance, control requirements, insulating systems and duct construction.

Exception: Special applications, including but not limited to, hospitals, laboratories, thermally sensitive equipment and computer rooms may be exempted from the requirements of this section when approved by the building official.

503.2 Calculations of Heating/Cooling Loads and System Sizing Limits: The design parameters specified in Chapter 3 shall apply for all computations.

503.2.1 Calculation Procedures: Heating and cooling design loads for the purpose of sizing HVAC systems are required and shall be calculated in accordance with accepted engineering practice, including infiltration and ventilation.

503.2.2 Space Heating and Space Cooling System Sizing Limits: Building mechanical systems for all buildings which provide space heating and/or space cooling shall be sized no greater than 150% of the heating and cooling design loads as calculated above.

Exceptions: The following limited exemptions from the sizing limit shall be allowed, however, in all cases heating and/or cooling design load calculations shall be submitted.

- For equipment which provides both heating and cooling in one package unit, including heat pumps with electric heating and cooling and gaspack units with gas heating and electric cooling, compliance need only be demonstrated for either the space heating or space cooling system size.
- 2. Natural gas- or oil-fired space heating equipment whose total rated space heating output in any one dwelling unit is 56,000 Btu/h or less may exceed the 150% sizing limit provided that the installed equipment has an annual fuel utilization efficiency (AFUE) of not less than the sum of 78% plus 1% for every 5,000 Btu/h that the space heating equipment output exceeds the design heating load of the dwelling unit.
- Stand-by equipment may be installed if controls and other devices are provided which allow redundant equipment to operate only when the primary equipment is not operating.

503.3 Simultaneous Heating and Cooling: Each temperature control zone shall include thermostatic controls installed and operated to sequence the use of heating and cooling energy to satisfy the thermal and/or humidity requirement of the zone. Controls shall prevent reheating (heating air that is cooler than system mixed air), recooling (cooling air that is warmer than the system mixed air) mixing or simultaneous supply of warm air (warmer than system meturn air mixed air) and cold air (cooler than system mixed air), or other simultaneous operation of heating and cooling systems to one zone. For the purposes of this section, system mixed air is defined as system return air mixed with the minimum ventilation air requirement by Section 303.

Exceptions:

 Variable air volume systems designed to reduce the air supply to each zone during periods of occupancy to the larger of the following:

a. 30% or less of the peak supply volume.

b. The minimum allowed to meet ventilation requirements of Section 303.

c. 0.5 cfm/ft² of zone conditioned area before reheating, recooling or mixing takes place. Consideration shall be given to supply air temperature reset control.

- The energy for reheating or providing warm air in mixing systems is provided entirely from recovered energy that would otherwise be wasted or from renewable energy sources. In addition, the system shall comply with Section 503.7 without exception.
- Areas where specific humidity levels are required to satisfy process needs.
- 4. Where special pressurization relationships or cross-contamination requirements are such that variable air volume systems are impractical, supply air temperatures shall be reset by representative building load or outside air temperature.

503.4 HVAC Equipment Performance Requirements

503.4.1 Equipment Components

503.4.1.1 General: The requirements of this section apply to equipment and mechanical component performance for heating, ventilating and air conditioning systems. Equipment efficiency levels are specified. Data furnished by the equipment supplier or certified under a nationally recognized certification program or rating procedure shall be used to satisfy these requirements. Equipment efficiencies shall be based on the standard rating conditions in Tables 5-4, 5-5 or 5-6 as appropriate.

503.4.1.2 Assembled Components: Where components from more than one manufacturer are assembled into systems regulated under this section, compliance for each component shall be as specified in Sections 503.4.2 through 503.4.6 of this Code.

503.4.2 HVAC System Heating Equipment, Heat Pump, Heating Mode: Heat pumps whose energy input is entirely electric shall have a coefficient of performance (COP) heating, not less than the values in Table 5-7. Heat pumps with supplementary backup heat other than electricity shall meet the requirements of Table 5-7.

503.4.2.1 Application: These requirements apply to, but are not limited to, unitary (central) heat pumps (air source and water source) in the heating mode, water source (hydronic) heat pumps as used in multiple-unit hydronic HVAC systems and heat pumps in the packaged terminal air conditioner in the heating mode.

503.4.2.2: Reserved

503.4.2.3 Supplementary Heater: The heat pump shall be installed with a control to prevent supplementary backup heater operation when the operating load can be met hy the heat pump compression cycle alone.

503.4.2.4 Heat Pump Controls: Requirements for heat pump controls are listed in Section 503.8.3.5 of this Code.

34

503.4.3 HVAC System Combustion Equipment: For Group R Occupancy, all gas, oil and propane central heating systems shall have a minimum AFUE of 0.78*. All other Group R Occupancy heating equipment fueled by gas, oil or propane shall be equipped with an intermittent ignition device or shall comply with the efficiencies as required in the 1987 National Appliances Energy Conservation Act (Public Law 100-12).

* HVAC Heating system efficiency trade-offs shall be made using Chapters 4 or 6 of this Code.

503.4.4 Packaged and Unitary HVAC System Equipment, Electrically Operated, Cooling Mode: HVAC system equipment as listed below, whose energy input in the cooling mode is entirely electric, shall have an energy efficiency ratio (EER) or a seasonal energy efficiency ratio (SEER) cooling not less than values in Table 5-8.

503.4.4.1 Application: These requirements apply to, but are not limited to, unitary (central) and packaged terminal heat pumps (air source and water source); packaged terminal air conditioners.

503.4.5: Reserved

503.4.6: Reserved

503.5: Reserved

503.6 Balancing: The HVAC system design shall provide a means for balancing air and water systems. Balancing the system shall include, but not be limited to, dampers, temperature and pressure test connections and balancing valves.

503.7 Cooling with Outdoor Air (Economizer Cycle): Each fan system shall be designed to use up to and including 100% of the fan system capacity for cooling with outdoor air automatically whenever its use will result in lower usage of new energy. Activation of economizer cycle shall be controlled by sensing outdoor air enthalpy or outdoor air dry-bulb temperature alone or alternate means approved by the building official.

Exceptions: Cooling with outdoor air is not required under any one or more of the following conditions:

- The fan system capacity is less than 3,500 cfm or total cooling capacity is less than 90,000 Btu/h.
- The quality of the outdoor air is so poor as to require extensive treatment of the air and approval by the building official.
- The need for humidification or dehumidification requires the use of more energy than is conserved by the outdoor air cooling on an annual basis.

4. The use of outdoor air cooling may affect the operation of other systems so as to increase the overall energy consumption of the building.

- When energy recovered from an internal/external zone heat recovery system exceeds the energy conserved by outdoor air cooling on an annual basis.
- 6. When all space cooling is accomplished by a circulating liquid which transfers space heat directly or indirectly to a heat rejection device such as a cooling tower without use of a refrigeration system.
- 7. When the use of 100% outside air will cause coil frosting, controls may be added to reduce the quantity of outside air. However, the intent of this exception is to use 100% air in lieu of mechanical cooling when less energy usage will result and this exception applies only to direct expansion systems when the compressor is running.

503.8 Controls

503.8.1 Temperature Control: Each system shall be provided with at least one adjustable thermostat for the regulation of temperature. Each thermostat shall be capable of being set by adjustment or selection of sensors as follows:

503.8.1.1: When used to control heating only: 55°F to 75°F.

503.8.1.2: When used to control cooling only: 70°F to 85°F.

503.8.1.3: When used to control both heating and cooling, it shall be capable of being set from $55^{\circ}F$ to $85^{\circ}F$ and shall be capable of operating the system heating and cooling in sequence. The thermostat and/or control system shall have an adjustable deadband of not less than $10^{\circ}F$.

503.8.2 Humidity Control: If a system is equipped with a means for adding moisture to maintain specific selected relative humidities in space or zones, a humidistat shall be provided. Humidistats shall be capable of being set to prevent new energy from being used to produce space-relative humidity above 30%

Exception: Special uses requiring different relative humidities may be permitted when approved by the building official.

503.8.3 Zoning for Temperature Control

503.8.3.1 One- and Two-Family Dwellings: At least one thermostat for regulation of space temperature shall be provided for each separate system. In addition, a readily accessible manual or automatic means shall be provided to partially restrict or shut off the heating and/or cooling input to each zone or floor.

503.8.3.2 Multifamily Dwellings: For multifamily dwellings, each individual dwelling unit shall have at least one thermostat for regulation of space temperature. A readily accessible manual or automatic means shall be provided to partially restrict or shut off the heating and/or cooling input to each room.

503.8.3.3: Reserved

503.8.3.4 Control Setback and Shut-Off:

 Residential Occupancy Groups. One- and Two-Family and Multifamily Dwellings--The thermostat required in Section 503.8.3.1 or Section 503.8.3.2, or an alternate means such as a switch or clock, shall provide a readily accessible, manual or automatic means for reducing the energy required for heating and cooling during the periods of non-use or reduced need, such as, but not limited to, unoccupied periods and sleeping hours. Lowering thermostat set points to reduce energy consumption of heating systems shall not cause energy to be expended to reach the reduced setting.

2. Reserved

503.8.3.5 Heat Pump Controls: Programmable thermostats are required for all heat pump systems. The cut-on temperature for the compression heating shall be higher than the cut-on temperature for the supplementary heat, and the cut-off temperature for the compression heating shall be higher than the cut-off temperature for the supplementary heat. Heat pump thermostats will be capable of providing at least two programmable setback periods per day. The automatic setback thermostat shall have the capability of limiting the use of supplemental heat during the warm-up period.

503.9 Air Handling Duct System Insulation: Ducts, plenums and enclosures installed in or on buildings shall be thermally insulated per Table 5-11.

Exceptions: Duct insulation (except where required to prevent condensation) is not required in any of the following cases:

- When the heat gain or loss of the ducts, without insulation, will not increase the energy requirements of the building.
- 2. Within the HVAC equipment.
- 3. Exhaust air ducts.
- Supply or return air ducts installed in unvented crawl spaces with insulated walls, basements or cellars in one- and two-family dwellings.

503.10 Duct Construction: All duct work shall be constructed in accordance with Standards RS-15, RS-16, RS-17, RS-18, RS-19 or RS-20, as applicable, and the Uniform Mechanical Code.

503.10.1 Leakage Testing: High-pressure and medium-pressure ducts shall be leak tested in accordance with the applicable standards listed in Chapter 7 of this Code with the rate of air leakage not to exceed the maximum rate specified in that standard.



37

503.10.2 Seams and Joints: When low-pressure supply air ducts are located outside of the conditioned space, all HVAC ductwork seams and joints, both longitudinal and transverse, shall be taped and sealed with products approved by the building official only. Ductwork joints shall be mechanically fastened with a minimum of three fasteners per joint for a cylindrical duct. Use Table 5-11 for duct insulation requirements.

503.10.3 Dampers: Requirements for automatic or manual dampers are found in the Washington State Ventilation and Indoor Air Quality Code.

503.11 Piping Insulation: All piping installed to serve buildings (and within) shall be thermally insulated in accordance with Table 5-12. For service hot water systems see Section 504.7. If water pipes are outside of conditioned space then the pipe insulation requirement shall be R-3 minimum for non-recirculating hot and cold water pipes. For recirculating service hot and cold water pipes use Table 5-12 for pipe sizes and temperatures.

Exception: Piping insulation is not required within unitary HVAC equipment.

503.11.1 Other Insulation Thickness: Insulation thickness in Table 5-12 is based on insulation having thermal resistance in the range of 4.0 to 4.6 per inch of thickness on a flat surface at a mean temperature of 75°F. Minimum insulation thickness shall be increased for materials having R-values less than 4.0 per inch or may be reduced for materials having R-values greater than 4.6 per inch.

a. For materials with thermal resistance greater than R = 4.6 per inch, the minimum insulation thickness may be reduced as follows:

4.6 x (Table 5-12 Thickness) = New Minimum Thickness Actual Resistance

- b. For materials with thermal resistance less than R = 4.0 per inch, the minimum insulation thickness shall be increased as follows:
 - 4.0 x (Table 5-12 Thickness) = New Minimum Thickness Actual Resistance
- c. Additional insulation with vapor barriers shall be provided to prevent condensation where required by the building official.

SECTION 504 - SERVICE WATER HEATING

504.1 Scope: The purpose of this section is to provide criteria for design and equipment selection that will produce energy savings when applied to service water heating.

504.2 Water Heaters, Storage Tanks and Boilers

504.2.1 Performance Efficiency: All storage water heaters shall meet the requirements of the 1987 National Appliance Energy Conservation Act and be so labeled. All electric water heaters in unheated spaces or on concrete floors shall be placed on an incompressible, insulated surface with a minimum thermal resistance of R-10.

504.2.2 Insulation: Heat loss from unfired hot-water storage tanks shall be limited to a maximum of 9.6 Btu/h/ft² of external tank surface area. The design ambient temperature shall be no higher than 65 °F.

504.2.3 Combination Service Water Heating/Space Heating Boilers: Service water heating equipment shall not be dependent on year round operation of space heating boilers.

Exceptions:

 Systems with service/space heating boilers having a standby loss Btu/h less than:

(13.3 pmd + 400)/n

determined by the fixture count method where:

- pmd = probable maximum demand in gallons/hour as determined in accordance with Chapter 37 of Standard RS-11.
- n = fraction of year when outdoor daily mean temperature exceeds 64.9°F.

The standby loss is to be determined for a test period of 24 hours duration while maintaining a boiler water temperature of 90°F above an ambient of 60°F and a five foot stack on appliance.

For systems where the use of a single heating unit will lead to energy savings, such unit shall be utilized.

504.3 Automatic Controls: Service water heating systems shall be equipped with automatic temperature controls capable of adjustment from the lowest to the highest acceptable temperature settings for the intended use. Temperature setting range shall be set to 120°F or 49°C.

504.4 Shutdown: A separate switch shall be provided to permit turning off the energy supplied to electric service water heating systems. A separate valve shall be provided to permit turning off the energy supplied to the main burner(s) of all other types of service water heater systems.

504.5 Swimming Pools

504.5.1 Controls: All pool heaters shall be equipped with readily accessible ON/OFF switch to allow shutting off the operation of the heater without adjusting the thermostat setting. Controls shall be provided to allow the water temperature to be regulated from the maximum design temperature down to 65°F.

504.5.2 Pool Covers: Heated swimming pools shall be equipped with a pool cover, approved by the building official.

504.6 Pump Operation: Circulating hot water systems shall be controlled so that the circulation pump(s) can be conveniently turned off, automatically or manually, when the hot water system is not in operation.

504.7 Pipe Insulation: For recirculating and non-recirculating systems, piping shall be thermally insulated in accordance with Section 503.11 and Table 5-12.

504.8 Conservation of Hot Water

504.8.1 Showers and Lavatories: Showers and lavatories used for other than safety reasons shall be equipped with flow control devices or specially manufactured showerheads or aerators to limit the total water flow rate as set forth in Chapter 51-26 WAC, as measured with both hot and cold faucets turned on to their maximum flow.

504.8.2 Lavatories in Rest Rooms of Public Facilities

504.8.2.1 Controls: Lavatories in restrooms of public facilities shall be equipped with a metering valve designed to close by spring or water pressure when left unattended (self-closing) and limit the flow rate as set forth in Chapter 51-26 WAC.

Exception: Separate lavatories for persons with disabilities shall not be equipped with self-closing valves.

504.8.2.2 Temperature: Lavatories in restrooms of public facilities shall be equipped with devices which limit the outlet temperature to a maximum of 110°F.

SECTION 505: Reserved

EQUATION 1 -- GROUP R OCCUPANCY TARGET UA

 $UA_{T} = U_{W}A_{W} + U_{BGW}A_{BGW} + U_{G}A_{G} + U_{F}A_{F} + U_{RC}A_{RC} + U_{CC}A_{CC} + U_{D}A_{D} + F_{S}P_{S}$

Where:

- UA_T = the target combined thermal transmittance of the gross exterior wall, floor and roof/ceiling assembly area.
- U_W = the thermal transmittance value of the opaque above grade wall area found in Table 5-1.
- Aw = opaque above grade wall area.
- U_{BGW} = the thermal transmittance value of the below grade opaque wall area found in Table 5-1.
- ABGW = opaque below grade wall area.
- U_G = the thermal transmittance value of the glazing area found in Table 5-1.
- $A_G = 15\%$ of the total floor area of the conditioned space.
- U_F = the thermal transmittance value of the floor area found in Table 5-1.
- A_F = floor area over unconditioned space.
- U_{RC} = the thermal transmittance value of the roof/ceiling area found in Table 5-1.
- A_{RC} = roof/ceiling area.
- U_{CC} = the thermal transmittance value of the cathedral ceiling area found in Table 5-1.
- A_{CC} = cathedral ceiling area.
- U_D = the thermal transmittance value of the opaque door area found in Table 5-1.
- A_D = opaque door area.
- F_S = concrete slab component F-value found in Table 5-1.
- P_S = lineal ft. of concrete slab perimeter.

EQUATION 2 - ALL OCCUPANCIES

$$U = \frac{1}{r_{o} + R_{1} + R_{2}...r_{i}}$$

Where:

- U = the thermal transmittance of the assembly.
- r. = outside air film resistance.
- $r_o = 0.17$ for all exterior surfaces.
- r_i = inside air film resistance.
- r. = 0.61 for interior horizontal surfaces, heat flow up.
- $r_i = 0.92$ for interior horizontal surfaces, heat flow down.
- r; = 0.68 for interior vertical surfaces.
- $R = \underline{1} = \underline{X} = \text{measure of the resistance to the passage}$ C K of heat for each element.
- C = conductance, the heat flow through a specific material of specific thickness.

K = insulation value of a material per inch.

X = the thickness of the material in inches.

EQUATION 3 – GROUP R OCCUPANCY PROPOSED UA

UA	= U _W A	$W + U_{BGW}A_{BGW} + U_{G}A_{G} + U_{F}A_{F} + U_{RC}A_{RC} + U_{CC}A_{CC} + U_{D}A_{D} + F_{S}P_{S}$
	Where:	
	UA =	the combined thermal transmittance of the gross exterior wall, floor and roof/ceiling assembly area.
	U _w =	the thermal transmittance of the opaque wall area.
	A _W =	opaque wall area.
	U _{BGW} =	the thermal transmittance value of the below grade opaque wall area.
	A _{BGW} =	opaque below grade wall area.
	U _G =	the thermal transmittance of the glazing (window or skylight) area.
	A _G =	glazing area, including windows in exterior doors.
	U _F =	the thermal transmittance of the floor area.
	A _F =	floor area over unconditioned space.
	U _{RC} =	the thermal transmittance of the roof/ceiling area.
	A _{RC} =	roof/ceiling area.
	U _{CC} =	the thermal transmittance of the cathedral ceiling area.
	A _{CC} =	cathedral ceiling area.
	U _D =	the thermal transmittance value of the opaque door area.
	A _D =	opaque door area.
	F _S =	concrete slab component F-value.
	P _s =	lineal ft. of concrete slab perimeter.

NOTE: Where more than one type of wall, window, roof/ceiling, door and skylight is used, the U and A terms for those items shall be expanded into sub-elements as:

 $U_{w_1}A_{w_1} + U_{w_2}A_{w_2} + U_{w_3}A_{w_3} + \dots$ etc.



.

•

EQUATION 4 - RESERVED

EQUATION 5 - RESERVED



TABLE 5-1 TARGET COMPONENT VALUES FOR GROUP R OCCUPANCY













45

TABLE 5-2 RESERVEDTABLE 5-3 RESERVED

TABLE 5-4 HVAC SYSTEM HEATING EQUIPMENT (HEAT PUMPS) ELECTRICALLY OPERATED STANDARD RATING CONDITIONS

	TYPE			
CONDITIONS	Air Source		Water Source	
Air entering equipment °F	70°F(dry bulb)	70°F(dry bulb)	70°F(dry bulb)	
Outdoor unit ambient °F	47°F(dry bulb) /43°F(wet bulb)	17°F(dry bulb) /15°F(wet bulb)		
Entering water temp. °F			60°F	
Water flow rate	********	*****	As used in cooling	

Standard ratings are at sea level.



•



		TEMPERATURES				
		Dry Bulb	Wet Bulb	Inlet	Outlet	
Air entering equipment	°F	80°	67°			
Condenser ambient (air cooled)	°F	95°	75°			
Condenser water (water cooled)	°F			85°	95°	



Standard ratings are at sea level.

TABLE 5-6 APPLIED IIVAC SYSTEM COMPONENTS ELECTRICALLY DRIVEN STANDARD RATING CONDITIONS – COOLING

ITEM	Centrifugal or Self- Contained Reciprocating Water Chiller	Condenserless Reciprocating Water Chiller
Water Temperature, °F		
Leaving Chilled	44°	44°
Entering Chilled	54°	54°
Leaving Condenser	95°	
Entering	85°	
Fouling Factor, Water		
Nonferrous Tubes	0.0005*	0.0005
Steel Tubes	0.0010*	0.0010
Refrigerant	0.0000*	0.0000
Condenser Ambient	95° (dry bulb) /	
(air/evap. cooled) °F	75° (wet bulb)	
Compressor Saturated Discharge Temperature		
Water Cooled (evap. cooled) °F	Constanting -	105°
Air Cooled °F	1180	120°

Standard ratings at sea level.

* h•ft2+ °F/Btu

48

TABLE 5-7

MINIMUM HEAT PUMP EFFICIENCIES, HEATING MODE

SOURCE	MINIMUM COP	MINIMUM HSPF	
Air Source:			
Split System	3.0 ²	6.8	
Single Package System	3.0 ²	6.6	
Water Source	3.83		
Ground Source	3.04		

¹ When tested at the standard rating specified in Table 5-4.

² When tested @ 47°F(dry bulb)/43°F(wet bulb)

³ @ 70°F entering

⁴ @ 50°F entering

TABLE 5-8

MINIMUM EFFICIENCY FOR ELECTRIC HVAC EQUIPMENT, COOLING

	Air Coole	Evap/Water Cooled		
Standard Rating Capacity	SEER	EER	EER	
Under 65,000 Btu/h (19,050 watts)				
A. Split System	10.0			
B. Single Package ³	9.7		9.31	
65,000 Btu/h and over		8.9 ²	10.51	

¹ @ 80°F (dry bulb) / 67°F (wet bulb)

2 @ 95°F dry bulb

³ Prior to January 1, 1993 a minimum value of 8.0 SEER may be used.

TABLE 5-9 RESERVEDTABLE 5-10 RESERVED

TABLE 5-11 INSULATION OF DUCTS

Duct Location	Climate Zone	Group R Occupancy Heating or Cooling Ducts
On roof or on exterior of building	. 1	E and W
	2	D and W
Attic, garage, crawl space, in	1	Е
walls1, in floor/ceiling1	2	Е
Within the conditioned space or in heated basements		None Required
In cement slab or in ground		В

Note: Where ducts are used for both heating and cooling, the minimum insulation shall be as required for the most restrictive condition.



- Insulation may be omitted on that portion of a duct which is located within a wall or floorceiling space where both sides of this space are exposed to conditioned air and where this space is not ventilated or otherwise exposed to unconditioned air.
- Vapor barriers shall be installed on conditioned air supply ducts in geographic areas where the average of the July, August and September mean dewpoint temperature exceeds 60°F.



- A. 0.5 inch 1.5 to 2 lb/cu. ft. duct liner, mineral or glass fiber blanket or equivalent to provide an installed total thermal resistance of at least R-2.
- B. 2 inch 0.60 lb/cu. ft. mineral or glass fiber blanket 1.5 inch 1.5 to 2 lb/cu. ft. duct liner, mineral or glass fiber blanket. 1.5 inch 3 to 7 lb/cu. ft. mineral or glass fiber board or equivalent to provide an installed total thermal resistance of at least R-5.
- C. 3 inch 0.60 lb/cu. ft. mineral or glass fiber blanket 2 inch 1.5 to 2 lb/cu. ft. duct liner, mineral or glass fiber blanket. 2 inch 3 to 7 lb/cu. ft. mineral or glass fiber board or equivalent to provide an installed total thermal resistance of at least R-7.
- D. 4 inch 0.60 lb/cu. ft. mineral or glass fiber blanket 3 inch 1.5 to 2 lb/cu. ft. duct liner, mineral or glass fiber blanket. 3 inch 3 to 7 lb/cu. ft. mineral or glass fiber board or equivalent to provide an installed total thermal resistance of at least R-10.
- E. 3.5 inch 0.60 lb/cu. ft. mineral or glass fiber blanket, 2.5 inch 1.5 to 2 lb/cu. ft. duct liner, mineral or glass fiber board or equivalent to provide an installed total thermal resistance of at least R-8.
 - Vapor barrier, with perm rating not greater than 0.5 perm, all joints sealed.
- W. Approved weatherproof barrier.



TABLE 5-12

52

MINIMUM PIPE INSULATION REQUIREMENTS'

INSULATION THICKNESS FOR GIVEN PIPE DIAMETERS ¹					CREATER		
PIPING SYSTEM	FLUID TEMP RANGE (OF)	LESS THAN 12 FOOT PIPE RUN ² UP TO 2"	1" AND LESS	GREATER THAN 1" TO 2"	GREATER THAN 2" TO 4"	GREATER THAN 4" TO 6"	GREATER THAN 6" AND LARGER
HEATING & HOT WATER SYSTEM Steam & Hot Water	S Pressure/temperature						
High Medium Low All Other	306°F ⇔ 450°F 251°F ⇔ 305°F 201°F ⇔ 250°F 100°F ⇔ 200°F	1.5" 1.5" 1.0" 0.5"	2.5" 2.0" 1.5" 1.0"	2.5" 2.5" 1.5" 1.0"	3.0" 2.5" 2.0" 1.5"	3.5" 3.0" 2.0" 1.5"	3.5" 3.0" 2.0" 1.5"
Steam Condensate (for feed water)	Any	1.0"	1.0"	1.5*	2.0*	2.0*	2.0"
COOLING SYSTEMS							
Chilled Water Refrigerant/brine	40°F ⇔ 55°F Below 40°F	0.5" 1.0"	0.5" 1.0"	0.75* 1.5*	1.0" 1.5"	1.0* 1.5*	1.0"

¹ For piping exposed to ambient air, increase thickness by 0.5".
² Pipe runouts not exceeding 12 feet in length to individual units, with a pipe diameter of less

than 2 inches.

* Column headings for pipe diameters amended 5/30/90.

TABLE 5-13 RESERVED

.

.
CHAPTER 6 BUILDING DESIGN BY PRESCRIPTIVE REQUIREMENTS APPROACH

SECTION 601 -- SCOPE

601.1 General: This chapter establishes design criteria in terms of prescribed requirements for building construction.

The provisions of this chapter are applicable to all Group R Occupancies. Occupancies shall comply with all the requirements of Chapter 5 except for the modifications herein specified.

The building envelope requirements of this chapter may be met by installing one of the prescriptive packages in Tables 6-1 to 6-6. Installed components shall meet the requirements of Sections 602 and 605. Compliance with nominal R-values shall be demonstrated for the thermal resistance of the added insulation in framing cavities and/or insulated sheathing only and shall not include the thermal transmittance of other building materials or air films, but shall permit interruption by occasional framing members.

SECTION 602 - BUILDING ENVELOPE REQUIREMENTS FOR GROUP R OCCUPANCY

602.1 Roof/Ceiling: Ceilings below vented attics and single-rafter, joist-vaulted ceilings shall be insulated to not less than the nominal R-value specified for ceilings in Tables 6-1 to 6-6 as applicable.

602.2 Exterior Walls Both Above and Below Grade: Above grade exterior walls shall be insulated to not less than the nominal R-value specified in Tables 6-1 to 6-6 as applicable. The following walls should be considered to meet R-19 without additional documentation:

- 1. 2 x 6 framed and insulated with R-19 fiberglass batts.
- 2 x 4 framed and insulated with R-13 fiberglass batts plus R-3.2 foam sheathing.
- 2 x 4 framed and insulated with R-11 fiberglass batts plus R-5.0 foam sheathing.

602.3 Exterior Walls (Below Grade): Below grade exterior walls surrounding conditioned space shall be insulated to not less than the nominal R-value specified for below grade walls in Tables 6-1 to 6-6 as applicable.

602.4 Slab-on-Grade Floors: Slab-on-grade floors shall be insulated along their perimeter to not less than the nominal R-values specified for slab-on-grade floors in Tables 6-1 to 6-6 as applicable. Slab insulation shall be installed in compliance with Section 502.1.4.8. See Chapter 5, Section 502.1.4.9, for additional requirements for radiant slab heating.

602.5 Floors Over Unconditioned Space: Floors over unconditioned spaces, such as vented crawl spaces, unconditioned basements and parking garages shall be insulated to not less than the nominal R-value shown for floors over unconditioned spaces in Tables 6-1 to 6-6.

602.6 Exterior Doors: Doors shall comply with Sections 602.6.1 and 602.6.2. Exceptions:

- Doors whose area and U-value are included in the calculations for compliance with the requirements for glazing in Section 602.7 shall be exempt from the door U-value requirements prescribed in Tables 6-1 to 6-6.
- 2. One unlabeled or untested exterior swinging door with the maximum area of 24 square feet may be installed for ornamental, security or architectural purposes. Products using this exception shall not be included in either the U-value or glazing area calculation requirements.

602.6.1 Exterior Door Area: For half-lite and full-lite doors, the glazing area shall be included in calculating the allowed total glazing area in Section 602.7.1. Single glazing used for ornamental, security or architectural purposes shall be calculated using the exception to Section 602.7.2.

602.6.2 Exterior Door U-Value: Doors, including fire doors, shall have a maximum area weighted average U-value not exceeding that prescribed in Tables 6-1 to 6-6.

602.7 Glazing

602.7.1 Glazing Area: The total glazing area as defined in Chapter 2 shall not exceed the percentage of gross conditioned floor area specified in Tables 6-1 to 6-6. This area shall also include any glazing in doors.

602.7.2 Glazing U-Value: The total glazing area as defined in Chapter 2 shall have an area weighted average U-value not to exceed that specified in Tables 6-1 to 6-6. U-values for glazing shall be determined in accordance with Section 502.1.5.1. These areas and U-values shall also include any doors using the exception of Section 602.6.

If the U-values for all glazing products are below the U-value specified, then no calculations are required. If compliance is to be achieved through an area weighted calculation, then the areas and U-values shall be included in the plans submitted with a building permit application.

Exception: Single glazing for ornamental, security or architectural purposes shall have its area doubled and shall be included in the percentage of the total glazing area as allowed for in Tables 6-1 to 6-6. The maximum area (before doubling) allowed for the total of all single glazing is 1% of the floor area.

602.8 Air Leakage for Group R Occupancy: The minimum air leakage control measures shall be as specified in Section 502.4 as applicable.

SECTION 603 - BUILDING MECHANICAL SYSTEMS FOR GROUP R OCCUPANCY

603.1: Group R Occupancies that are space heated by air-to-air, ground-to-air or water-to-air heat pumps shall comply with Table 6-2 or 6-4 or 6-6 for other fuels. System sizing shall be determined by an analysis consistent with Section 503.2 of this Code, or, when approved by the building official, Chapter 9. All mechanical equipment efficiencies and service water heating system efficiencies shall comply with standards as stated in Sections 503 and 504 of this Code.

SECTION 604 – RESERVED SECTION 605 – RESERVED SECTION 606 – RESERVED SECTION 607 – RESERVED SECTION 608 – RESERVED

TABLE 6-1 PRESCRIPTIVE REQUIREMENTS¹ FOR GROUP R OCCUPANCY CLIMATE ZONE 1 • HEATING BY ELECTRIC RESISTANCE

Option	Glazing % Floor Area	Glazing U-Value	Doors ¹⁰ U-Value	Ceiling ²	Vaulted Ceiling ³	Wall Above Grade	Wall• int ⁴ Below Grade	Wall• ext ⁴ Below Grade	Floor ⁵	Slab ⁴ on Grade	
I.	10%	0.46	0.40	R-38	R-30	R-21	R-21	R-10	R-30	R-10	
Ш,	12%	0.43	0.20	R-38	R-30	R-19	R-19	R-10	R-30	R-10	
III.	12%	0.409	0.40	R-38	R-30	R-21	R-21	R-10	R-30	R-10	
IV.*	15%	0.409	0.20	R-38	R-30	R-19	R-19	R-10	R-30	R-10	
V.	18%	0.39	0.20	R-38	R-30	R-21	R-21	R-10	R-30	R-10	
VI.	21%	0.36	0.20	R-38	R-30	R-21	R-21	R-10	R-30	R-10	
VII.7	25%	0.327	0.20	R-38	R-30	R-19+R-58	R-21	R-10	R-30	R-10	
VIII.7	30%	0.297	0.20	R-38	R-30	R-19+R-58	R-21	R-10	R-30	R-10	

* Reference Case

- 1 Minimum requirements for each option listed. For example, if a proposed design has a glazing ratio to the conditioned floor area of 19%, it shall comply with all of the requirements of the 21% glazing option (or higher). Proposed designs which cannot meet the specific requirements of a listed option above may calculate compliance by Chapters 4 or 5 of this Code.
- 2 Requirement applies to all ceilings except single rafter or joist vaulted ceilings. 'Adv' denotes Advanced Framed Ceiling.
- 3 Requirement applicable only to single rafter or joist vaulted ceilings.
- 4 Below grade walls shall be insulated either on the exterior to a minimum level of R-10, or on the interior to the same level as walls above grade. Exterior insulation installed on below grade walls shall be a water resistant material, manufactured for its intended use, and installed according to the manufacturer's specifications. See Section 602.2.
- 5 Floors over crawl spaces or exposed to ambient air conditions.
- 6 Required slab perimeter insulation shall be a water resistant material, manufactured for its intended use, and installed according to manufacturer's specifications. See Section 602.4.
- 7 The following options shall be applicable to buildings less than three stories: 0.35 maximum for glazing areas of 25% or less; 0.32 maximum for glazing areas of 30% or less.
- 8 This wall insulation requirement denotes R-19 wall cavity insulation plus R-5 foam sheathing.
- 9 Until December 31, 1994, a vinyl or wood double-pane window, excluding sliding glass doors, constructed with a minimum ¼ inch air space between glazings, and either a low-e glazing or an argon fill of no less than 90%, shall be deemed to satisfy the glazing U-value. The only labeling requirement for products using this exception shall be a description of the product, and a label stating: "This product is deemed to satisfy the electric resistance path in the Washington State Energy Code."

10 Doors, including all fire doors, shall be assigned default U-values from Table 10-6C or 10-6D.



TABLE 6-2 PRESCRIPTIVE REQUIREMENTS¹ FOR GROUP R OCCUPANCY CLIMATE ZONE 1 • HEATING BY OTHER FUELS

	Option	HVAC ⁹ Equip. Effic.	Glazing % Floor Area	Glazing U-Value	Doors ¹¹ U-Value	Ceiling ²	Vaulted Ceiling ³	Wall Above Grade	Wall• int ⁴ Below	Wall• ext ⁴ Below	Floor ⁵	Slab ⁶ on Grade
1		Med.	10%	0.70	0.40	R-30	R-30	R-15	R-15	R-10	R-19	R-10
1	I.	Med.	12%	0.6510	0.40	R-30	R-30	R-15	R-15	R-10	R-19	R-10
I	11.	High	21%	0.75	0.40	R-30	R-30	R-19	R-19	R-10	R-19	R-10
I	V.*	Med.	21%	0.6510	0.40	R-30	R-30	R-19	R-19	R-10	R-19	R-10
1	٧.	Low	21%	0.60	0.40	R-30	R-30	R-19	R-19	R-10	R-19	R-10
1	VI.7	Med.	25%	0.457	0.40	R-38	R-30	R-19	R-19	R-10	R-25	R-10
1	VII.7	Med.	30%	0.407	0.40	R-30	R-30	R-19	R-19	R-10	R-25	R-10

Reference Case

1 Minimum requirements for each option listed. For example, if a proposed design has a glazing ratio to the conditioned floor area of 19%, it shall comply with all of the requirements of the 21% glazing option (or higher). Proposed designs which cannot meet the specific requirements of a listed option above may calculate compliance by Chapters 4 or 5 of this Code.

- 2 Requirement applies to all ceilings except single rafter or joist vaulted ceilings. 'Adv' denotes Advanced Framed Ceiling.
- 3 Requirement applicable only to single rafter or joist vaulted ceilings.
- 4 Below grade walls shall be insulated either on the exterior to a minimum level of R-10, or on the interior to the same level as walls above grade. Exterior insulation installed on below grade walls shall be a water resistant material, manufactured for its intended use, and installed according to the manufacturer's specifications. See Section 602.2.
- 5 Floors over crawl spaces or exposed to ambient air conditions.
- 6 Required slab perimeter insulation shall be a water resistant material, manufactured for its intended use, and installed according to manufacturer's specifications. See Section 602.4.
- 7 The following options shall be applicable to buildings less than three stories: 0.50 maximum for glazing areas of 25% or less; 0.45 maximum for glazing areas of 30% or less.
- 8 This wall insulation requirement denotes R-19 wall cavity insulation plus R-5 foam sheathing.
- 9 Minimum HVAC Equipment efficiency requirement. 'Low' denotes an AFUE of 0.74. 'Med.' denotes an AFUE of 0.78. 'High' denotes an AFUE of 0.88. Minimum HVAC Equipment efficiency requirement for heat pumps. 'Low' denotes an HSPF of 6.35. 'Med' denotes an HSPF of 6.8. 'High' an HSPF of 7.7. Water and ground source heat pumps shall be considered as medium efficiency and have a minimum COP as required in Table 5-7.
- 10 Until December 31, 1994, an aluminum, double-pane window, excluding sliding glass doors, constructed with a minimum 7/16 incb air space between glazings shall be deemed to satisfy the glazing U-value. The only labeling requirement for products using this exception shall be a description of the product, and a label stating: "This product is deemed to satisfy the other fuels path in the Washington State Energy Code."
- 11 Doors, including all fire doors, shall be assigned default U-values from Table 10-6C or 10-6D.







TABLE 6-3 PRESCRIPTIVE REQUIREMENTS¹ FOR GROUP R OCCUPANCY CLIMATE ZONE 2 • HEATING BY ELECTRIC RESISTANCE

Option	Glazing % Floor Area	Glazing U-Value	Doors ¹¹ U-value	Ceiling ²	Vaulted Ceiling ³	Wall Above Grade	Wall• int ⁴ Below Grade	Wall• ext ⁴ Below Grade	Floor ³	Slab* on Grade	
1.	10%	0.38	0.20	R-38	R-30	R-21	R-21	R-12	R-30	R-10	
II.	12%	0.4010	0.20	R-38	R-30	R-19+R-5*	R-21	R-12	R-25	R-10	
111.*	15%	0.4010	0.20	R-38	R-30	R-19+R-5*	R-21	R-12	R-30	R-10	
IV.	18%	0.38	0.20	R-38	R-30	R-19+R-5*	R-21	R-12	R-30	R-10	
V7	21%	0.35	0.20	R-38Ady	R-38	R-19+R-5#	R-21	R-12	R-30	R-10	
VI7	25%	0.307	0.20	R-49Adv	R-38	R-19+R-5*	R-21	R-12	R-30	R-10	1
VIL.7	30%	0.287	0.20	R-60Adv	R-38	R-21+R-7.59	R-21	R-12	R-30	R-10	1

* Reference Case

1 Minimum requirements for each option listed. For example, if a proposed design has a glazing ratio to the conditioned floor area of 19%, it shall comply with all of the requirements of the 21% glazing option (or higher). Proposed designs which cannot meet the specific requirements of a listed option above may calculate compliance by Chapters 4 or 5 of this Code.

- 2 Requirement applies to all ceilings except single rafter or joist vaulted ceilings. 'Adv' denotes Advanced Framed Ceiling.
- 3 Requirement applicable only to single rafter or joist vaulted ceilings.
- 4 Below grade walls shall be insulated either on the exterior to a minimum level of R-10, or on the interior to the same level as walls above grade. Exterior insulation installed on below grade walls shall be a water resistant material, manufactured for its intended-use, and installed according to the manufacturer's specifications. See Section 602.2.
- 5 Floors over crawl spaces or exposed to ambient air conditions.
- 6 Required slab perimeter insulation shall be a water resistant material, manufactured for its intended use, and installed according to manufacturer's specifications. See Section 602.4.
- 7 The following options shall be applicable to buildings less than three stories: 0.33 maximum for glazing areas of 25% or less; 0.31 maximum for glazing areas of 30% or less.
- 8 This wall insulation requirement denotes R-19 wall cavity insulation plus R-5 foam sheathing.
- 9 This wall insulation requirement denotes R-21 wall cavity insulation plus R-7.5 foam sheathing.
- 10 Until December 31, 1994, a vinyl or wood double-pane window, excluding sliding glass doors, constructed with a minimum ¼ inch air space between glazings, and either a low-e glazing or an argon fill of no less than 90%, shall be deemed to satisfy the glazing U-value. The only labeling requirement for products using this exception shall be a description of the product, and a label stating: "This product is deemed to satisfy the electric resistance path in the Washington State Energy Code."
- 11 Doors, including all fire doors, shall be assigned default U-values from Table 10-6C or 10-6D.

Þ

TABLE 6-4

Option	HVAC ⁹ Equip. Effic.	Glazing % Floor Area	Glazing U-Value	Doors ¹¹ U-Value	Ceiling ²	Vaulted Ceiling ³	Wall Above Grade	Wall= int ⁴ Below Grade	Wall* ext ⁴ Below Grade	Floor ^s	Slab ⁶ on Grade
I.	Med.	10%	0.70	0.40	R-38	R-30	R-19	R-19	R-12	R-25	R-10
11.	Med.	12%	0.6510	0.40	R-38	R-30	R-19	R-19	R-12	R-25	R-10
111.	High	17%	0.6510	0.40	R-38	R-30	R-19	R-19	R-12	R-25	R-10
IV.*	Med.	17%	0.60	0.40	R-38	R-30	R-19	R-19	R-12	R-30	R-10
V.	Low	17%	0.50	0.40	R-38	R-30	R-19	R-19	R-12	R-30	R-10
VI.	Med.	21%	0.50	0.40	R-38	R-30	R-19	R-19	R-12	R-30	R-10
VIL.	Med.	25%	0.407	0.40	R-38	R-30	R-19	R-19	R-12	R-30	R-10
VIII.	Med.	30%	0.407	0.40	R-38	R-30	R-19	R-19	R-12	R-30	R-10

PRESCRIPTIVE REQUIREMENTS¹ FOR GROUP R OCCUPANCY CLIMATE ZONE 2 • HEATING BY OTHER FUELS

* Reference Case

- 1 Minimum requirements for each option listed. For example, if a proposed design has a glazing ratio to the conditioned floor area of 19%, it shall comply with all of the requirements of the 21% glazing option (or higher). Proposed designs which cannot meet the specific requirements of a listed option above may calculate compliance by Chapters 4 or 5 of this Code.
- 2 Requirement applies to all ceilings except single rafter or joist vaulted ceilings. 'Adv' denotes Advanced Framed Ceiling.
- 3 Requirement applicable only to single rafter or joist vaulted ceilings.
- 4 Below grade walls shall be insulated either on the exterior to a minimum level of R-10, or on the interior to the same level as walls above grade. Exterior insulation installed on below grade walls shall be a water resistant material, manufactured for its intended use, and installed according to the manufacturer's specifications. See Section 602.2.
- 5 Floors over crawl spaces or exposed to ambient air conditions.
- 6 Required slab perimeter insulation shall be a water resistant material, manufactured for its intended use, and installed according to manufacturer's specifications. See Section 602.4.
- 7 The following options shall be applicable to buildings less than three stories: 0.45 maximum for glazing areas of 25% or less; 0.40 maximum for glazing areas of 30% or less.
- 8 This wall insulation requirement denotes R-19 wall cavity insulation plus R-5 foam sheathing.
- 9 Minimum HVAC Equipment efficiency requirement. 'Low' denotes an AFUE of 0.74. 'Med.' denotes an AFUE of 0.78. 'High' denotes an AFUE of 0.88.
- 10 Until December 31, 1994, an aluminum, double-pane window, excluding sliding glass doors, constructed with a minimum 7/16 inch air space between glazings shall be deemed to satisfy the glazing U-value. The only labeling requirement for products using this exception shall be a description of the product, and a label stating: "This product is deemed to satisfy the other fuels path in the Washington State Energy Code."
- 11 Doors, including all fire doors, shall be assigned default U-values from Table 10-6C or 10-6D.









•

TABLE 6-5 LOG HOMES PRESCRIPTIVE REQUIREMENTS¹ HEATING BY ELECTRIC RESISTANCE

Option	Average ²	Glazing %	Glazing	Doors ¹⁰	Ceiling ³	Vaulted ⁴	Floor ⁵	Slab ⁶
1000	Log	Floor Area	U-Value	U-Value		Ceiling		on
	Thickness							Grade
Climate	Zone 1							
1.7	5.5"	15%	0.319	0.14	R-60 Adv	R-38	R-38	R-10
11.7	7.5"	15%	0.40*	0.20	R-60 Adv	R-38	R-30	R-10
111.*	9.6"	15%	0.40*	0.20	R-38	R-30	R-30	R-10
Climate	Zone 2							
11.7	6.7"	15%	0.319	0.14	R-60 Adv	R-38	R-38	R-10
V.7	8.7"	15%	0.40*	0.14	R-60 Adv	R-38	R-38	R-10
VI.7	9.8*	15%	0.40 ^s	0.20	R-60 Adv	R-38	R-30	R-10
VII.7	10.5"	15%	0.40 [±]	0.20	R-49 Adv	R-38	R-30	R-10
VIII.*	13.5"	15%	0.40*	0.20	R-38	R-30	R-30	R-10

* Reference Case

- 1 For Group R Occupancy use Table 6-5 for only the portion of floor area using log/solid timber walls. Use Tables 6-1 to 6-4 for all other portions of the floor area. Minimum requirements are for each option listed. Interpolations between options is not permitted. Proposed designs which cannot meet the specific requirements of a listed option above may calculate compliance by Chapters 4 or 5 of this Code.
- 2 Required minimum average log thickness.
- 3 'Adv' denotes Advanced Framing. Requirement applies to all ceilings except single rafter joist vaulted ceilings.
- 4 Requirement applicable only to single rafter joist vaulted ceilings.
- 5 Floors over crawl spaces or exposed to ambient air conditions.
- 6 Required slab perimeter insulation shall be water resistant material, manufactured for its intended use, and installed according to manufacturer's specifications.
- 7 These options shall be applicable to buildings less than three stories.
- 8 Until December 31, 1994, a vinyl or wood double-pane window, excluding sliding glass doors, constructed with a minimum ¼ inch air space between glazings, and either a low-e glazing or an argon fill of no less than 90%, shall be deemed to satisfy the glazing U-value. The only labeling requirement for products using this exception shall be a description of the product, and a label stating: "This product is deemed to satisfy the electric resistance path in the Washington State Energy Code."
- 9 Until December 31, 1994, a vinyl or wood double-pane window, excluding sliding glass doors, constructed with a minimum ¼ inch air space between glazings and both a low-e glazing and an argon fill of no less than 90%, shall be deemed to satisfy the glazing U-value. The only labeling requirement for products using this exception shall be a description of the product, and a label stating: "This product is deemed to satisfy either the electric resistance path or the other fuels path for log homes in the Washington State Energy Code."

10 Doors, including all fire doors, shall be assigned default U-values from Table 10-6C or 10-6D.



Option	Average ² Log Thickness	Glazing % Floor Area	Glazing U-Value	Doors ¹¹ U-Value	Ceiling ³	Vaulted ⁴ Ceiling	Floor ⁵	Slab ⁶ on Grade
Climate	Zone 1							
1.7	3.5"	21%	0.40	0.39	R-49 Adv	R-38	R-30	R-10
11.	4.4"	21%	0.40	0.40	R-38	R-30	R-19	R-10
III.	5.2"	21%	0.50	0.40	R-38	R-30	R-19	R-10
IV.	6.5"	21%	0.60	0.40	R-38	R-30	R-19	R-10
V.	7.0"	21%	0.60	0.40	R-38	R-30	R-19	R-10
VI.*	8.2"	21%	0.65%	0.40	R-38	R-30	R-19	R-10
Climate	Zone 2							
VII.7	3.5"	17%	0.3110	0.14	R-60 Adv	R-38	R-38	R-10
VIII.7,8	3.5"	17%	0.40	0.40	R-60 Adv	R-38	R-30	R-10
IX.7	4.6"	17%	0.40	0.40	R-60 Adv	R-38	R-30	R-10
X.	5.4"	17%	0.40	0.40	R-38	R-30	R-30	R-10
XI.	6.8"	17%	0.50	0.40	R-38	R-30	R-30	R-10
XII.*	9.0"	17%	0.60	0.40	R-38	R-30	R-30	R-10

TABLE 6-6 LOG HOMES PRESCRIPTIVE REQUIREMENTS¹ HEATING BY OTHER FUELS

Reference Case

- 1 For Group R Occupancy use Table 6-6 for only the portion of floor area using log/solid timber walls. Use Tables 6-1 to 6-4 for all other portions of the floor area. Minimum requirements are for each option listed. Interpolations between options is not permitted. Proposed designs which cannot meet the specific requirements of a listed option above may calculate compliance by Chapters 4 or 5 of this Code.
- 2 Required minimum average log thickness.
- 3 'Adv' denotes Advanced Framing. Requirement applies to all ceilings except single rafter joist vaulted ceilings.
- 4 Requirement applicable only to single rafter joist vaulted ceilings.
- 5 Floors over crawl spaces or exposed to ambient air conditions.
- 6 Required slab perimeter insulation shall be water resistant material, manufactured for its intended use, and installed according to manufacturer's specifications.
- 7 These options shall be applicable to buildings less than three stories.
- 8 For this option, minimum HVAC system efficiency is an AFUE of 0.88.
- 9 Until December 31, 1994, an aluminum, double-pane window, excluding sliding glass doors, constructed with a minimum 7/16 inch air space between glazings shall be deemed to satisfy the glazing U-value. The only labeling requirement for products using this exception shall be a description of the product, and a label stating: "This product is deemed to satisfy the other fuels path in the Washington State Energy Code."
- 10 Until December 31, 1994, a vinyl or wood double-pane window, excluding sliding glass doors, constructed with a minimum ½ inch air space between glazings and both a low-e glazing and an argon fill of no less than 90%, shall be deemed to satisfy the glazing U-value. The only labeling requirement for products using this exception shall be a description of the product, and a label stating: "This product is deemed to satisfy either the electric resistance path or the other fuels path for log homes in the Washington State Energy Code."
- 11 Doors, including all fire doors, shall be assigned default U-values from Table 10-6C or 10-6D.

TABLE 6-7 RESERVED

CHAPTER 7 - STANDARDS

SECTION 701 - STANDARDS

The standards and portions thereof, which are referred to in various parts of this Code shall be part of the Washington State Energy Code and are hereby declared to be a part of this Code.

CODE

STANDARD

NO. TITLE AND SOURCE

- RS-1 1989 ASHRAE Handbook of Fundamentals.
- RS-2 Standard Method of Test for Rate of Air Leakage Through Exterior Windows, Curtain Walls and Doors, Specification E283-84 of ASTM.

Specifications for Aluminum Windows, ANSI A134.1, 1972

Specifications for Aluminum Sliding Glass Doors, ANSI A134.2, 1972.

Industry Standard for Wood Window Units, NWWDA IS-2-87, Industry Standard for Wood Sliding Patio Doors, NWWDA IS-3-88.

- RS-2B AAMA 1503.1-88, 1988 Voluntary Test Method for Thermal Transmittance of Windows, Doors and Glazed Wall Sections.
- RS-2C ASTM C236-87 Test for Thermal Conductance and Transmittance of Built-Up Sections by Means of a Guarded Hot Box; and ASTM C976-82 Thermal Performance of Building Assemblies by Means of the Calibrated Hot Box.
- RS-3 ASHRAE Standard 62-89 Ventilation for Acceptable Indoor Air Quality.
- RS-4 ASHRAE Standard 55-81 Thermal Environmental Conditions for Human Occupancy.
- RS-5 DOE Test Procedures for Water Heaters, 10 CFR Part 430 Appendix E to Subpart B.
- RS-6 Household Automatic Electric Storage-Type Water Heaters, ANSI C72.1-1972.

- RS-7 Gas Water Heaters, Volume III, Circulating Tank, Instantaneous and Large Automatic Storage-Type Water Heaters, ANSI Z21.10.3, 1974.
- RS-8 IES Lighting Handbook, Illuminating Engineering Society, 1984 Reference Volume, 1987 Application Volume.
- RS-9 ASHRAE Standard 90.1-1989, Efficient Design of New Buildings Except New Low-Rise Residential Buildings.
- RS-10 Standard for Packaged Terminal Air Conditioners, ARI Standard 310-87.
- RS-11 1987 ASHRAE HVAC Systems and Applications Handbook.
- RS-12 Energy Calculations I: Procedures for Determining Heating and Cooling Loads for Computerizing Energy Calculations--Algorithms for Building Heat Transfer Subsystems, ASHRAE 1975.
- RS-13 Energy Calculations II: Procedures for Simulating the Performance of Components and Systems for Energy Calculations, 3rd Edition, ASHRAE 1975.
- RS-14 Standard for Positive Displacement Refrigerant Compressor and Condensing Units, ARI Standard 520-74.
- RS-15 1988 ASHRAE Equipment Handbook.
- RS-16 Heating and Air Conditioning Systems--Installation Standards, SMACNA, February, 1977.
- RS-17 SMACNA Duct Metal and Flexible Construction Standards, 1st Edition, Washington, D.C., 1985.
- RS-18 Same as Standard RS-17.
- RS-19 SMACNA Fibrous Glass Duct Construction Standards, 6th Edition, Washington, D.C., 1990.
- RS-20 1990 ASHRAE Refrigeration Volume.
- RS-21 Standard for Package Terminal Heat Pumps, ARI Standard 380-90.
- RS-22 ASTM E779-87 Standard Practice for Measuring Air Leakage by the Fan Pressurization Method.

- RS-23 ASTM E741 Standard Practice for Measuring Air Leakage by the Tracer Dilution Method.
- RS-24 Standard 24 CFR Part 3280 HUD.
- RS-25 Thermal Bridge in Sheet Metal Construction from Appendix E of Standard RS-9.
- RS-26 Super Good Cents Technical Reference.

0

ACCREDITED AUTHORITATIVE AGENCIES

AAMA refers to the American Architectural Manufacturers Association, 35 East Wacker Drive, Chicago, IL 60601

ANSI refers to the American National Standards Institute, Inc., 1430 Broadway, New York, NY 10018

ARI refers to the Air Conditioning and Refrigeration Institute, 1815 North Fort Myer Drive, Arlington, VA 22209

ASHRAE refers to the American Society of Heating, Refrigerating and Air Conditioning Engineers, Inc., 1791 Tullie Circle, N.E., Atlanta, GA 30329

ASTM refers to the American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103

IES refers to Illuminating Engineering Society, 345 East 47th Street, New York, NY 10017

NESCA refers to the National Environmental System Contractors Association, 1501 Wilson Blvd., Arlington, VA 22209

NWWDA refers to the National Wood Window and Door Association, 1400 East Toughy Avenue, Suite G-54, Des Plaines, IL 60018

SMACNA refers to the Sheet Metal and Air Conditioning Contractors National Association, Inc., 4201 Lafayette Center Drive, Chantilly, VA 22021-1209

CHAPTER 8

SECTION 800 -- SUGGESTED SOFTWARE FOR CHAPTER 4 SYSTEMS ANALYSIS APPROACH FOR GROUP R OCCUPANCY

PROGRAM NAME	SOURCE
CALPAS 3	BERKELEY SOLAR GROUI
	455 Santa Clara Ave.
	Oakland, CA 94610
	(415) 843-7600
DATACAL	SUNRISE ENERGY, INC.
	5708 43rd Ave E.
	Tacoma, WA 98443
	(206) 922-5218
DOE 2	ACROSOFT INT'L., INC.
	9745 E. Hampten Av Suite 23
	Denver, CO 80231
	(303) 368-9225
F-LOAD	F-CHART SOFTWARE
	4406 Fox Bluff Rd.
	Middleton, WI 53562
	(608) 836-8536
MICROPAS	ENERCOMP
	123 C Street
	Davis, CA 95616
	(916) 753-3400
SUNDAY	ECOTOPE
	2812 East Madison St.
	Seattle, WA 98112
	(206) 322-3753
WATTSUN 5	WSEO
	925 Plum Street
	Building 4
	Olympia, WA 98504-3165
	(206) 956-2031

9

69

¥.

CHAPTER 9

SECTION 900 -- PRESCRIPTIVE HEATING SYSTEM SIZING

When using the prescriptive approach in Chapter 6, if approved by the building official, design heat load calculations are not required to show compliance to this Code if the heating system installed is equal to or less than the following:

Climate Zone 1

Electric Resistance	21 Btu/h•ft2
Electric Resistance (Forced Air)	24 Btu/h•ft ²
Other Fuels (Forced Air)	27 Btu/h•ft ²
Climate Zone 2	

Electric Resistance	29 Btu/h•ft ²
Electric Resistance (Forced Air)	32 Btu/h•ft ²
Other Fuels (Forced Air)	39 Btu/h•ft2

Example: A 1500 ft² house in Zone 1, heated with gas, would not have to submit a design heat load if the proposed furnace is 40,500 Btu or less.

 $1500 \times 27 = 40,500$

Disclaimer: All heating systems shall be designed and installed in accordance with Uniform Building Code Section 1211.

CHAPTER 10

SECTION 1000 - DEFAULT HEAT LOSS COEFFICIENTS

SECTION 1001 - GENERAL

1001.1 Scope: This chapter includes tables of seasonal average heat loss coefficients for specified nominal insulation. The heat loss coefficients may also be used for heating system sizing.

1001.2 Description: These coefficients were developed primarily from data and procedures from Standard RS-1, and taken specifically from Standard RS-26, listed in Chapter 7.

Coefficients not contained in this chapter may be computed using the procedures listed in these references if the assumptions in the following sections and Standard RS-26, listed in Chapter 7, are used, along with data from the sources referenced above.

SECTION 1002 - BELOW GRADE WALLS AND SLABS

1002.1 General: Table 10-1 lists heat loss coefficients for below-grade walls and floors.

Coefficients for below-grade walls are given as U-values (Btu/h*fi²*°F of wall area). Coefficients for below-grade slabs are listed as F-values (Btu/h*°F per lineal foot of slab perimeter).

Below-grade wall U-values are only valid when used with the accompanying below-grade slab F-value, and vice versa.

1002.2 Component Description: All below-grade walls are assumed to be 8 inch concrete. The wall is assumed to extend from the slab upward to the top of the mud sill for the distance specified in Table 10-1, with 6 inches of concrete wall extending above grade.

Interior insulation is assumed to be fiberglass batts placed in the cavity formed by 2x4 framing on 24 inch centers with 1/2 inch gypsum board as the interior finish material. Exterior insulation is assumed to be applied directly to the exterior of the below-grade wall from the top of the wall to the footing. The exterior case does not assume any interior framing or sbeetrock.

In all cases, the entire wall surface is assumed to be insulated to the indicated nominal level with the appropriate framing and insulation application. Coefficients are listed for wall depths of 2, 3-1/2 and 7 feet below grade. Basements shallower than two feet should use on-grade slab coefficients.

Heat loss calculations for wall areas above grade should use above-grade wall U-values, beginning at the mudsill.

1002.3 Insulation Description: Coefficients are listed for the following four configurations:

- 1. Uninsulated: No insulation or interior finish.
- Interior insulation: Interior 2x4 insulated wall without a thermal break between concrete wall and slab.
- Interior insulation with thermal break: Interior 2x4 insulated wall with R-5 rigid board providing a thermal break between the concrete wall and the slab.
- Exterior insulation: Insulation applied directly to the exterior surface of the concrete wall.

•

1	Below Grade Wall U-value	Below Grade Slab F-value
2-Foot Depth		
Below Grade		
Uninsulated	0.350	0.59
R-11 Interior	0.066	0.68
R-11 Interior w/tb	0.070	0.60
R-19 Interior	0.043	0.69
R-19 Interior w/tb	0.045	0.61
R-10 Exterior	0.070	0.60
R-12 Exterior	0.061	0.60
3.5-Foot Depth		
Below Grade		
Uninsulated	0.278	0.53
R-11 Interior	0.062	0.63
R-11 Interior w/tb	0.064	0.57
R-19 Interior	0.041	0.64
R-19 Interior w/tb	0.042	0.57
R-10 Exterior	0.064	0.57
R-12 Exterior	0.057	0.57
7-Foot Depth Below Grade		
Uninsulated	0.193	0.46
R-11 Interior	0.054	0.56
R-11 Interior w/tb	0.056	0.42
R-19 Interior	0.037	0.57
R-19 Interior w/tb	0.038	0.43
R-10 Exterior	0.056	0.42
R-12 Exterior	0.050	0.42

TABLE 10-1 DEFAULT WALL U-VALUES AND SLAB F-VALUES FOR BASEMENTS

SECTION 1003 - ON-GRADE SLAB FLOORS

1003.1 General: Table 10-2 lists heat loss coefficients for heated on-grade slab floors, in units of Btu/°F•hr per lineal foot of perimeter.

1003.2 Component Description: All on-grade slab floors are assumed to be 6 inch concrete poured directly onto the earth. The bottom of the slab is assumed to be at grade line. Monolithic and floating slabs are not differentiated.

Soil is assumed to have a conductivity of 0.75 Btu/h*ft²**F. Slabs 2 feet or more below grade should use basement coefficients.

1003.3 Insulation Description: Coefficients are provided for the following three configurations:

Two Foot (or four foot) vertical: Insulation is applied directly to the slab exterior, extending downward from the top of the slab to a depth of 2 feet (or 4 feet) below grade.

Two Foot (or four Foot) horizontal: Insulation is applied directly to the underside of the slab, and run horizontally from the perimeter inward for 2 feet (or 4 feet). The slab edge is exposed in this configuration.

Note: A horizontal installation with a thermal break of at least R-5 at the slab edge should use the vertical-case F-values.

Fully insulated slab: Insulation extends from the top of the slab, along the entire perimeter, and completely covers the area under the slab.

Insulation type	R-0	R-5	R-10	R-15
	Un	heated S	Slab	
Uninsulated slab	0.73			-
2-ft Horizontal (No thermal break)		0.70	0.70	0.69
4-ft Horizontal (No thermal break)		0.67	0.64	0.63
2-ft Vertical	-	0.58	0.54	0.52
4-ft Vertical		0.54	0.48	0.45
Fully insulated slab			0.36	-
	П	eated S	lab	
Uninsulated slab	0.84			
Fully insulated slab		0.74	0.55	0.44
R-5 Center (With perimeter insulation)		-	0.66	0.62
R-10 Center (With perimeter insulation)				0.51
3-ft Vertical			0.78	

TABLE 10-2 DEFAULT F-VALUES FOR ON-GRADE SLABS

SECTION 1004 -- CRAWLSPACE FLOORS

1004.1 General: Tables 10-3 and 10-4 list heat loss coefficients for floors over crawlspaces in units of $Btu/h^{\circ}n^{2*}$ °F of floor.

They are derived from procedures listed in Standard RS-1, listed in Chapter 7, assuming an average outdoor temperature of 45° F, an average indoor temperature of 65° F and a crawlspace area of 1350 ft² and 100 feet of perimeter. The crawlspace is assumed to be 2-1/2 feet high, with 24 inches below grade and 6 inches above grade.

1004.2 Crawlspace Description: Four crawlspace configurations are considered: vented, unvented, enclosed and heated plenum.

Vented crawlspaces: Assumed to have 3 air changes per hour, with at least 1 ft² of net-free ventilation in the foundation for every 300 ft² of crawlspace floor area. The crawlspace is not actively heated.

Floors over unheated areas, such as garages, may only use those values which have R-0 perimeter insulation.

Unvented crawlspaces: Assumed to have 1.5 air changes per hour, with less than 1 ft² of net-free ventilation in the foundation for every 300 ft² of crawlspace floor area. The crawlspace is not actively heated. Floors over unheated basements may only use those values which have R-0 perimeter insulation.

Heated-plenum crawlspaces: Assumed to have 0.25 air changes per hour, with no foundation vents. Heated supply air from central furnace is blown into a crawlspace and allowed to enter the living space unducted via holes cut into the floor.

Enclosed floors: Assumes no buffer space, and a covering of 1/2 inch T1-11 on the exterior of the cavity exposed to the outside air.

1004.3 Construction Description: Floors are assumed to be either joisted floors framed on 16 centers, or post and beam on 4 foot by 8 foot squares. Insulation is assumed to be installed under the subflooring between the joists or beams with no space between the insulation and the subfloor. Insulation is assumed to be uncompressed.

Perimeter insulation is assumed to extend from the top of the rim joist to the crawlspace floor and then inward along the ground (on top of the ground cover) for at least 24 inches.

Floor coverings are assumed to be light carpet with rubber pad.

TABLE 10-3 DEFAULT U-VALUES FOR FLOORS OVER VENTED CRAWLSPACE OR UNHEATED BASEMENT

Nomin	al R-value	U-v	alue
Floor	Perimeter	Post & Beam	Joists
0	0	0.112	0.134
	11	0.100	0.116
	19	0.098	0.114
	30	0.093	0.107
11	0	0.052	0.056
	11	0.048	0.052
19	0	0.038	0.041
	11	0.036	0.038
22	0	0.034	0.037
	11	0.033	0.035
25	0	0.032	0.034
	11	0.031	0.033
30	0	0.028	0.029
	11	0.027	0.028
38	0	0.024	0.025
	11	0.024	0.024

TABLE 10-4 DEFAULT U-VALUES FOR FLOORS OVER HEATED PLENUM CRAWLSPACES

Nominal R-valuePerimeter	U-value
11	0.085
19	0.075
30	0.069

Note: Crawlspaces used as heated plenums have approximately 30% higher heat loss rate than unvented crawlspaces with the same assumed ACH. Default U-values in Table 10-4 reflect this higher rate of heat loss.

79

SECTION 1005 - ABOVE-GRADE WALLS

1005.1 General: Table 10-5 lists heat loss coefficients for the opaque portion of above-grade walls (Btu/h*ft²* °F). They are derived from procedures listed in Standard RS-1, listed in Chapter 7, assuming exterior air films at 7.5-mph wind speed.

Insulation is assumed to uniformly fill the entire cavity and to be installed as per manufacturer's directions. All walls are assumed to be finished on the inside with 1/2 inch gypsum wallboard, and on the outside with either beveled wood siding over 1/2 inch plywood sheathing or with 5/8 inch T1-11 siding. Insulated sheathing (either interior or exterior) is assumed to cover the entire opaque wall surface.

1005.2 Framing Description: Three framing types are considered and defined as follows:

Standard: Studs framed on 16 inch centers with double top plate and single bottom plate. Corners use 3 studs and each opening is framed using 2 studs. Headers consist of double 2X or single 4X material with an air space left between the header and the exterior sheathing. Interior partition wall/exterior wall intersections use 2 studs in the exterior wall.

Standard framing weighting factors:

Studs and plates	0.19
Insulated cavity	0.77
Headers	0.04

Intermediate: Studs framed on 16 inch centers with double top plate and single bottom plate. Corners use 2 studs or other means of fully insulating corners, and each opening is framed by 2 studs. Headers consist of double 2X material with R-10 insulation between the header and exterior sheathing. Interior partition wall/exterior wall intersections are fully insulated in the exterior wall.

Intermediate framing weighting factors:

Studs and plates	0.18
Insulated cavity	0.78
Headers	0.04

Advanced: Studs framed on 24 inch centers with double top plate and single bottom plate. Corners use 2 studs or other means of fully insulating corners, and I stud is used to support each header. Headers consist of double 2X material with R-10 insulation between the header and exterior sheathing. Interior partition wall/exterior wall intersections are fully insulated in the exterior wall.

I

Advanced Framing Weighting Factors:

Studs and plates	0.13
nsulated cavity	0.83
leaders	0.04

1005.3 Component Description: Default coefficients for three types of walls are listed: single-stud walls, strap walls and double-stud walls.

Single-Stud Wall: Assumes either 2x4 or 2x6 studs framed on 16 or 24 inch centers. Headers are solid for 2x4 walls and double 2x for 2x6 walls, with either dead-air or rigid-board insulation in the remaining space.

Strap Wall: Assumes 2x6 studs framed on 16 or 24 inch centers. 2x3 or 2x4 strapping is run horizontally along the interior surface of the wall to provide additional space for insulation.

Double-Stud Wall: Assumes an exterior structural wall and a separate interior, non-structural wall. Insulation is placed in both wall cavities and in the space between the two walls. Stud spacing is assumed to be on 24 inch centers for both walls.

TABLE 10-5 DEFAULT U-VALUES FOR ABOVE-GRADE WALLS

2 x 4 Single Wood Stud: R-11 Batt

NOTE:

Nominal Batt R-value: R-11 at 3.5 inch thickness

Installed Batt R-value: R-11 in 3.5 inch cavity

Siding Material/Framing Type								
	Lappe	d Wood	T1	-11				
R-value of Foam								
Board	STD	ADV	STD	ADV				
0	0.088	0.084	0.094	0.090				
1	0.080	0.077	0.085	0.082				
2	0.074	0.071	0.078	0.075				
3	0.069	0.066	0.072	0.070				
4	0.064	0.062	0.067	0.065				
5	0.060	0.058	0.063	0.061				
6	0.056	0.055	0.059	0.057				
7	0.053	0.052	0.055	0.054				
8	0.051	0.049	0.052	0.051				
9	0.048	0.047	0.050	0.049				
10	0.046	0.045	0.047	0.046				
11	0.044	0.043	0.045	0.044				
12	0.042	0.041	0.043	0.042				

2 x 4 Single Wood Stud: R-13 Batt

NOTE:

0

Nominal Batt R-value: R-13 at 3.63 inch thickness

Installed Batt R-value: R-12.7 in 3.5 inch cavity

Siding Material/Framing Type								
	Lappe	Lapped Wood T1-11						
R-value of Foam Board	STD	ADV	STD	ADV				
0	0.082	0.078	0.088	0.083				
1	0.075	0.072	0.080	0.076				
2	0.069	0.066	0.073	0.070				
3	0.065	0.062	0.068	0.065				
4	0.060	0.058	0.063	0.061				
5	0.057	0.055	0.059	0.057				
6	0.053	0.052	0.056	0.054				
7	0.051	0.049	0.052	0.051				
8	0.048	0.047	0.050	0.048				
9	0.046	0.045	0.047	0.046				
10	0.044	0.043	0.045	0.044				
11	0.042	0.041	0.043	0.042				
12	0.040	0.039	0.041	0.040				

2 x 4 Single Wood Stud: R-15 Batt

NOTE:

Nominal Batt R-value: R-15 at 3.5 inch thickness

Installed Batt R-value: R-15 in 3.5 inch cavity

Siding Material/Framing Type								
	Lapped	Wood	T1	-11				
R-value of Foam Board	STD	ADV	STD	ADV				
0	0.076	0.071	0.081	0.075				
1	0.069	0.065	0.073	0.069				
2	0.064	0.061	0.068	0.069				
3	0.060	0.057	0.063	0.059				
4	0.056	0.053	0.059	0.056				
5	0.053	0.051	0.055	0.052				
6	0.050	0.048	0.052	0.050				
7	0.047	0.046	0.049	0.047				
8	0.045	0.044	0.047	0.045				
9	0.043	0.042	0.044	0.043				
10	0.041	0.040	0.042	0.041				
11	0.039	0.038	0.041	0.039				
12	0.038	0.037	0.039	0.038				

2 x 6 Single Wood Stud: R-19 Batt

	Siding Material/Framing Type							
		Lapped Wood				T1-11		
NOTE:	R-value of Foam Board	STD	INT	ADV	STD	INT	ADV	
Nominal Batt R-value:	0	0.062	0.058	0.055	0.065	0.061	0.058	
R-19 at 6 inch thickness	1	0.058	0.055	0.052	0.060	0.057	0.055	
	2	0.054	0.052	0.050	0.056	0.054	0.051	
Installed Batt R-value:	3	0.051	0.049	0.047	0.053	0.051	0.049	
R-18 in 5.5 inch cavity	4	0.048	0.046	0.045	0.050	0.048	0.046	
	5	0.046	0.044	0.043	0.048	0.046	0.044	
	6	0.044	0.042	0.041	0.045	0.044	0.042	
	7	0.042	0.040	0.039	0.043	0.042	0.040	
	8	0.040	0.039	0.038	0.041	0.040	0.039	
	9	0.038	0.037	0.035	0.039	0.038	0.037	
	10	0.037	0.036	0.035	0.038	0.037	0.036	
	11	0.036	0.035	0.034	0.036	0.035	0.035	
	12	0.034	0.033	0.033	0.035	0.034	0.033	

-

2 x 6 Single Wood Stud: R-21 Batt



Siding Material/Framing Type Lapped Wood T1-11 **R**-value of Foam Board STD INT ADV STD INT ADV 0 0.057 0.054 0.051 0.060 0.056 0.053 1 0.054 0.051 0.048 0.056 0.053 0.050 2 0.050 0.048 0.045 0.052 0.050 0.047 3 0.048 0.045 0.043 0.049 0.047 0.045 4 0.045 0.043 0.041 0.047 0.045 0.043 5 0.043 0.041 0.040 0.044 0.042 0.041 6 0.041 0.039 0.038 0.042 0.041 0.039 7 0.039 0.038 0.036 0.040 0.039 0.037 8 0.036 0.038 0.035 0.039 0.037 0.036 9 0.036 0.035 0.034 0.037 0.036 0.035 10 0.035 0.034 0.033 0.036 0.035 0.033 11 0.033 0.033 0.032 0.034 0.033 0.032

0.031

0.033

0.032

0.031

2 x 6 Single Wood Stud: R-22 Batt

12

0.032

0.031

Siding M	Siding Material/Framing Type									
	La	pped W	ood		T1-11					
R-value of Foam Board	STD	INT	ADV	STD	INT	ADV				
0	0.059	0.055	0.052	0.062	0.058	0.054				
1	0.055	0.052	0.049	0.057	0.054	0.051				
2	0.052	0.049	0.047	0.054	0.051	0.048				
3	0.049	0.046	0.044	0.050	0.048	0.046				
4	0.046	0.044	0.042	0.048	0.046	0.044				
5	0.044	0.042	0.041	0.045	0.043	0.042				
6	0.042	0.040	0.039	0.043	0.042	0.040				
7	0.040	0.039	0.037	0.041	0.040	0.038				
8	0.038	0.037	0.036	0.039	0.038	0.037				
9	0.037	0.036	0.035	0.038	0.037	0.035				
10	0.035	0.034	0.033	0.036	0.035	0.034				
11	0.034	0.033	0.032	0.035	0.034	0.033				
12	0.033	0.032	0.031	0.034	0.033	0.032				

NOTE: Nominal Batt R-value: R-21 at 5.5 inch thickness

Installed Batt R-value: R-21 in 5.5 inch cavity





NOTE: Nominal Batt R-value: R-22 at 6.75 inch thickness

Installed Batt R-value: R-20 in 5.5 inch cavity



•

2 x 6 Single Wood Stud: Two R-11 Batts

	Siding Material/Framing Type						
	Lapped Wood			T1-11			
NOTE:	R-value of Foam Board	STD	INT	ADV	STD	INT	ADV
Iominal Batt R-value:	0	0.060	0.057	0.054	0.063	0.059	0.056
R-22 at 7 inch thickness	1	0.056	0.053	0.051	0.059	0.056	0.053
	2	0.053	0.050	0.048	0.055	0.052	0.050
nstalled Batt R-value:	3	0.050	0.048	0.046	0.052	0.049	0.047
R-18.9 in 5.5 inch cavity	4	0.047	0.045	0.044	0.049	0.047	0.045
	5	0.045	0.043	0.042	0.046	0.045	0.043
	6	0.043	0.041	0.040	0.044	0.043	0.041
	7	0.041	0.040	0.038	0.042	0.041	0.039
	8	0.039	0.038	0.037	0.040	0.039	0.038
	9	0.038	0.037	0.036	0.039	0.038	0.036
	10	0.036	0.035	0.034	0.037	0.036	0.035
	11	0.035	0.034	0.033	0.036	0.035	0.034
	12	0.034	0.033	0.032	0.034	0.034	0.033

2 x 8 Single Stud: R-25 Batt

	La	ipped W	ood	T1-11		
R-value of Foam Board	STD	INT	ADV	STD	INT	AI
0	0.051	0.047	0.045	0.053	0.049	0.0
1	0.048	0.045	0.043	0.049	0.046	0.0
2	0.045	0.043	0.041	0.047	0.044	0.0
3	0.043	0.041	0.039	0.044	0.042	0.0
4	0.041	0.039	0.037	0.042	0.040	0.0
5	0.039	0.037	0.036	0.040	0.038	0.0
6	0.037	0.036	0.035	0.038	0.037	0.0
7	0.036	0.035	0.033	0.037	0.035	0.0
8	0.035	0.033	0.032	0.035	0.034	0.0
9	0.033	0.032	0.031	0.034	0.033	0.0
10	0.032	0.031	0.030	0.033	0.032	0.0
11	0.031	0.030	0.029	0.032	0.031	0.0
12	0.030	0.029	0.028	0.031	0.030	0.02

NOTE:

Nominal Batt R-value: R-25 at 8 inch thickness

Installed Batt R-value: R-23.6 in 7.25 inch cavity









2 x 6: Strap Wall

.

•

•

0

No. 1 States	Siding M	Siding Material/Frame Type					
	Lappe	Lapped Wood T1-11					
and the sales	STD	ADV	STD	ADV			
R-19 + R-11 Batts	0.036	0.035	0.038	0.036			
R-19 + R-8 Batts	0.041	0.039	0.042	0.040			

2 x 6 + 2 x 4: Double Wood Stud

			Siding Material/Frame Type			e
Batt Configuration			Lapped Wood		T1-11	
Exterior	Middle	Interior	STD	ADV	STD	ADV
R-19		R-11	0.040	0.037	0.041	0.038
R-19		R-19	0.034	0.031	0.035	0.032
R-19	R-8	R-11	0.029	0.028	0.031	0.029
R-19	R-11	R-11	0.027	0.026	0.028	0.027
R-19	R-11	R-19	0.024	0.023	0.025	0.023
R-19	R-19	R-19	0.021	0.020	0.021	0.020

2 x 4 + 2 x 4: Double Wood Stud

			Sliding N	Aaterial/F	rame Typ	e
Batt Configuration		Lapped Wood		T1-11		
Exterior	Middle	Interior	STD	ADV	STD	ADV
R-11	••	R-11	0.050	0.046	0.052	0.048
R-19		R-11	0.039	0.037	0.043	0.039
R-11	R-8	R-11	0.037	0.035	0.036	0.036
R-11	R-11	R-11	0.032	0.031	0.033	0.032
R-13	R-13	R-13	0.029	0.028	0.029	0.028
R-11	R-19	R-11	0.026	0.026	0.027	0.026

Log Walls

	Diameter, Inches	U-value
NOTE:	5 A 12 10 10 10 10	
R-value of wood:	6	0.148
R-1.25 per inch thickness	8	0.111
	10	0.089
Average wall thickness	12	0.074

Average Log

14 16 0.063

0.056

1

Stress Skin Panel

90% average log diameter

	Panel Thickness, Inches	U-value
NOTE:		
R-value of expanded	3 1/2	0.071
polystyrene: R-3.85 per inch	5 1/2	0.048
	7 1/4	0.037
Framing: 6%	91/4	0.030
Spline: 8%	11 1/4	0.025

No thermal bridging between interior and exterior splines

Single Metal Stud

.

•

Nominal Wall Thickness,	Nominal Insulation R-Value	Effective Insulation R-Value	Overall Assembly U-Value	
Inches			16" O.C.	24" O.C.
4	R-11	R-11	0.14	0.13
4	R-13	R-12.7	0.13	0.12
6	R-19	R-18	0.11	0.10



SECTION 1006 - DEFAULT U-VALUES FOR GLAZING AND DOORS

1006.1 Untested Glazing and Doors: Untested glazing and doors shall be assigned the U-values from Tables 10-6A, 10-6B, 10-6C or 10-6D as appropriate.

89

TABLE 10-6A Window Default Table

Description ^{1,2,3,4}		Frame Type ^{5,6}			
		Aluminum	Aluminum Thermal Break ⁷	Wood/Vinyl	
Single		1.20	1.20	1.20	
Double, < 1/2"	Clear	0.92	0.75	0.63	
	Clear + Argon	0.87	0.71	0.60	
	Low-e	0.85	0.69	0.58	
	Low-e + Argon	0.79	0.62	0.53	
Double, $\geq 1/2^{\circ}$	Clear	0.86	0.69	0.58	
	Clear + Argon	0.83	0.67	0.55	
	Low-e	0.78	0.61	0.51	
	Low-e + Argon	0.75	0.58	0,48	
Triple,	Clear	0.70	0.53	0.43	
	Clear + Argon	0.69	0.52	0.41	
	Low-e	0.67	0,49	0.40	
	Low-e + Argon	0.63	0.47	0.37	

- 1 < 1/2" = a minimum dead air space of less than 0.5 inches between the panes of glass.
- $\geq 1/2$ " = a minimum dead air space of 0.5 inches or greater between the panes of glass.
- 2 Any low-e (emissivity) coating (0.1, 0.2 or 0.4).

3 U-values listed for argon shall consist of sealed, gas-filled insulated units for argon, CO2, SF6, argon/SF6 mixtures and Krypton.

4 "Glass block" assemblies may use a U-value of 0.51.

- 5 Insulated fiberglass framed products shall use wood/vinyl U-values.
- 6 Aluminum clad wood windows shall use the U-values listed for wood/vinyl windows.
- 7 Aluminum Thermal Break = An aluminum thermal break framed window shall incorporate the following minimum design characteristics:
- a) The thermal conductivity of the thermal break material shall be not more than 3.6 Btu-in/h/ft²/°F;
- b) The thermal break material must produce a gap in the frame material of not less than 0.210 inches; and,
 c) All metal framing members of the products exposed to interior and exterior air shall incorporate a
- thermal break meeting the criteria in a) and b) above.

		FR	AME TYPE7.8	
DESCRIPTION2,3,4,5,6	ALUMINUM	ALUM. THERMAL BREAK ⁹	WOOD/VINYL	ALUM. CLAD WOOD/REINFORCED VINYL ¹⁰
Double, Clear 1/4"	0.82	0.66	0.56	0.59
Double Clear 4" + argon	0.77	0.63	0.53	0.56
Double Low-e4 14"	0.76	0.61	0.52	0.54
Double, Low-e2 1/4"	0.73	0.58	0.49	0.51
Double, Low-el 14"	0.70	0.55	0.47	0.49
Double, Low-e4 1/4" + argon	0.70	0.55	0.47	0.49
Double, Low-e2 1/4" + argon	0.66	0.52	0.43	0.46
Double, Low-el 14" + argon	0.64	0.50	0.41	0.43
Double, Clear 3/."	0.78	0.63	0.54	0.57
Double, Clear 3/," + argon	0.75	0.60	0.51	0.54
Double, Low-e4 3/,"	0.72	0.57	0.48	0.51
Double, Low-e2 3/,"	0.69	0.54	0.45	0.48
Double, Low-el 3/,"	0.66	0.51	0.43	0.46
Double, Low-e4 3/," + argon	0.68	0.53	0.44	0.47
Double, Low-e2 3/," + argon	0.63	0.49	0.41	0.44
Double, Low-el 3/," + argon	0.61	0.47	0.39	0.41
Double, Clear 1/2 "	0.75	0.60	0,50	0.54
Double, Clear 1/2" + argon	0.72	0.58	0.48	0.51
Double, Low-e4 1/2"	0.68	0.53	0.44	0.47
Double, Low-e2 1/2"	0.64	0.50	0.41	0.44
Double, Low-e1 1/2"	0.61	0.47	0.39	0.42
Double, Low-e4 1/2" + argon	0.65	0.50	0.42	0.44
Double, Low-e2 1/4" + arpon	0.60	0.46	0.37	0.40
Double, Low-el 1/2" + argon	0.58	0.43	0.35	0.38
Triple Clear 14"	0.66	0.52	0.42	0.44
Triple, Clear ¼" + argon	0.63	0.49	0.39	0.42
Triple Low-e4 1/4"	0.64	0.50	0.40	0.40
Triple Low-e2 1/4"	0.62	0.48	0.39	0.41
Triple Low-el 14"	0.61	0.47	0.38	0.40
Triple, Low-e4 '4" + argon	0.60	0.46	0.37	0.39
Triple, Low-e2 1/4" + argon	0.58	0.43	0.34	0.37
Triple Low-el 14" + areon	0.57	0.42	0.34	0.36
Triple Clear 1/2"	0.61	0.46	0.37	0.40
Triple, Clear 1/2" + argon	0.59	0.45	0.36	0.38
Triple, Low-e4 1/2"	0.58	0.43	0.35	0.37
Triple, Low-e2 1/4"	0.55	0.41	0.32	0.35
Triple, Low-el 1/2*	0.54	0.39	0.31	0.33
Triple Low-e4 1/2" + argon				
tribuel rout of the sufferi	0.55	0.41	0.32	0.35
Triple Low-e2 16" + argon	0.55	0.41	0.32	0.35

TABLE 10-6B APPROVED WINDOW AND SKYLIGHT DEFAULT TABLE¹
Footnotes to Table 10-6B



- I Subtract 0.02 from the listed default U-value for non-aluminum spacer. Acceptable spacer materials may include but is not limited to fiberglass, wood and butyl or other material with an equivalent thermal performance.
- 2 1/4" = a minimum dead air space of 0.25 inches between the panes of glass. 3/8" = a minimum dead air space of 0.375 inches between the panes of glass. 1/2" = a minimum dead air space of 0.5 inches between the panes of glass. Product with air spaces different than those listed above shall use the value for the next smaller air space; i.e. 3/4 inch = 1/2 inch U-values, 7/16 inch = 3/8 inch U-values, 5/16 inch = 1/4 inch U-values.
- 3 Low-e4 (emissivity) shall be 0.4 or less. Low-e2 (emissivity) shall be 0.2 or less. Low-e1 (emissivity) shall be 0.1 or less.
- 4 U-values listed for argon shall consist of sealed, gas-filled insulated units for argon, CO2, SF6, and argon/SF6 mixtures. The following conversion factor shall apply to Krypton gas-filled units: 1/4" or greater with krypton is equivalent to 1/2" argon.
- 5 Dividers placed between glazing: The U-value listed shall be used where the divider has a minimum gap of 1/8 inch between the divider and lite of each inside glass surface. Add 0.03 to the listed U-value for True Divided Lite windows.
- 6 "Glass block" assemblies may use a U-value of 0.51.
- 7 Insulated fiberglass framed products shall use wood/vinyl U-values.
- 8 Subtract 0.02 from the listed default values for solariums.
- 9 Aluminum Thermal Break = An aluminum thermal break framed window shall incorporate the following minimum design characteristics:
- a) The thermal conductivity of the thermal break material shall be not more than 3.6 Btuin/h/R²/F°;
- b) The thermal break material must produce a gap in the frame material of not less than 0.210 inches; and,
- c) All metal framing members of the products exposed to interior and exterior air shall incorporate a thermal break meeting the criteria in a) and b) above.
- 10 Aluminum clad wood windows shall use the U-values listed for Aluminum Clad Wood/Reinforced Vinyl windows. Vinyl clad wood window shall use the U-values listed for Wood/Vinyl windows. Any vinyl frame window with metal reinforcement in more than one rail shall use the U-values listed for Aluminum Clad Wood/Reinforced Vinyl window.







TABLE 10-6C TRANSMISSION COEFFICIENTS (U) FOR WOOD AND STEEL DOORS Btu/h•ft²•F

Nominal Door Thickness, Inches	Description	No Storm Door	Wood Storm Door ^c	Metal Storm Door ^d
Wood	The second s			
Doorsb			-	
1-3/8	Panel door with 7/16 inch panelse	0.57	0.33	0.37
1-3/8	Hollow core flush door	0.47	0.30	0.32
1-3/8	Solid core flush door	0.39	0.26	0.28
1-3/4	Panel door with 7/16 inch panelse	0.57	0.33	0.36
1-3/4	Hollow core flush door	0.46	0.29	0.32
1-3/4	Panel door with 3/4 inch panelse	0.40	0.27	0.29
1-3/4	Panel door with 1-1/8 inch panelse	0.39	0.26	0.28
1-3/4	Solid core flush door	0.33	0.28	0.25
2-1/4	Solid core flush door	0.27	0.20	0.21
Steel Doors ^b				-
1-3/4	Fiberglass or mineral wool core w/ steel stiffeners, no thermal break ^f	0.60		
1-3/4	Paper honeycomb core without thermal break	0.56		
1-3/4	Solid urethane foam core without thermal breaka	0.40		
1-3/4	Solid fire rated mineral fiberboard core without thermal break ^f	0.38		
1-3/4	Polystyrene core without thermal break (18 gage commercial steel) ^f	0.35		
1-3/4	Polyurethane core without thermal break (18 gage commercial steel) ^f	0.29		
1-3/4	Polyurethane core without thermal break (24 gage commercial steel) ^f	0.29		
1-3/4	Polyurethane core w/ thermal break & wood perimeter (24 gage commercial steel) ^f	0.20		
		0.10	11.10	0.12



- a Values are based on a nominal 32 by 80 in. door size with no glazing.
- b Outside air conditions: 15 mph wind speed, 0°F air temperature; inside air conditions: natural convection, 70°F air temperature.
- c Values for wood storm door are for approximately 50% glass area.
- d Values for metal storm door are for any percent glass area.
- e 55% panel area.
- f ASTM C 236 hotbox data on a nominal 3 by 7 ft door size with no glazing.

The U-values in Table 6C are for exterior wood and steel doors. The values given for wood doors were calculated, and those for steel doors were taken from hotbox tests (Sabine et al. 1975; Yellot 1965) or from manufacturer's test reports. An outdoor surface conductance of 6.0 Btu/h*ft²*°F was used, and the indoor surface conductance was taken as 1.4 Btu/h*ft²*°F for vertical surfaces with horizontal heat flow. All values given are for exterior doors without glazing. If an exterior door contains glazing, refer to Table 10-6D.

TABLE 10-6D APPROVED GLAZED DOOR DEFAULT U-VALUES²

	Door Material				
	Insu	lated ⁶	We	Wood ⁷	
Description ^{2,3,4,5}	Full-Lite ^{4,9}	Half-Lite ^{10,11}	Full-Lite ³	Half-Lite ¹⁰	
Double, Clear 1/4"	0.39	0.31	0.47	0.42	
Double, Clear 1/4" + argon	0.37	0.30	0.45	0.41	
Double, Low-e4 1/4"	0.36	0.30	0.44	0.41	
Double, Low-e2 1/4"	0.35	0.29	0.43	0.40	
Double, Low-e1 1/4"	0.24	0.28	0.41	0.39	
Double, Low-e4 1/4" + argon	0.33	0.28	0.41	0.39	
Double, Low-e2 1/4" + argon	0.31	0.26	0.39	0.38	
Double, Low-e1 1/4" + argon	0.31	0.26	0.38	0.37	
Double, Clear 3/8"	0.37	0.30	0.45	0.41	
Double, Clear 3/8" + argon	0.36	0.29	0.44	0.41	
Double, Low-e4 3/8"	0.34	0.28	0.42	0.40	
Double, Low-e2 3/8"	0.33	0.28	0.41	0.39	
Double, Low-el 3/8"	0.21	0.26	0.38	0.37	
Double, Low-e4 3/8" + argon	0.32	0.27	0.40	0.38	
Double, Low-e2 3/8" + argon	0.29	0.25	0.37	0.37	
Double, Low-el 3/8" + argon	0.29	0.25	0.36	0.36	
Double, Clear 1/2"	0.36	0.29	0.44	0.41	
Double, Clear 1/2" + argon	0.34	0.28	0.42	0.40	
Double, Low-e4 1/2*	0.32	0.27	0,40	0.38	
Double, Low-e2 1/2*	0.30	0.26	0.38	0.37	
Double, Low-el 1/2"	0.29	0.25	0.36	0.36	
Double, Low-e4 1/2" + argon	0.30	0.26	0.38	0.37	
Double, Low-e2 1/2" + argon	0.28	0.25	0.36	0.36	
Double, Low-el 1/2* + argon	0.28	0.24	0.34	0.35	
Triple, Clear 1/4"	0.31	0.26	0.39	0.38	
Triple, Clear 1/4" + argon	0.29	0.25	0.37	0.37	
Triple, Low-e4 1/4"	0.30	0.26	0.38	0.37	
Triple, Low-e2 1/4"	0.29	0.25	0.37	0.36	
Triple, Low-e4 1/4" + argon	0.27	0.24	0.35	0.35	
Triple, Low-e2 1/4" + argon	0.26	0.24	0.34	0.35	



.

0



1

93

Footnotes to Table 10-6D

- 1 Subtract 0.02 from the listed default U-value for insulated spacers. Insulated spacer material includes fiberglass, wood and butyl or other material with an equivalent Thermal performance.
- 2 1/4" = a minimum dead air space of 0.25 inches between the panes of glass.
 3/8" = a minimum dead air space of 0.375 inches between the panes of glass.
 1/2" = a minimum dead air space of 0.5 inches between the panes of glass.
 Products with air spaces different than those listed above shall use the value for next smaller air space; i.e. 3/4 inch = 1/2 inch U-values, 7/16 inch = 3/8 inch U-values, 5/16 inch = 1/4 inch U-values.
- 3 Low-e4 (emissivity) shall be 0.4 or less. Low-e2 (emissivity) shall be 0.2 or less. Low-e1 (emissivity) shall be 0.1 or less.
- U-values listed for argon shall consist of sealed, gas-filled, insulated units for argon, CO2, SF6 and argon/SF6 mixtures.
 The following conversion factor shall apply to Krypton gas-filled units:
 1/4 inch or greater airspace of Krypton gas-fill = 1/2 inch air space Argon gas-fill.
- 5 Dividers placed between glazing: The U-values listed shall be used where the divider has a minimum gap of 1/8 inch between the divider and lite of each inside glass surface. Add 0.03 to the listed U-value for True Divided Lite windows.
- 6 Insulated = Any urethane insulated foam core door with a thermal break. Thermal Break = A thermal break door shall incorporate the following design characteristics:
 - a) The thermal conductivity of the thermal break material shall be not more than 3.6 Btu-in/h•ft²•°F; and
 - b) The thermal break material shall not be less than 0.210 inches.
- 7 Wood = any wood door.
- 8 Full-Lite = A door that consists of more than 50% glazing.
- 9 Add 0.05 to the listed U-value for Full-Lite values if the insulated door does not have a thermal break.
- 10 Half-Lite = A door that consists of 50% or less glazing.
- 11 Add 0.06 to the listed U-value for Half-Lite values if the insulated door does not have a thermal break.

SECTION 1007 - CEILINGS

1007.1 General: Table 10-7 lists heat loss coefficients for the opaque portion of exterior ceilings below vented attics, vaulted ceilings and roof decks in units of Btu/h*ft²*°F of ceiling.

They are derived from procedures listed in Standard RS-1, listed in Chapter 7. Ceiling U-values are modified for the buffering effect of the attic, assuming an indoor temperature of 65°F and an outdoor temperature of 45°F.

1007.2 Component Description: The three types of ceilings are characterized as follows:

Ceilings Below a Vented Attic: Attic insulation is assumed to be blown-in, loose-fill fiberglass with a K-value of 2.6 h*ft²* F/Btu per inch. Full bag count for specified R-value is assumed in all cases. Ceiling dimensions for flat ceiling calculations are 45 by 30 feet, with a gabled roof having a 4/12 pitch. The attic is assumed to vent naturally at the rate of 3 air changes per hour through soffit and ridge vents. A void fraction of 0.002 is assumed for all attics with insulation baffles. Standard-framed, unbaffled attics assume a void fraction of 0.008.

Attic framing is either standard or advanced. Standard framing assumes tapering of insulation depth around the perimeter with resultant decrease in thermal resistance. An increased R-value is assumed in the center of the ceiling due to the effect of piling leftover insulation. Advanced framing assumes full and even depth of insulation extending to the outside edge of exterior walls. Advanced framing does not change from the default value.

U-values for flat ceilings below vented attics with standard framing may he modified with the following table:

	U-Value fo			
-	Standar	rd Framing		
Roof Pitch	R-30	R-38		
4/12	0.036	0.031		
5/12	0.035	0.030		
6/12	0.034	0.029		
7/12	0.034	0.029		
8/12	0.034	0.028		
9/12	0.034	0.028		
10/12	0.033	0.028		
11/12	0.033	0.027		
12/12	0.033	0.027		

Vented scissors truss attics assume a ceiling pitch of 2/12 with a roof pitch of either 4/12 or 5/12. Unbaffled standard framed scissors truss attics are assumed to have a void fraction of 0.016.











Vaulted Ceilings: Insulation is assumed to be fiberglass batts installed in roof joist cavities. In the vented case, at least 1.5 inches between the top of the batts and the underside of the roof sheathing is left open for ventilation in each cavity. A ventilation rate of 3 air changes per hour is assumed. In the unvented or dense pack case, the ceiling cavity is assumed to be fully packed with insulation, leaving no space for ventilation.

Roof Decks: Rigid insulation is applied to the top of roof decking with no space left for ventilation. Roofing materials are attached directly on top of the insulation. Framing members are often left exposed on the interior side.

TABLE 10-7 DEFAULT U-VALUES FOR CEILINGS

Ceilings Below Vented Attics

•

	Standard Frame	Advanced Frame	
Flat Ceiling	Baffled		
R-19	0.049	0.047	
R-30	0.036	0.032	
R-38	0.031	0.026	
R-49	0.027	0.020	
R-60	0.025	0.017	
Scissors Truss			
R-30 (4/12 roof pitch)	0.043	0.031	
R-38 (4/12 roof pitch)	0.040	0.025	
R-49 (4/12 roof pitch)	0.038	0.020	
R-30 (5/12 roof pitch)	0.039	0.032	
R-38 (5/12 roof pitch)	0.035	0.026	
R-49 (5/12 roof pitch)	0.032	0.020	
Vaulted Ceilings	A CARLON AND A CARLON		
	16" O.C.	24" O.C.	
Vented			
R-19 2x10 joist	0.049	0.048	
R-30 2x12 joist	0.034	0.033	
R-38 2x14 joist	0.027	0.027	
Unvented			
R-30 2x10 joist	0.034	0.033	
R-38 2x12 joist	0.029	0.027	
R-21 + R-21 2x12 joist	0.026	0.025	
Roof Deck			
	4x Beams	, 48" O.C.	
R-12.5 2" Rigid insulation	0.0)64	
R-21.9 3.5" Rigid insulation	ulation 0.040		
R-37.5 6" Rigid insulation	0.025		
R-50 8" Rigid insulation	0.019		

SECTION 1008 -- AIR INFILTRATION

1008.1 General: Tables 10-8 and 10-9 list effective air change rates and heat capacities for heat loss due to infiltration.

The estimated seasonal average infiltration rate in air changes per hour (ACH) is given for standard air-leakage control (see Section 502.4 of this Code for air leakage requirements). The effective air change rate shall be used in calculations for compliance under either the Component Performance or Systems Analysis approaches.

Heat loss due to infiltration shall be computed using the following equation:

$$Q_{infil} = ACH_{eff} * HCP$$

Where:

Qinfit	= Heat loss due to air infiltration.
ACHeff	= The effective air infiltration rate in Table 10-8.
HCP	= The Heat Capacity Density Product for the appropriate elevation or climate zone as given below.

TABLE 10-8 ASSUMED EFFECTIVE AIR CHANGES PER HOUR

Air-Leakage Control Package Air Changes per Hour Natural Effective

Standard

0.35 0.35

TABLE 10-9 DEFAULT HEAT CAPACITY/DENSITY PRODUCT FOR AIR

Zone	Average Elevation	Heat Capacity/Density	
1	Mean Sea Level	0.0180 Btu/h**F	
2	2000	0.0168 Btu/h•°F	
3	3000	0.0162 Btu/h*°F	

SECTION 1009 -- MASS

1009.1 General: Table 10-10 lists default mass-values for residential construction types. All calculations are based on standard ASHRAE values for heat-storage capacity as listed in Standard RS-1, Chapter 22.

Thermal capacity of furniture is ignored, as is heat storage beyond the first 4 inches of mass thickness. All mass is assumed to be in direct contact with the conditioned space. Concrete separated from the heated volume by other materials must multiply the listed concrete mass value by the result of the following formula:

Ln(R-value) x (-.221) + 0.5

Where:

Ln = Natural log R-value = R-value of material covering concrete

Note: All default values for covered concrete slabs have been adjusted according to this procedure.

1009.2 Mass Description: Mass is divided into two types: structural and additional.

Structural Mass: Includes heat-storage capacity of all standard building components of a typical residential structure, including floors, ceilings and interior and exterior walls in Btu/ft²*°F of floor area. It also assumes exterior wall, interior wall and ceiling surface area approximately equals three times the floor area.

Additional Mass: Includes any additional building material not part of the normal structure, which is added specifically to increase the building's thermal-storage capability. This category includes masonry fireplaces, water or trombe walls and extra layers of sheetrock. Coefficients are in Btu/fi²*°F of surface area of material exposed to conditioned space. The coefficient for water is Btu/°F*gallon.

1009.3 Component Description: Light frame assumes 1 inch thick wood flooring with 5/8 inch sheetrock on ceilings and interior walls, and walls consisting of either 5/8 inch sheetrock or solid logs. Slab assumes a 4 inch concrete slab on or below grade, with5/8 inch sheetrock on exterior and interior walls and ceiling, and with separate values for interior or exterior wall insulation. Adjustments for slab covering is based on R-value of material. Additional mass values are based on the density multiplied by the specific heat of the material adjusted for listed thickness.

TABLE 10-10 DEFAULT MASS VALUES

tructural Mass M-value	Btu/ft²•°F floor area
ight Frame:	
Joisted/post & beam floor, sheetrock	
walls and ceilings	3.0
Joisted/post & beam floor, log walls,	11.4
sheetrock ceilings	4.0
lab With Interior Wall Insulation:	
Slab, no covering or tile, sheetrock walls and ceilings	10.0
Slab, hardwood floor covering, sheetrock walls and ceilin	ngs 7.0
Slab, carpet and pad, sheetrock walls and ceilings	5.0
lab With Exterior Wall Insulation:	
Slab no covering or tile sheetrock walls and ceilings	12.0
Slab hardwood floor covering sheetrock walls and ceilir	188 9.0
Slab, carpet and pad, sheetrock walls and ceilings	7.0
dditional Mass M-Value:	Btu/ft²•°F surface area
Gunny wellboard 1/2 inch thickness	0.54
Gypsum wallboard 5/8 inch thickness	0.68
Hardwood floor	1.40
Concrete/Brick, 4 inch-thickness	10.30
Concrete/Brick, 6 inch-thickness	15.40
	Btu/°F•gallon
Water, 1 gallon	8.0

0

ſ



CHAPTER 11 ADMINISTRATION AND ENFORCEMENT

SECTION 1100 - TITLE: Chapters 11 through 20 of this Code shall be known as the "Washington State Nonresidential Energy Code" and may be cited as such; and will be referred to hereafter as "this Code."

SECTION 1110 -- PURPOSE AND INTENT: The purpose of this Code is to provide minimum standards for new or altered buildings and structures or portions thereof to achieve efficient use and conservation of energy. It is intended that these provisions provide flexibility to permit the use of innovative approaches and techniques to achieve efficient use and conservation of energy.

The purpose of this Code is not to create or otherwise establish or designate any particular class or group of persons who will or should be especially protected or benefited by the terms of this Code. This Code is not intended to abridge any safety or health requirements required under any other applicable codes or ordinances.

The provisions of this Code do not consider the efficiency of various energy forms as they are delivered to the building envelope.

SECTION 1120 -- SCOPE: This Code sets forth minimum requirements for the design of new or altered buildings and structures or portions thereof that provide facilities or shelter for public assembly, educational, business, mercantile, institutional, storage, factory and industrial occupancies by regulating their exterior envelopes and the selection of their HVAC, service water heating, electrical distribution and illuminating systems and equipment for efficient use and conservation of energy.

SECTION 1130 -- APPLICATION TO EXISTING BUILDINGS: Additions, alterations or repairs, changes of occupancy or use and historic buildings that do not comply with the requirements for new buildings shall comply with the requirements in Sections 1130 through 1134.

Exception: The building official may approve designs of alterations or repairs which do not fully conform with all of the requirements of Sections 1130 through 1134 where in the opinion of the building official full compliance is physically impossible and/or economically impractical and the alteration or repair improves the energy efficiency of the building.

In no case shall energy code requirements be less than those requirements in effect at the time of the initial construction of the building.

1131 Additions to Existing Buildings: Additions to existing buildings or structures may be constructed without making the entire building or structure comply, provided that the new additions shall conform to the provisions of this Code.

Exception: New additions which do not fully comply with the requirements of this Code and which have a floor area which is less than 750 ft² may be approved provided that improvements are made to the existing building to compensate for any deficiencies in the new addition. Compliance shall be demonstrated by either systems analysis per Section 1141.4 or component performance calculations per Sections 1330 through 1334. The nonconforming addition and upgraded existing building shall have an energy budget or target UA and SHGC that are less than or equal to the unimproved existing building, with the addition designed to comply with this Code.

1132 Alterations and Repairs: Alterations and repairs to buildings or portions thereof originally constructed subject to the requirements of this Code shall conform to the provisions of this Code without the use of the exception in Section 1130. Other alterations and repairs may be made to existing buildings and moved buildings without making the entire building comply with all of the requirements of this Code for new buildings, provided the following requirements are met:

1132.1 Building Envelope: Alterations or repairs shall comply with nominal Rvalues and glazing requirements in Table 13-1 or 13-2.

Exceptions:

- 1. Storm windows installed over existing glazing.
- Glass replaced in existing sash and frame provided that glazing is of equal or lower U-factor.
- For solar heat gain coefficient compliance, glazing with a solar heat gain coefficient equal to or lower than that of the other existing glazing.
- Existing roof/ceiling, wall or floor cavities exposed during construction provided that these cavities are insulated to full depth with insulation having a minimum nominal value of R-3.0 per inch installed per Sections 1311 and 1313.
- Existing walls and floors without framing cavities, provided that any new cavities added to existing walls and floors comply with Exception 4.
- 6. Where the roof membrane is being replaced and
 - a. The roof sheathing or roof insulation is not exposed; or
 - b. If there is existing roof insulation below the deck.

In no case shall the energy efficiency of the building be decreased.

1132.2 Building Mechanical Systems: Those parts of systems which are altered or replaced shall comply with Chapter 14 of this Code.

1994 FIRST EDITION

1132.3 Lighting and Motors: Tenant improvements, alterations or repairs where 60% or more of the fixtures are new shall comply with Sections 1531 and 1532. Where less than 60% of the fixtures are new, the installed lighting wattage shall be maintained or reduced. Where 60% or more of the lighting fixtures in a suspended ceiling are new, and the existing insulation is on the suspended ceiling, the roof/ceiling assembly shall be insulated according to the provisions of Chapter 13, Section 1311.2.

Where new wiring is being installed to serve added fixtures and/or fixtures are being relocated to a new circuit, controls shall comply with Sections 1513.1 through 1513.5. Where a new lighting panel with all new raceway and conductor wiring from the panel to the fixtures is being installed, controls shall comply with Section 1513.6.

Those motors which are altered or replaced shall comply with Section 1511.

1133 Change of Occupancy or Use: Changes of occupancy or use shall comply with the following requirements:

- Any unconditioned space that is altered to become conditioned space shall be required to be brought into full compliance with this Code.
- b. Any Group R occupancy which is converted to other than a Group R occupancy shall be required to comply with all of the provisions of Sections 1130 through 1132 of this Code.

1134 Historic Buildings: The building official may modify the specific requirements of this Code for historic buildings and require in lieu thereof alternate requirements which will result in a reasonable degree of energy efficiency. This modification may be allowed for those buildings which have been specifically designated as historically significant by the state or local governing body, or listed in The National Register of Historic Places or which have been determined to be eligible for listing.

SECTION 1140 -- ENFORCEMENT: The building official shall have the power to render interpretations of this code and to adopt and enforce rules and supplemental regulations in order to clarify the application of its provisions. Such interpretations, rules and regulations shall be in conformance with the intent and purpose of this Code. Fees may be assessed for enforcement of this Code and shall be as set forth in the fee schedule adopted by the jurisdiction.

1141 Plans and Specifications

1141.1 General: If required by the building official, plans and specifications shall be submitted in support of an application for a building permit. If required by the building official, plans and specifications shall be stamped and authenticated by a registered design professional currently licensed in the state of Washington. All plans and specifications, together with supporting data, shall be submitted to the building official prior to issuance of a building permit.

1141.2 Details: The plans and specifications shall show in sufficient detail all pertinent data and features of the building and the equipment and systems as herein governed including, but not limited to: design criteria; exterior envelope component materials, U-factors of the envelope systems, R-values of insulating materials; U-factors and shading coefficients of glazing; area weighted U-factor calculations; efficiency, economizer, size and type of apparatus and equipment; fan system horsepower; equipment and systems controls; lighting fixture schedule with wattages and controls narrative; and other pertinent data to indicate compliance with the requirements of this Code.

1141.3 Alternate Materials and Method of Construction: The provisions of this Code are not intended to prevent the use of any material, method of construction, design or insulating system not specifically prescribed herein, provided that such construction, design or insulating system has been approved by the building official as meeting the intent of this Code. The building official may approve any such alternate provided the proposed alternate meets or exceeds the provisions of this Code and that the material, method, design or work offered is for the purpose intended, at least the equivalent of that prescribed in this Code, in quality, strength, effectiveness, fire-resistance, durability, safety and energy efficiency. The building official may require that sufficient evidence of proof be submitted to substantiate any claims that may be made regarding performance capabilities.

1141.4 Systems Analysis Approach for the Entire Building: In lieu of using Chapters 12 through 20, compliance may be demonstrated using the systems analysis option in Standard RS-29. When using systems analysis, the proposed building shall provide equal or better conservation of energy than the standard design as defined in Standard RS-29. If required by the building official, all energy comparison calculations submitted under the provisions of Standard RS-29 shall be stamped and authenticated by an engineer or architect licensed to practice by the state of Washington.

1142 Materials and Equipment

1142.1 Identification: All materials and equipment shall be identified in order to show compliance with this Code.

1142.2 Maintenance Information: Maintenance instructions shall be furnished for any equipment which requires preventive maintenance for efficient operation. Required regular maintenance actions shall be clearly stated and incorporated on a readily accessible label. Such label may be limited to identifying, by title or publication number, the operation and maintenance manual for that particular model and type of product.

1143 Inspections

1143.1 General: All construction or work for which a permit is required shall be subject to inspection by the building official and all such construction or work shall remain accessible and exposed for inspection purposes until approved by the building official. No work shall be done on any part of the building or structure beyond the point indicated in each inspection without first obtaining the approval of the building official.

1143.2 Required Inspections: The building official, upon notification, shall make the inspection required in this Section, in addition to or as part of those inspections required in Section 305(e) of the Uniform Building Code. Inspections may be conducted by special inspection pursuant to Section 306(b) and 306(c) of the Uniform Building Code. Where applicable, inspections shall include at least:

1143.2.1 Envelope

- Wall Insulation Inspection: To be made after all wall insulation and air vapor retarder sheet or film materials are in place, but before any wall covering is placed.
- B. Glazing Inspection: To be made after glazing materials are installed in the building.
- Exterior Roofing Insulation: To be made after the installation of the roof insulation, but before concealment.
- Slab/Floor Insulation: To be made after the installation of the slab/floor insulation, but before concealment.

1143.2.2 Mechanical

- a. Mechanical Equipment Efficiency and Economizer: To be made after all equipment and controls required by this Code are installed and prior to the concealment of such equipment or controls.
- Mechanical Pipe and Duct Insulation: To be made after all pipe and duct insulation is in place, but before concealment.

1143.2.3 Lighting and Motors

- a. Lighting Equipment and Controls: To be made after the installation of all lighting equipment and controls required by this Code, but before concealment of the lighting equipment.
- Motor Inspections: To be made after installation of all equipment covered by this Code, but before concealment.

1143.3 Re-inspection: The building official may require a structure to be reinspected. A re-inspection fee may be assessed for each inspection or reinspection when such portion of work for which inspection is called is not complete or when corrections called for are not made.

1144 Violations: It shall be a violation of this Code for any person, firm or corporation to erect or construct any building, or remodel or rehabilitate any existing building or structure in the state, or allow the same to be done, contrary to any of the provisions of this Code.

1150 CONFLICTS WITH OTHER CODES: In case of conflicts among Codes enumerated in RCW 19.27.031 subsections (1), (2), (3) and (4) and this Code, the first named Code shall govern. The duct insulation requirements in this Code or a local jurisdiction's energy code, whichever is more stringent, supersede the requirements in the Uniform Mechanical Code.

Where, in any specific case, different sections of this Code specify different materials, methods of construction or other requirements, the most restrictive shall govern. Where there is a conflict between a general requirement and a specific requirement, the specific requirement shall be applicable.

1160 SEVERABILITY & LIABILITY

1161 Severability: If any provision of this Code or its application to any person or circumstance is held invalid, the remainder of this Code or the application of the provision to other persons or circumstances is not affected.

1162 Liability: Nothing contained in this Code is intended to be nor shall be construed to create or form the basis for any liability on the part of any city or county or its officers, employees or agents for any injury or damage resulting from the failure of a building to conform to the provisions of this Code.

1994 FIRST EDITION

CHAPTER 12 DEFINITIONS

1201 Scope: The following definitions will apply to Chapters 11 through 20.

SECTION 1210 – APPLICATION OF TERMS: For the purposes of this Code, certain abbreviations, terms, phrases, words and their derivatives, shall be as set forth in this chapter. Where terms are not defined, they shall have their ordinary accepted meanings within the context with which they are used. In the event there is a question about the definition of a term, the definitions for terms in the Codes enumerated in RCW 19.27.031 and the edition of Webster's dictionary referenced therein shall be considered as the sources for providing ordinarily accepted meanings.

AAMA: American Architectural Manufacturers Association.

ADDITION: See the Washington State Building Code.

ADVANCED FRAMED CEILING: Advanced framing assumes full and even depth of insulation extending to the outside edge of exterior walls. (See Standard Framing and Section 2007.2 of this Code.)

ADVANCED FRAMED WALLS: Studs framed on 24 inch centers with double top plate and single bottom plate. Corners use two studs or other means of fully insulating corners, and one stud is used to support each header. Headers consist of double 2X material with R-10 insulation between the header and exterior sheathing. Interior partition wall/exterior wall intersections are fully insulated in the exterior wall. (See Standard Framing and Section 2005.2 of this Code.)

AFUE - ANNUAL FUEL UTILIZATION EFFICIENCY: Unlike steady state conditions, this rating is based on average usage including on and off cycling as set out in the standardized Department of Energy Test Procedures.

AIR CONDITIONING, COMFORT: The process of treating air to control simultaneously its temperature, humidity, cleanliness and distribution to meet requirements of the conditioned space.

ARI: Air-Conditioning and Refrigeration Institute.

ASHRAE: American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.

ASTM: American Society for Testing and Materials.

AUTOMATIC: Self-acting, operating by its own mechanism when actuated by some impersonal influence, as for example, a change in current strength, pressure, temperature or mechanical configuration. (See Manual.)

BELOW GRADE WALLS: Walls or the portion of walls which are entirely below the finished grade or which extend two feet or less above the finish grade.

BOILER CAPACITY: The rate of heat output in Btu/h measured at the boiler outlet, at the design inlet and outlet conditions and rated fuel/energy input.

BUILDING ENVELOPE: The elements of a building which enclose conditioned spaces through which thermal energy may be transferred to or from the exterior, or to or from unconditioned spaces, or to or from semi-heated spaces, or to or from spaces exempted by the provisions of Section 1301.

BUILDING, EXISTING: See the Washington State Building Code.

BUILDING OFFICIAL: The official authorized to act in behalf of a jurisdiction code enforcement agency or its authorized representative.

BUILDING PROJECT: A building or group of buildings, including on-site energy conversion or electric-generating facilities, which utilize a single submittal for a construction permit or are within the boundary of a contiguous area under one ownership.

CONDITIONED FLOOR AREA: (See Gross Conditioned Floor Area.)

CONDITIONED SPACE: A cooled space, heated space (fully heated), heated space (semi-heated) or indirectly conditioned space.

COOLED SPACE: An enclosed space within a building that is cooled by a cooling system whose sensible capacity

- a. exceeds 5 Btu/(h ft²), or
- b. is capable of maintaining space dry bulb temperature of 90 °F or less at design cooling conditions.

COP - COEFFICIENT OF PERFORMANCE: The ratio of the rate of net heat output (heating mode) or heat removal (cooling mode) to the rate of total on-site energy input to the heat pump, expressed in consistent units and under designated rating conditions.(See Net Heat Output, Net Heat Removal, Total On-Site Energy Input.)

DAYLIGHTED ZONE:

a. Under overhead glazing: the area under overhead glazing whose horizontal dimension, in each direction, is equal to the overhead glazing dimension in that direction plus either the floor to ceiling height or the dimension to a ceiling height opaque partition, or onehalf the distance to adjacent overhead or vertical glazing, whichever is least.

b. At vertical glazing: the area adjacent to vertical glazing which receives daylighting from the glazing. For purposes of this definition and unless more detailed daylighting analysis is provided, the daylighting zone depth is assumed to extend into the space a distance of 15 feet or to the nearest ceiling height opaque partition, whichever is less. The daylighting zone width is assumed to be the width of the window plus either two feet on each side (the distance to an opaque partition) or one-half the distance to adjacent overhead or vertical glazing, whichever is least. DAYLIGHT SENSING CONTROL (DS): A device that automatically regulates the power input to electric lighting near the glazing to maintain the desired workplace illumination, thus taking advantage of direct or indirect sunlight.

DEADBAND: The temperature range in which no heating or cooling is used.

DESIGN COOLING CONDITIONS: The cooling outdoor design temperature from the 0.5% column for summer from the Puget Sound Chapter of ASHRAE publication "Recommended Outdoor Design Temperatures, Washington State, ASHRAE."

DESIGN HEATING CONDITIONS: The heating outdoor design temperature from the 0.6% column for winter from the Puget Sound Chapter of ASHRAE publication "Recommended Outdoor Design Temperatures, Washington State, ASHRAE."

DOOR AREA: Total area of door measured using the rough opening and including the door and frame.

DOOR: All operable opening areas, which are not glazing, in the building envelope including swinging and roll-up doors, fire doors, smoke vents and access hatches.

DWELLING UNIT: See the Washington State Building Code.

EER - ENERGY EFFICIENCY RATIO: The ratio of net equipment cooling capacity in Btu/h to total rate of electric input in watts under designated operating conditions.

ECONOMIZER, AIR: A ducting arrangement and automatic control system that allows a cooling supply fan system to supply outside air to reduce or eliminate the need for mechanical refrigeration during mild or cold weather.

ECONOMIZER, WATER: A system by which the supply air of a cooling system is cooled directly, indirectly or both, by evaporation of water or by other appropriate fluid in order to reduce or eliminate the need for mechanical refrigeration.

EFFICIENCY, HVAC SYSTEM: The ratio of useful energy (at the point of use) to the energy input for a designated time period, expressed in percent.

EMISSIVITY: The ability to absorb infrared radiation. A low emissivity implies a higher reflectance of infrared radiation.

ENERGY: The capacity for doing work; taking a number of forms which may be transformed from one into another, such as thermal (heat), mechanical (work), electrical and chemical; in customary units, measured in kilowatt-hours (kWh) or British thermal units (Btu). (See New energy.)

ENERGY, RECOVERED: (See Recovered Energy.)

EXTERIOR ENVELOPE: (See Building Envelope.)

FACADE AREA: Vertical projected area including non-horizontal roof area, overhangs, cornices, etc. measured in elevation in a vertical plane parallel to the plane of the building face.

FLOOR OVER UNCONDITIONED SPACE: A floor which separates a conditioned space from an unconditioned space which is buffered from exterior ambient conditions including vented crawlspaces and unconditioned basements or other similar spaces, or exposed to exterior ambient conditions including open parking garages and enclosed garages which are mechanically ventilated.

F-FACTOR: The perimeter heat loss factor expressed in Btu/h . ft . °F.

F-VALUE: (See F-Factor.)

GLAZING: All areas, including the frames, in the shell of a conditioned space that let in natural light including windows, clerestories, skylights, sliding or swinging glass doors and glass block walls.

GLAZING AREA: Total area of the glazing measured using the rough opening, and including the glazing, sash and frame. For doors where the daylight opening area is less than 50% of the door area, the glazing area is the daylight opening area. For all other doors, the glazing area is the door area.

GROSS CONDITIONED FLOOR AREA: The horizontal projection of that portion of interior space which is contained within exterior walls and which is conditioned directly or indirectly by an energy-using system, and which has an average height of five feet or greater, measured from the exterior faces.

GROSS EXTERIOR WALL AREA: The normal projection of the building envelope wall area bounding interior space which is conditioned by an energyusing system; includes opaque wall, vertical glazing and door areas. The gross area of walls consists of all opaque wall areas, including foundation walls, between floor spandrels, peripheral edges of floors, vertical glazing areas and door areas, where such surfaces are exposed to exterior ambient conditions and enclose a conditioned space including interstitial areas between two such spaces. (See Below Grade Wall)

GROSS FLOOR AREA: The sum of the areas of the several floors of the building, including basements, cellars, mezzanine and intermediate floored tiers and penthouses of headroom height, measured from the exterior faces of exterior walls or from the center line of walls separating buildings, but excluding: Covered walkways, open roofed-over areas, porches and similar spaces, pipe trenches, exterior terraces or steps, chimneys, roof overhangs and similar features. GROSS ROOF/CEILING AREA: A roof/ceiling assembly shall be considered as all components of the roof/ceiling envelope through which heat flows, thus creating a building transmission heat loss or gain, where such assembly is exposed to exterior ambient conditions and encloses a conditioned space. The assembly does not include those components that are separated from a heated and/or cooled space by a vented airspace. The gross area of a roof/ceiling assembly consists of the total interior surface of such assembly, including overhead glazing.

GUEST ROOM: See the Washington State Building Code.

HEAT: The form of energy that is transferred by virtue of a temperature difference.

HEAT STORAGE CAPACITY: The physical property of materials (mass) located inside the building envelope to absorb, store and release heat.

HEATED SPACE (FULLY HEATED): An enclosed space within a building, including adjacent connected spaces separated by an un-insulated component (e.g., basements, utility rooms, garages, corridors), which is heated by a heating system whose output capacity is

- a. capable of maintaining a space dry-bulb temperature of 45 °F or greater at design heating conditions; or
- b. 8 Btu/(h ft²) or greater in Climate Zone 1 and 12 Btu/(h ft²) or greater in Climate Zone 2.

HEATED SPACE (SEMI-HEATED): An enclosed space within a building, including adjacent connected spaces separated by an un-insulated component (e.g., basements, utility rooms, garages, corridors), which is heated by a heating system

- a. whose output capacity is 3 Btu/(h ft²) or greater in Climate Zone 1 and 5 Btu/(h • ft²) or greater in Climate Zone 2; and
- b. is not a Heated Space (Fully Heated).

HSPF - **HEATING SEASON PERFORMANCE FACTOR:** The total heating output (Btu) of a heat pump during its normal annual usage period for heating divided by the total electric power input (watt hour) during the same period, as determined by test procedures consistent with the U.S. Department of Energy "Test Procedure for Central Air Conditioners, Including Heat Pumps," published in Standard RS-30. When specified in Btu per watt hour an HSPF of 6.826 is equivalent to a COP of 2.0.

IIUMIDISTAT: A regulatory device, actuated by changes in humidity, used for automatic control of relative humidity.

IIVAC: Heating, ventilating and air conditioning.

HVAC SYSTEM COMPONENTS: HVAC system components provide, in one or more factory-assembled packages, means for chilling and/or heating water with controlled temperature for delivery to terminal units serving the conditioned spaces of the buildings. Types of HVAC system components include, but are not limited to, water chiller packages, reciprocating condensing units and water source (hydronic) heat pumps. (See HVAC System Equipment.)

HVAC SYSTEM EFFICIENCY: (See Efficiency, HVAC System.)

IIVAC SYSTEM EQUIPMENT: HVAC system equipment provides, in one (single package) or more (split system) factory-assembled packages, means for air circulation, air cleaning, air cooling with controlled temperature and dehumidification; and optionally, either alone or in combination with a heating plant, the functions of heating and humidifying. The cooling function may be either electrically or heat operated and the refrigerant condenser may be air, water or evaporatively cooled. Where the equipment is provided in more than one package, the separate packages shall be designed by the manufacturer to be used together. The equipment may provide the heating function as a heat pump or by the use of electric elements. (The word "equipment" used without modifying adjective may, in accordance with common industry usage, apply either to HVAC system equipment or HVAC system components.)

INDIRECTLY CONDITIONED SPACE: An enclosed space within a building that is not a heated or cooled space, whose area weighted heat transfer coefficient to heated or cooled spaces exceeds that to the outdoors or to unconditioned spaces; or through which air from heated or cooled spaces is transferred at a rate exceeding three air changes per hour. Enclosed corridors between conditioned spaces shall be considered as indirectly conditioned space. (See Heated Space, Cooled Space and Unconditioned Space.)

INFILTRATION: The uncontrolled inward air leakage through cracks and interstices in any building element and around windows and doors of a building caused by the pressure effects of wind and/or the effect of differences in the indoor and outdoor air density.

INSULATION BAFFLE: A rigid material, resistant to wind driven moisture, the purpose of which is to allow air to flow freely into the attic or crawl space and to prevent insulation from blocking the ventilation of these spaces, or the loss of insulation. Example materials for this purpose are sheet metal or wax impregnated cardboard.

INSULATION POSITION:

- a. Exterior Insulation Position: a wall having all or nearly all of its mass exposed to the room air with the insulation on the exterior of the mass.
- b. Integral Insulation Position: a wall having mass exposed to both room and outside air, with substantially equal amounts of mass on the inside and outside of the insulation layer.
- c. Interior Insulation Position: a wall not meeting either of the above definitions; particularly a wall having most of its mass external to the insulation layer.

IPLV - INTEGRATED PART-LOAD VALUE: A single number figure of merit based on part-load EER or COP expressing part-load efficiency for air conditioning and heat pump equipment on the basis of weighted operation at various load capacities for the equipment as specified in the Air-Conditioning and Refrigeration Institute (ARI) and Cooling Tower Institute (CTI) procedures.

LUMINAIRE: A complete lighting unit consisting of a lamp or lamps together with the parts designed to distribute the light, to position and protect the lamps and to connect the lamps to the electric power supply.

MANUAL: Capable of being operated by personal intervention. (See Automatic.)

NFPA: National Fire Protection Association,

NFRC: National Fenestration Rating Council.

NET HEAT OUTPUT: The change in the total heat content of the air entering and leaving the equipment (not including supplementary heat and heat from boilers).

NET HEAT REMOVAL: The total difference in heat content of the air entering and leaving the equipment (without heat) or the difference in total heat content of the water or refrigerant entering and leaving the component.

NEW ENERGY: Energy, other than recovered energy, utilized for the purpose of heating or cooling. (See Energy.)

NOMINAL R-VALUE: The thermal resistance of insulation as specified by the manufacturer according to recognized trade and engineering standards.

NONRENEWABLE ENERGY SOURCES: All energy sources that are not renewable energy sources including natural gas, oil, coal, wood, liquified petroleum gas, steam and any utility-supplied electricity.

NONRESIDENTIAL: All buildings and spaces in the Uniform Building Code (UBC) occupancies other than Group R.

OCCUPANCY: See the Washington State Building Code.

OCCUPANCY SENSOR: A device that detects occupants within an area, causing any combination of lighting, equipment or appliances to be turned on or shut off.

OPAQUE ENVELOPE AREAS: All exposed areas of a building envelope which enclose conditioned space, except openings for doors, glazing and building service systems.

OPEN BLOWN: Loose fill insulation pneumatically installed in an unconfined attic space.

OUTDOOR AIR (OUTSIDE AIR): Air taken from the outdoors and, therefore, not previously circulated through a building.

OVERHEAD GLAZING: A glazing surface that has a slope of less than 60° from the horizontal plane.

PACKAGED TERMINAL AIR CONDITIONER: A factory-selected combination of heating and cooling components, assemblies or sections intended to serve a room or zone. (For the complete technical definition, see Standard RS-10.)

PERMEANCE (PERM): The ability of a material of specified thickness to transmit moisture in terms of amount of moisture transmitted per unit time for a specified area and differential pressure (grains per hour•ft²•inches of HG). Permeance may be measured using ASTM E-96-72 or other approved dry cup method as specified in Standard RS-1.

POOL COVER: A vapor-retardant cover which lies on or at the surface of the pool.

POWER: In connection with machines, the time rate of doing work. In connection with the transmission of energy of all types, the rate at which energy is transmitted; in customary units, it is measured in watts (W) or British Thermal Units per hour (Btu/h).

PROCESS ENERGY: Energy consumed in support of a manufacturing, industrial or commercial process other than the maintenance of building comfort or amenities for building occupants.

RADIANT FLOOR: A floor assembly, on grade or below, containing heated pipes, ducts or electric heating cables that constitute a floor or portion thereof for complete or partial heating of the structure.

READILY ACCESSIBLE: See the Washington State Mechanical Code.

RECOOLING: The removal of heat by sensible cooling of the supply air (directly or indirectly) that has been previously heated above the temperature to which the air is to be supplied to the conditioned space for proper control of the temperature of that space.

RECOVERED ENERGY: Energy utilized which would otherwise be wasted (i.e., not contribute to a desired end use) from an energy utilization system.

REHEAT: The application of sensible heat to supply air that has been previously cooled below the temperature of the conditioned space by either mechanical refrigeration or the introduction of outdoor air to provide cooling.

RENEWABLE ENERGY SOURCES: Renewable energy sources (excluding minerals) derived from: (1) incoming solar radiation, including but not limited to, natural daylighting and photosynthetic processes; (2) energy sources resulting from wind, waves and tides, lake or pond thermal differences; and (3) energy derived from the internal heat of the earth, including nocturnal thermal exchanges.

RESET: Adjustment of the set point of a control instrument to a higher or lower value automatically or manually to conserve energy.

ROOF/CEILING ASSEMBLY: (See Gross Roof/Ceiling Area.)

SEER - SEASONAL ENERGY EFFICIENCY RATIO: The total cooling output of an air conditioner during its normal annual usage period, in Btu's, divided by the total electric energy input in watt-hours, during the same period, as determined by 10 CFR, Part 430.

SEMI-HEATED SPACE: Sub-category of Heated Space. (See Heated Space.)

SEQUENCE: A consecutive series of operations.

SERVICE SYSTEMS: All energy-using systems in a building that are operated to provide services for the occupants or processes housed therein, including HVAC, service water heating, illumination, transportation, cooking or food preparation, laundering or similar functions.

SERVICE WATER HEATING: Supply of hot water for domestic or commercial purposes other than comfort heating.

SHADED: Glazed area which is externally protected from direct solar radiation by use of devices permanently affixed to the structure or by an adjacent building, topographical feature or vegetation.

SHADING COEFFICIENT: The ratio of solar heat gain occurring through nonopaque portions of the glazing, with or without integral shading devices, to the solar heat gain occurring through an equivalent area of unshaded, 1/8 inch thick, clear, double-strength glass.

Note: Heat gains to be compared under the same conditions. See Chapter 26 of Standard RS-27, listed in Chapter 17 of this Code.

SHALL: Denotes a mandatory Code requirement.

SKYLIGHT: (See Overhead Glazing.)

SLAB-BELOW-GRADE: Any portion of a slab floor in contact with the ground which is more than 24 inches below the final elevation of the nearest exterior grade.

SLAB-ON-GRADE, EXTERIOR: Any portion of a slab floor in contact with the ground which is less than or equal to 24 inches below the final elevation of the nearest exterior grade.

SOLAR ENERGY SOURCE: Source of natural daylighting and of thermal, chemical or electrical energy derived directly from conversion of incident solar radiation.

SOLAR HEAT GAIN COEFFICIENT (SIIGC): The ratio of the solar heat gain entering the space through the glazing product to the incident solar radiation. Solar heat gain includes directly transmitted solar heat and absorbed solar radiation which is then reradiated, conducted or convected into the space.

SPLIT SYSTEM: Any heat pump or air conditioning unit which is provided in more than one assembly requiring refrigeration piping installed in the field.

STANDARD FRAMING: All framing practices not defined as "intermediate" or "advanced" shall be considered standard. (See Section 2005.2 of this Code.)

SUBSTANTIAL CONTACT: A condition where adjacent building materials are placed in a manner that proximal surfaces are contiguous, being installed and supported as to eliminate voids between materials, without compressing or degrading the thermal performance of either product.

SYSTEM: A combination of central or terminal equipment or components and/or controls, accessories, interconnecting means and terminal devices by which energy is transformed so as to perform a specific function, such as HVAC, service water heating or illumination.

TAPERING: Installation of a reduced level of ceiling insulation at the eaves, due to reduced clearance.

THERMAL BY-PASS: An area where the envelope surrounding the conditioned space is breached, or where an ineffective application compromises the performance of a thermal or infiltration barrier, increasing the structure's energy consumption by exposing finished surfaces to ambient conditions and additional heat transfer.

THERMAL CONDUCTANCE (C): Time rate of heat flow through a body (frequently per unit area) from one of its bounding surfaces to the other for a unit temperature difference between the two surfaces, under steady conditions (Btu/h \cdot ft² \cdot °F).

THERMAL RESISTANCE (R): The reciprocal of thermal conductance $(h \cdot ft^2 \cdot {}^{\circ}F/Btu)$.

THERMAL TRANSMITTANCE (U): The coefficient of heat transmission (air to air). It is the time rate of heat flow per unit area and unit temperature difference between the warm side and cold side air films (Btu/h \cdot ft² \cdot °F).

116

THERMAL TRANSMITTANCE, OVERALL (U_0) : The overall (average) heat transmission of a gross area of the exterior building envelope (Btu/h • ft² • °F). The U₀-factor applies to the combined effect of the time rate of heat flows through the various parallel paths, such as glazing, doors and opaque construction areas, comprising the gross area of one or more exterior building components, such as walls, floors or roof/ceiling.

THERMOSTAT: An automatic control device actuated by temperature and designed to be responsive to temperature.

TOTAL ON-SITE ENERGY INPUT: The combination of all the energy inputs to all elements and accessories as included in the equipment components, including but not limited to, compressor(s), compressor sump heater(s), circulating pump(s), purge devices, fan(s) and the HVAC system component control circuit.

TRANSMISSION COEFFICIENT: The ratio of the solar heat gain through a glazing system to that of an unshaded single pane of double strength window glass under the same set of conditions.

U-FACTOR: (See Thermal Transmittance.)

U-VALUE: (See U-Factor.)

UNCONDITIONED SPACE: Space within a building that is not a conditioned space. (See Conditioned Space.)

UNIFORM BUILDING CODE (UBC): (See Washington State Uniform Building Code.)

UNIFORM MECHANICAL CODE (UMC): (See Washington State Uniform Mechanical Code.)

UNIFORM PLUMBING CODE (UPC): (See Washington State Uniform Plumbing Code.)

UNITARY COOLING AND HEATING EQUIPMENT: One or more factorymade assemblies which include an evaporator or cooling coil, a compressor and condenser combination and may include a heating function as well. Where such equipment is provided in more than one assembly, the separate assemblies shall be designed to be used together.

UNITARY HEAT PUMP: One or more factory-made assemblies which include an indoor conditioning coil, compressor(s) and outdoor coil or refrigerant-towater heat exchanger, including means to provide both heating and cooling functions. When such equipment is provided in more than one assembly, the separate assemblies shall be designed to be used together.

VAPOR RETARDER: A layer of low moisture transmissivity material (not more than 1.0 perm dry cup) placed over the warm side (in winter) of insulation, over the exterior of below grade walls, and under floors as ground cover to limit the transport of water and water vapor through exterior walls, ceilings and floors. Vapor retarding paint, listed for this application, also meets this definition.

VAULTED CEILINGS: All ceilings where enclosed joist or rafter space is formed by ceilings applied directly to the underside of roof joists or rafters.

VENTILATION: The process of supplying or removing air by natural or mechanical means to or from any space. Such air may or may not have been conditioned.

VENTILATION AIR: That portion of supply air which comes from outside (outdoors) plus any recirculated air that has been treated to maintain the desired quality of air within a designated space.

VERTICAL GLAZING: A glazing surface that has a slope of 60° or greater from the horizontal plane.

WALLS (EXTERIOR): Any member or group of members which defines the exterior boundaries or courts of a building and which have a slope of 60° or greater with the horizontal plane, and separates conditioned from unconditioned space. Band joists between floors are to be considered a part of exterior walls.

WASHINGTON STATE UNIFORM BUILDING CODE (UBC): The Uniform Building Code as modified by the Washington State Building Code Council.

WASHINGTON STATE UNIFORM MECHANICAL CODE (UMC): The Uniform Mechanical Code as modified by the Washington State Building Code Council.

WASHINGTON STATE UNIFORM PLUMBING CODE (UPC): The Uniform Plumbing Code as modified by the Washington State Building Code Council.

ZONE: A space or group of spaces within a building with heating and/or cooling requirements sufficiently similar so that comfort conditions can be maintained throughout by a single controlling device. Each dwelling unit in residential buildings shall be considered a single zone.

CHAPTER 13 BUILDING ENVELOPE

1301 Scope: Conditioned buildings or portions thereof shall be constructed to provide the required thermal performance of the various components according to the requirements of this chapter. Unless otherwise approved by the building official, all spaces shall be assumed to be at least semi-heated.

Exceptions:

- Greenhouses isolated from any conditioned space and not intended for occupancy.
- As approved by the building official, spaces not assumed to be at least semi-heated.
- Unconditioned Group M occupancy accessory to Group R occupancy.

1302 Space Heat Type: For the purpose of determining building envelope requirements, the following two categories comprise all space heating types:

Electric Resistance: Space heating systems which use electric resistance elements as the primary heating system including baseboard, radiant and forced air units where the total electric resistance heat capacity exceeds 1.0 W/ft² of the gross conditioned floor area.

Exception: Heat pumps and terminal electric resistance heating in variable air volume distribution systems.

Other: All other space heating systems including gas, solid fuel, oil and propane space heating systems and those systems listed in the exception to electric resistance.

1303 Climate Zones: All buildings shall comply with the requirements of the appropriate climate zone as defined herein.

- ZONE 1: Climate Zone 1 shall include all counties not included in Climate Zone 2.
- ZONE 2: Climate Zone 2 shall include: Adams, Chelan, Douglas, Ferry, Grant, Kittitas, Lincoln, Okanogan, Pend Oreille, Spokane, Stevens and Whitman counties.

SECTION 1310 – GENERAL REQUIREMENTS: The building envelope shall comply with Sections 1311 through 1314.

1310.1 Conditioned Spaces: The building envelope for conditioned spaces shall also comply with one of the following paths:

- a. Prescriptive Building Envelope Option Sections 1320 through 1323.
- Component Performance Building Envelope Option Sections 1330 through 1334.
- c. Systems Analysis. See Section 1141.4.

1310.2 Semi-Heated Spaces: All spaces shall be considered conditioned spaces, and shall comply with the requirements in Section 1310.1 unless they meet the following criteria for semi-heated spaces. The installed heating equipment output, in Climate Zone 1, shall be 3 Btu/($h \cdot ft^2$) or greater but not greater than 8 Btu/($h \cdot ft^2$) and in Climate Zone 2, shall be 5 Btu/($h \cdot ft^2$) or greater but not greater than 12 Btu/($h \cdot ft^2$). Heating shall be controlled by a thermostat mounted not lower than the heating unit and capable of preventing heating above 44° space temperature. For semi-heated spaces, the only prescriptive, component performance or systems analysis building envelope requirement shall be that:

Climate Zone 1

- a. U=0.10 maximum for the roof assembly, or
- b. continuous R-9 insulation installed entirely outside of the roof structure, or
- c. R-11 insulation installed inside or within a wood roof structure, or
- d. R-19 insulation installed inside or within a metal roof structure.

Climate Zone 2

- a. U=0.07 maximum for the roof assembly, or
- continuous R-14 insulation installed entirely outside of the roof structure, or
- c. R-19 insulation installed inside or within a wood roof structure, or
- d. R-25 insulation installed inside or within a metal roof structure.

Section Number	Subject	Prescriptive Option	Component Performance Option	Systems Analysis Option
1310	General Requirements	X	X	Х
1311	Insulation	x	X	х
1312	Glazing and Doors	x	x	X
1313	Moisture Control	X	X	х
1314	Air Leakage	x	X	Х
1320	Prescriptive Building Envelope Option	X		
1321	General	х		
1322	Opaque Envelope	x		
1323	Glazing	X		
1330	Component Performance Building		5	
	Envelope Option		X	
1331	General		X	
1332	Component U-Factors		X	
1333	UA Calculations		X	
1334	Solar Heat Gain Coefficient		X	-
RS-29	Systems Analysis			X

Figure 13A Building Envelope Compliance Options

1311 Insulation

1311.1 Installation Requirements: All insulation materials shall be installed according to the manufacturer's instructions to achieve proper densities, maintain clearances and maintain uniform R-values. To the maximum extent possible, insulation shall extend over the full component area to the intended R-value.

1311.2 Roof/Ceiling Insulation: Open-blown or poured loose-fill insulation may be used in attic spaces where the slope of the ceiling is not more than 3/12 and there is at least 30 inches of clear distance from the top of the bottom chord of the truss or ceiling joist to the underside of the sheathing at the roof ridge. When eave vents are installed, baffling of the vent openings shall be provided so as to deflect the incoming air above the surface of the insulation.

Where lighting fixtures are recessed into a suspended or exposed grid ceiling, the roof/ceiling assembly shall be insulated in a location other than directly on the suspended ceiling.

Exception: Type IC rated recessed lighting fixtures.

Where installed in wood framing, faced batt insulation shall be face stapled.

1311.3 Wall Insulation: Exterior wall cavities isolated during framing shall be fully insulated to the levels of the surrounding walls. When installed in wood framing, faced batt insulation shall be face stapled.

Above grade exterior insulation shall be protected.

1311.4 Floor Insulation: Floor insulation shall be installed in a permanent manner in substantial contact with the surface being insulated. Insulation supports shall be installed so spacing is not more than 24 inches on center. Installed insulation shall not block the airflow through foundation vents.

1311.5 Slab-On-Grade Floor: Slab-on-grade insulation installed inside the foundation wall shall extend downward from the top of the slab a minimum distance of 24 inches or to the top of the footing, whichever is less. Insulation installed outside the foundation shall extend downward a minimum of 24 inches or to the frostline, whichever is greater. Above grade insulation shall be protected.

Exception: For monolithic slabs, the insulation shall extend downward from the top of the slab to the bottom of the footing.

1311.6 Radiant Floors (on or below grade): Slab-on-grade insulation shall extend downward from the top of the slab a minimum distance of 36 inches or downward to the top of the footing and horizontal for an aggregate of not less than 36 inches.

If required by the building official where soil conditions warrant such insulation, the entire area of a radiant floor shall be thermally isolated from the soil. Where a soil gas control system is provided below the radiant floor, which results in increased convective flow below the radiant floor, the radiant floor shall be thermally isolated from the sub-floor gravel layer.

1312 Glazing and Doors

1312.1 Standard Procedure for Determination of Glazing and Door U-Factors: U-factors for glazing and doors shall be determined, certified and labeled in accordance with Standard RS-31 by a certified independent agency licensed by the National Fenestration Rating Council (NFRC). Compliance shall be based on Model Size AA or BB. Product samples used for U-factor determinations shall be production line units or representative of units as purchased by the consumer or contractor. Unlabeled glazing and doors shall be assigned the default U-factor in Section 2006.

1312.2 Solar Heat Gain Coefficient and Shading Coefficient: Solar Heat Gain Coefficient (SHGC), shall be determined, certified and labeled in accordance with the National Fenestration Rating Council (NFRC) Standard by a certified, independent agency, licensed by the NFRC.

Exception: Shading coefficients (SC) shall be an acceptable alternate for compliance with solar heat gain coefficient requirements. Shading coefficients for glazing shall be taken from Chapter 27 of Standard RS-27 or from the manufacturer's test data.

1313 Moisture Control

1313.1 Vapor Retarders: Vapor retarders shall be installed on the warm side (in winter) of insulation as required by this section.

Exception: Vapor retarder installed with not more than 1/3 of the nominal R-value between it and the conditioned space.

1313.2 Roof/Ceiling Assemblies: Roof/Ceiling assemblies where the ventilation space above the insulation is less than an average of 12 inches shall be provided with a vapor retarder. Roof/ceiling assemblies without a vented airspace, where neither the roof deck nor the roof structure are made of wood, shall provide a continuous vapor retarder with taped seams.

Exception: Vapor retarders need not be provided where all of the insulation is installed between the roof membrane and the structural roof deck.

1313.3 Walls: Walls separating conditioned space from unconditioned space shall be provided with a vapor retarder.

1313.4 Floors: Floors separating conditioned space from unconditioned space shall be provided with a vapor retarder.

1313.5 Crawl Spaces: A ground cover of six mil (0.006 inch thick) black polyethylene or approved equal shall be laid over the ground within crawl spaces. The ground cover shall be overlapped 12 inches minimum at the joints and shall extend to the foundation wall.

Exception: The ground cover may be omitted in crawl spaces if the crawl space has a concrete slab floor with a minimum thickness of 3-1/2 inches.

1314 Air Leakage

1314.1 Building Envelope: The requirements of this section shall apply to building elements separating conditioned from unconditioned spaces. Exterior joints around windows and door frames, openings between walls and foundation, between walls and roof and wall panels; openings at penetrations of utility services through walls, floors and roofs; and all other openings in the building envelope shall be sealed, caulked, gasketed or weatherstripped to limit air leakage.

1314.2 Glazing and Doors: Doors and operable glazing separating conditioned from unconditioned space shall be weatherstripped. Fixed windows shall be tight fitting with glass retained by stops with sealant or caulking all around.

Exception: Openings that are required to be fire resistant.

1314.3 Building Assemblies Used as Ducts or Plenums: Building assemblies used as ducts or plenums shall be sealed, caulked and gasketed to limit air leakage.

SECTION 1320 - PRESCRIPTIVE BUILDING ENVELOPE OPTION

1321 General: This section establishes building envelope design criteria in terms of prescribed requirements for building construction.

1322 Opaque Envelope: Roof/ceilings, opaque exterior walls, opaque doors, floors over unconditioned space, below grade walls, slab on grade floors and radiant floors enclosing conditioned spaces shall be insulated according to Section 1311 and Tables 13-1 or 13-2. Compliance with nominal R-values shall be demonstrated for the thermal resistance of the added insulation in framing cavities and/or insulated sheathing only. Nominal R-values shall not include the thermal transmittance of other building materials or air films.

Exceptions:

- Opaque smoke vents are not required to meet insulation requirements.
- The perimeter edge of an above grade floor slab which penetrates the exterior wall may be left uninsulated provided that the wall insulation is increased by R-2 above that required in Tables 13-1 and 13-2.

1323 Glazing: Glazing shall comply with Section 1312 and Tables 13-1 or 13-2. All glazing shall be, at a minimum, double glazing.

Exceptions:

- Vertical glazing located on the street level story of a retail occupancy provided the glazing is double-glazed with a minimum 1/2 inch airspace and does not exceed 75% of the gross exterior wall area of the street level story which does not exceed 20 feet in height. When this exception is utilized, separate calculations shall be performed for these sections of the building envelope and these values shall not be averaged with any others for compliance purposes. The 75% area may be exceeded on the street level, if the additional glass area is provided from allowances from other areas of the building.
- Single glazing for ornamental, security or architectural purposes shall be included in the percentage of the total glazing area, U-factor calculation and SHGC as allowed in the Tables 13-1 or 13-2. The maximum area allowed for the total of all single glazing is 1% of the gross exterior wall area.

1323.1 Area: The percentage of total glazing (vertical and overhead) area relative to the gross exterior wall area shall not be greater than the appropriate value from Tables 13-1 or 13-2 for the vertical glazing U-factor, overhead glazing U-factor and solar heat gain coefficient selected.

1323.2 U-Factor: The area-weighted average U-factor of vertical glazing shall not be greater than that specified in Tables 13-1 or 13-2 for the appropriate area and solar heat gain coefficient. The area-weighted average U-factor of overhead glazing shall not be greater than that specified in Tables 13-1 or 13-2 for the appropriate area and solar heat gain coefficient. U-factors for glazing shall be determined in accordance with Section 1312.

1323.3 Solar Heat Gain Coefficient: The area-weighted average solar heat gain coefficient of vertical glazing shall not be greater than that specified in Tables 13-1 or 13-2 for the appropriate area and U-factor. The area-weighted average solar heat gain coefficient of overhead glazing shall not be greater than that specified in Tables 13-1 or 13-2 for the appropriate area and U-factor.

SECTION 1330 - COMPONENT PERFORMANCE BUILDING ENVELOPE OPTION

1331 General: Buildings or structures whose design heat loss rate (UA_p) and solar heat gain coefficient $(SHGC_p)$ are less than or equal to the target heat loss rate (UA_t) and solar heat gain coefficient $(SHGC_t)$ shall be considered in compliance with this section. The stated U-factor, F-factor or allowable area of any component assembly, listed in Tables 13-1 or 13-2, such as roof/ceiling, opaque wall, opaque door, glazing, floor over conditioned space, slab on grade floor, radiant floor or opaque floor may be increased and the U-factor or F-factor for other components decreased, provided that the total heat gain or loss for the entire building envelope does not exceed the total resulting from compliance to the U-factors, F-factors or allowable areas specified in this section.

Exception: For buildings or structures utilizing the other space heat type (including heat pumps and VAV) compliance path, for the gross opaque wall, opaque door and glazing (vertical and overhead) area only, compliance may also be shown using the ENVSTD diskette version 2.1 or later of Standard RS-9 with the following additional requirements:

- Only the Exterior Wall Requirements portion of the ENVSTD computer program may be used under this exception.
- Overhead glazing shall be added to vertical glazing, and shall be input as 1/4 north, 1/4 east, 1/4 south and 1/4 west facing.
- 3. Lighting loads shall be determined according to Table 15-1.
- Equipment loads shall be determined from Table 3-1 of Standard RS-29.

1332 Component U-Factors: The U-factors for typical construction assemblies are included in Chapter 20. These values shall be used for all calculations. Where proposed construction assemblies are not represented in Chapter 20, values shall be calculated in accordance with Chapters 19-27 in Standard RS-27 listed in Chapter 17, using the framing factors listed in Chapter 20. For envelope assemblies containing metal framing, the U-factor shall be determined by one of the following methods:

- Results of laboratory measurements according to acceptable methods of test.
- Standard RS-25, listed in Chapter 17, where the metal framing is bonded on one or both sides to a metal skin or covering.
- The zone method as provided in Chapter 22 of Standard RS-27, listed in Chapter 17.
- 4. Effective framing/cavity R-values as provided in Table 20-5A.

When return air ceiling plenums are employed, the roof/ceiling assembly shall:

- a. For thermal transmittance purposes, not include the ceiling proper nor the plenum space as part of the assembly; and
- For gross area purposes, be based upon the interior face of the upper plenum surface.

1333 UA Calculations: The target UA_t and the proposed UA_p shall be calculated using Equations 13-1 and 13-2 and the corresponding areas and U-factors from Table 13-1 or 13-2. For the target UA_t calculation, the overhead glazing shall be located in roof/ceiling area and the remainder of the glazing allowed per Table 13-1 or 13-2 shall be located in the wall area.

1334 Solar Heat Gain Coefficient: Solar heat gain coefficient shall comply with Section 1323.3
EQUATION 13-1:

Target UA_t

- $\begin{array}{l} UA_t = U_{rat}A_{rat} + U_{ograt}A_{ograt} + U_{ort}A_{ort} + U_{ogort}A_{ogort} + U_{wt}A_{wt} + U_{vgt}A_{vgt} \\ + U_{dt}A_{dt} + U_{ft}A_{ft} + F_{st}P_{st} + U_{bgwt}A_{bgwt} \end{array}$
- UA_t = The target combined specific heat transfer of the gross roof/ceiling assembly, exterior wall and floor area.

Where:

- Urat = The thermal transmittance value for roofs over attics found in Table 13-1 or 13- 2.
- Uograt = The thermal transmittance for overhead glazing found in Table 13-1 or 13-2 which corresponds to the proposed total glazing area as a percent of gross exterior wall area.
- U_{ort} = The thermal transmittance value for other roofs found in Table 13-1 or 13-2.
- Uogort = The thermal transmittance for overhead glazing found in Table 13-1 or 13-2 which corresponds to the proposed total glazing area as a percent of gross exterior wall area.
- U_{wt} = The thermal transmittance value for opaque walls found in Table 13-1 or 13-2.
- Uvgt = The thermal transmittance value for vertical glazing found in Table 13-1 or 13-2 which corresponds to the proposed total glazing area as a percent of gross exterior wall area.
- U_{dt} = The thermal transmittance value for opaque doors found in Table 13-1 or 13-2.
- Uft = The thermal transmittance value for floors over unconditioned space found in Table 13-1 or 13-2.
- F_{st} = The F-factor for slab-on-grade and radiant slab floors found in Table 13-1 or 13-2.
- Ubgwt = The thermal transmittance value for opaque walls found in Table 13-1 or 13-2.
- A_{dt} = The proposed opaque door area, A_{d} .
- Aft = The proposed floor over unconditioned space area, Af.
- P_{st} = The proposed lineal feet of slab-on-grade and radiant slab floor perimeter, P_s.

Abgwt = The proposed below grade wall area, Abgw. and;

if the total amount of glazing area as a percent of gross exterior wall area does not exceed the maximum allowed in Table 13-1 or 13-2:

- Arat = The proposed roof over attic area, Ara.
- Aograt = The proposed overhead glazing area in roofs over attics, Aogra.
- Aort = The proposed other roof area, Aor.
- Aogort = The proposed overhead glazing area in other roofs, Aogor.
- A_{wt} = The proposed opaque above grade wall area, A_{w} .

Avgt = The proposed vertical glazing area, Avg.

or;

if the total amount of glazing area as a percent of gross exterior wall area exceeds the maximum allowed in Table 13-1 or 13-2:

Arat = The greater of: the proposed roof over attic area, and the gross roof over attic area minus Aograt.

Aograt = The lesser of:

proposed overhead glazing area in roofs over attics, and the maximum allowed glazing area from Table 13-1 or 13-2.

Aort = The greater of: the proposed other roof area, and the gross other roof area minus Aogort.

Aogort = The lesser of: the proposed overhead glazing area in other roofs, and the maximum allowed glazing area from Table 13-1 or 13-2 minus Aograt

Awt = The greater of: proposed opaque above grade wall area, and the gross exterior above grade wall area minus Adt minus Avet.

Avgt = The lesser of: the proposed vertical glazing area, and the maximum allowed glazing area from Table 13-1 or 13-2 minus Aograt minus Aogort.

EQUATION 13-2

Proposed UAp

.

•

UAp = Uri	Ara+UorAor+UogAog+	UwAw+UdAd+Uv	gAvg+UfAf+rg	Ps+UbgwAbgw
When	re:			

UAp	-	exterior wall, floor and roof/ceiling assembly area.
U _{ra} A _{ra}		The thermal transmittance of the roof over attic area. Opaque roof over attic area.
Uor Aor	-	The thermal transmittance of the other roof area. Opaque other roof area.
U _{og} A _{og}	1 1	The thermal transmittance for the overhead glazing Overhead glazing area.
U _W A _W	11 11	The thermal transmittance of the opaque wall area. Opaque above grade wall area (not including opaque doors).
Uvg Avg	= =	The thermal transmittance of the vertical glazing area. Vertical glazing area.
Ud Ad		The thermal transmittance value of the opaque door area. Opaque door area.
Uf	=	The thermal transmittance of the floor over unconditioned space area.
Af	=	Floor area over unconditioned space.
Fs Ps	=	Slab-on-grade or radiant floor component F-factor. Lineal feet of slab-on-grade or radiant floor perimeter.
Ubgw Abgw	=	The thermal transmittance value of the below grade wall area. Below grade wall area as defined in Tables 13-1 or 13-2.

NOTE: Where more than one type of wall, window, roof/ceiling, door and skylight is used, the U and A terms for those items shall be expanded into subelements as:

 $U_{w1}A_{w1} + U_{w2}A_{w2} + U_{w3}A_{w3} + \dots etc.$

TABLE 13-1 BUILDING ENVELOPE REQUIREMENTS FOR CLIMATE ZONE 1

MINIMUM INSULATION R-VALUES OR MAXIMUM COMPONENT U-FACTORS FOR ZONE 1

Building Components

Space Heat Type	Cor	mponents				
	Roofs Over Attic	All Other Roofs	Opaque Walis ¹ ,2	Opaque Doors	Floor Over Uncond Space	Slab On Grade ⁵
1. Electric resistance heat	R-38 or U=0.031	R-30 or U=0.034	R-19 or U = 0.062 ³	U=0.60	R-30 or U = 0.029	R-10 or F=0.54
2. All others including Heat pumps and VAV	R-30 or U=0.036	R-21 or U=0.050	R-11 or U = 0.14	U=0.60	R-19 or U=0.056	R-10 or F=0.54

MAXIMUM GLAZING AREAS AND U-FACTORS AND MAXIMUM GLAZING SOLAR HEAT GAIN COEFFICIENTS FOR ZONE 1

Glazing

Children P	-			-						-	-	
Maximum Glazing Area as % of Wall	0% to 15%			>15% to 20%			>2	0% to	30%	> 30% to 40%		
	Maxin U-Fac	esatas Intr	Max. SHGC ⁴	Maxie U-Fac	aum tor	Max. SHGC ⁴	Maxin U-Fac	ium for	Max. SHGC ⁴	Maxin U-Fac	tor	Max. SHGC ⁴
	VG	OG	2 +	VG	OG		VG	OG		VG	OG	-
1. Electric resistance heat	0.40	0.80	1.0	0.40	0.80	1.0	PRES	CRIPTI	VE PATH	NOT	ALLOW	ED
2. All others including Heat pumps and VAV	0.90	1.45	1.0	0.75	1,40	1.0	0.60	1.30	0.65	0.50	1.25	0.45

Footnotes

- 1. Below Grade Walls: Below grade walls shall be insulated either on the interior or the exterior. Below grade walls insulated on the exterior shall use a minimum of R-10 insulation. Below grade walls insulated on the interior shall use opaque wall values. No insulation is required for those portions of below grade walls and footings that are more than 10 feet below grade. Below grade walls, however, shall not be included in the gross exterior wall are unless insulated to the levels given above.
- 2. Concrete Masonry Walls: If the area weighted heat capacity of the total opaque above grade wall is a minimum of 9.0 Btu/fi² * °F, then the U-factor may be increased to 0.19 for interior insulation and 0.25 for integral and exterior insulation for insulation position as defined in Chapter 12. Individual walls with heat capacities less than 9.0 Btu/fi² * °F and below grade walls shall meet opague wall requirements listed above. Glazing shall comply with the following:

Maximum Glazing Area as % of Wall	0 to 10 %			>10 to 15 %			>	15% 10	20 %	>20% to 25 %		
	Masia U-Fact	11160 CF	Max. SHGC ⁴	Maxin U-Fact	uun lor	Max. SHGC ⁴	Maxin U-Fuct	ium lor	Max. SHGC ⁴	Maxin U-Fart	enne Linz	Max. SHGC ⁴
	VG	OG		VG	00		VG.	OG		VG	OG	
1. Electric resistance heat	0.40	0.80	1.0	0,40	0.80	1.0	0,40	0.80	1.0	NO	TALL	OWED
2. All others including Heat pumps and VAV	0.90	1.45	1.0	0.75	1.40	1.0	0.65	1,30	0.80	0.60	1.30	0.65

3. Metal Stud Walls: For metal stud construction U=0.11.

- SHGC (Solar Heat Gain Coefficient per Section 1312.2): May substitute Maximum Shading Coefficient (SC) for SHGC (See Section 1210 for definition of Shading Coefficient).
- 5. Radiant Floors: Where insulation is required under the entire slab, radiant floors shall use a minimum of R-10 insulation or F=0.55 maximum. Where insulation is not required under the entire slab, radiant floors shall use R-10 perimeter insulation according to Section 1311.6 or F=0.78 maximum.



TABLE 13-2 BUILDING ENVELOPE REQUIREMENTS FOR CLIMATE ZONE 2

MINIMUM INSULATION R-VALUES OR MAXIMUM COMPONENT U-FACTORS FOR ZONE 2

Building Components

Space Heat Type	Co	nponents							
	Roofs Over Attic	All Other Roofs	Opaque Walls1,2	Opaque Doors	Floor Over Uncond Space	Slab On Grade			
1. Electric resistance heat	R-38 or U=0.031	R-30 or U=0.034	R-24 or U=0.044 ³	U=0.60	R-30 or U=0.029	R-10 or F=0.54			
2. All others including Heat pumps and VAV	R-38 or U=0.031	R-25 or U=0.040	R-19 or U=0.11	U=0.60	R-21 or U=0.047	R-10 or F=0.54			

MAXIMUM GLAZING AREAS AND U-FACTORS AND MAXIMUM GLAZING SOLAR HEAT GAIN COEFFICIENTS FOR ZONE 2

Glazing

Maximum Glazing Area as % of Wall	0	% to 1	15%	>1	5% 10	20%	>2	0% 10	25%	>2	5% 10	30%
	Maxin U-Fac	tor.	Max. SHGC ⁴	Maxin U-Fac	tor	Max. SHGC ⁴	Maxin U-Fac	aum Ior	Max. SHGC ⁴	Maxia U-Fac	auns for	Max. SIIGC ⁴
	VG	OG		VG	OG		VG	OG		VG	OG	
1. Electric resistance heat	0.40	0.80	1.0	0.40	0,80	1.0	PRES	CRIPTI	VE PATH	NOT	LLOW	CO
2. All others including Heat pumps and VAV	0.90	1.45	1.0	0.75	1.40	1.0	0.60	1.30	0.60	0.50	1.25	0.50

Footnotes

- 1. Below Grade Walls: Below grade walls shall be insulated either on the interior or the exterior. Below grade walls insulated on the exterior shall use a minimum of R-12 insulation. Below grade walls insulated on the interior shall use opaque wall values. No insulation is required for those portions of below grade walls and footings that are more than 10 feet below grade. Below grade walls, however, shall not be included in the gross exterior wall are unless insulated to the levels given above.
- 2. Concrete Masonry Walls: If the area weighted heat capacity of the total opaque above grade wall is a minimum of 9.0 $Btu/ft^2 \cdot {}^\circ F$, then the U-factor may be increased to 0.19 for interior insulation and 0.25 for integral and exterior insulation for insulation position as defined in Chapter 12. Individual walls with heat capacities less than 9.0 $Btu/ft^2 \cdot {}^\circ F$ and below grade walls shall meet opague wall requirements listed above. Glazing shall comply with the following:

Maximum Glazing Area as % of Wall	0 to 5 %			>5 to 7 %			>7% to 10 %			>10% to 15%		
	Maxim U-Fact	or	Max, SHGC ⁴	Maxin U-Fac	aum loc	Mus. SHGC ⁴	Maxia U-Fact	1017	Max. SHGC ⁴	Maxia U-Fact	or	Max. SHGC ⁴
	VG	OG		VG	OG		VG	DO		VG	OG	
1. Electric resistance heat	0.40	0.80	1.0	0.40	0.80	1.0	0.40	0.80	1.0	NO	TALL	OWED
2. All others including Heat pumps and VAV	0.90	1.45	1.0	0.60	1.30	0.70	0.50	1.25	0.50	0.40	0.80	0.40

3. Metal Stud Walls: For metal stud construction U=0.10.

 SHGC (Solar Heat Gain Coefficient per Section 1312.2): May substitute Maximum Shading Coefficient (SC) for SHGC (See Section 1210 for definition of Shading Coefficient).

5. Radiant Floors: Where insulation is required under the entire slab, radiant floors shall use a minimum of R-10 insulation or F=0.55 maximum. Where insulation is not required under the entire slab, radiant floors shall use R-10 perimeter insulation according to Section 1311.6 or F=0.78 maximum.





x

CHAPTER 14 BUILDING MECHANICAL SYSTEMS

1401 Scope: This section covers the determination of requirements, system and component performance, control requirements and duct construction.

Exception: Special applications, including but not limited to hospitals, laboratories, thermally sensitive equipment and rooms designed to comply with the special construction and fire protection requirements of NFPA 75, "Standard for the Protection of Electronic Computer/Data Processing Equipment" may be exempt from the requirements of this section when approved by the building official. Exemptions shall be specific on a case-by-case basis and allowed only to the extent necessary to accommodate the special applications.

1402 Mechanical Ventilation: The minimum requirements for ventilation shall comply with the Washington State Ventilation and Indoor Air Quality Code (WAC 51-13).

SECTION 1410 -- GENERAL REQUIREMENTS: The building mechanical system shall comply with Sections 1411 through 1415, Sections 1440 through 1442 and Sections 1450 through 1454, and with one of the following paths:

- Simple Systems (Packaged Unitary Equipment) Sections 1420 through 1424.
- b. Complex Systems Sections 1430 through 1438.
- c. Systems Analysis. See Section 1141.4.

	Figure	14A	
Mechanical	Systems	Compliance	Paths

Section Number	Subject	Simple Systems Path	Complex Systems Path	Systems Analysis Option
1410	General Requirements	X	X	Х
1411	HVAC Equipment Performance Requirements	X	X	х
1412	Controls	X	X	X
1413	Air Economizers	X	X	X
1414	Ducting Systems	X	X	Х
1415	Piping Systems	X	X	Х
1420	Simple Systems (Packaged Unitary Equipment)	X		
1421	System Type	X		
1422	Controls	X		
1423	Economizers	X		
1424	Separate Air Distribution Systems	X		
1430	Complex Systems		X	
1431	System Type		X	
1432	Controls		X	
1433	Economizers		X	
1434	Separate Air Distribution Systems		X	
1435	Simultaneous Heating and Cooling		X	
1436	Heat Recovery		X	
1437	Electric Motor Efficiency		x	
1438	Variable Flow Systems		X	
RS-29	Systems Analysis			X
1440	Service Water Heating	X	X	X
1441	Water Heater Installation -	X	X	X
1442	Shut Off Controls	X	X	X
1450	Heated Pools	X	X	X
1451	General	X	X	X
1452	Pool Water Heaters	X	X	X
1453	Controls	X	X	X
1454	Pool Covers	X	X	X

ï

1411 IIVAC Equipment Performance Requirements

1411.1 General: Equipment shall have a minimum performance at the specified rating conditions not less than the values shown in Tables 14-1 through 14-3.

1411.2 Rating Conditions: Cooling equipment shall be rated at ARI test conditions and procedures when available. Where no applicable procedures exist, data shall be furnished by the equipment manufacturer.

1411.3 Combination Space and Service Water Heating: Equipment whose listed principal function is service water heating and which is used to provide additional functions (e.g., space heating) as part of a combination system, shall comply with minimum performance requirements for the principal function category.

1411.4 Packaged Electric Heating and Cooling Equipment: Packaged electric equipment providing both heating and cooling with a total cooling capacity greater than 20,000 Btu/h shall be a heat pump.

1412 Controls

1412.1 Temperature Controls: Each system shall be provided with at least one temperature control device. Each zone shall be controlled by individual thermostatic controls responding to temperature within the zone. At a minimum, each floor of a building shall be considered as a separate zone.

1412.2 Deadband Controls: When used to control both comfort heating and cooling, zone thermostatic controls shall be capable of a deadband of at least 5 °F within which the supply of heating and cooling energy to the zone is shut off or reduced to a minimum.

Exceptions:

- Special occupancy, special usage or code requirements where deadband controls are not appropriate.
- Buildings complying with Section 1141.4, if in the proposed building energy analysis, heating and cooling thermostat setpoints are set to the same temperature between 70°F and 75°F inclusive, and assumed to be constant throughout the year.
- Thermostats that require manual changeover between heating and cooling modes.

1412.3 Humidity Controls: If a system is equipped with a means for adding moisture, a humidistat shall be provided.

1412.4 Setback and Shut-Off: HVAC systems shall be equipped with automatic controls capable of accomplishing a reduction of energy use through control setback or equipment shutdown during periods of non-use or alternate use of the spaces served by the system. The automatic controls shall have a minimum seven-day clock and be capable of being set for seven different day types per week.

Exceptions:

- Systems serving areas which require continuous operation at the same temperature setpoint.
- Equipment with full load demands of 2 kW (6,826 Btu/h) or less may be controlled by readily accessible manual off-hour controls.

1412.4.1 Dampers: Outside air intakes, exhaust outlets and relief outlets serving conditioned spaces shall be equipped with dampers which close automatically when the system is off or upon power failure. Stair shaft and elevator shaft smoke relief openings shall be equipped with normally open dampers. These dampers shall remain closed in normal operation until activated by the fire alarm system or other approved smoke detection system.

Exceptions:

- 1. Systems serving areas which require continuous operation.
- 2. Combustion air intakes.

1412.5 Heat Pump Controls: Unitary air cooled heat pumps shall include microprocessor controls that minimize supplemental heat usage during start-up, set-up and defrost conditions. These controls shall anticipate need for heat and use compression heating as the first stage of heat. Controls shall indicate when supplemental heating is being used through visual means (e.g., LED indicators).

1412.6 Combustion Heating Equipment Controls: Combustion heating equipment with a capacity over 225,000 Btu/h shall have modulating or staged combustion control.

Exceptions:

- 1. Boilers.
- 2. Radiant Heaters.

1412.7 Balancing: Each air supply outlet or air or water terminal device shall have a means for balancing, including but not limited to, dampers, temperature and pressure test connections and balancing valves.

1413 Air Economizers

1413.1 Operation: Air economizers shall be of automatically modulating outside and return air dampers to provide 100% of the design supply air as outside air to reduce or eliminate the need for mechanical cooling.

1413.2 Control: Air economizers shall be controlled by a control system capable of determining if outside air can meet part or all of the building's cooling loads.

1413.3 Integrated Operation - Building Heating Energy: Air economizers shall be capable of providing partial cooling even when additional mechanical cooling is required to meet the remainder of the cooling load. Controls shall not preclude the economizer operation when mechanical cooling is required simultaneously.

Exception: Economizers on individual, direct expansion, cooling systems with capacities not greater than 75,000 Btu/h may include controls that limit simultaneous operation of the economizer and mechanical cooling for the purpose of preventing ice formation on cooling coils.

1414 Ducting Systems

1414.1 Sealing: Duct work which is designed to operate at pressures above 1/2 inch water column static pressure shall be sealed in accordance with Standard RS-18. Extent of sealing required is as follows:

- 1. Static pressure: 1/2 inch to 2 inches; seal transverse joints.
- Static pressure: 2 inches to 3 inches; seal all transverse joints and longitudinal seams.
- Static pressure: above 3 inches; seal all transverse joints, longitudinal seams and duct wall penetrations.

1414.2 Insulation: Ducts and plenums that

are constructed as part of the building envelope shall meet the requirements of Chapter 13. Other ducts and plenums shall be thermally insulated per Table 14-5.

Exceptions:

- 1. Within the HVAC equipment.
- 2. Exhaust air ducts not subject to condensation.
- 3. Exposed ductwork within a space that serves that space only.

1415 Piping Systems

1415.1 Insulation: Piping shall be thermally insulated in accordance with Table 14-6.

Exception: Piping installed within unitary HVAC equipment.

Water pipes outside the conditioned space shall be insulated in accordance with Washington State Plumbing Code (WAC 51-26)

SECTION 1420 -- SIMPLE SYSTEMS (Packaged Unitary Equipment)

1421 System Type: To qualify as a simple system, systems shall be one of the following:

- Air cooled, constant volume packaged equipment, which provide heating, cooling or both, and require only external connection to duct work and energy services.
- Air cooled, constant volume split systems, which provide heating, cooling or both, with cooling capacity of 54,000 Btu/h or less.
- c. Heating only systems which have a capacity of less than 5,000 cfm or which have a minimum outside air supply of less than 70% of the total air circulation.

All other systems shall comply with Sections 1430 through 1438.

1422 Controls: In addition to the control requirements in Section 1412, where separate heating and cooling equipment serve the same temperature zone, thermostats shall be interlocked to prevent simultaneous heating and cooling.

1423 Economizers: Economizers meeting the requirements of Section 1413 shall be installed on packaged roof top fan-cooling units having a supply capacity of greater than 1,900 cfm or a total cooling capacity greater than 54,000 Btu/h.

The total capacity of all units without economizers shall not exceed 240,000 Btu/h per building.

1424 Separate Air Distribution Systems: Zones with special process temperature requirements and/or humidity requirements shall be served by separate air distribution systems from those serving zones requiring only comfort conditions.

SECTION 1430 -- COMPLEX SYSTEMS

1431 System Type: All systems not qualifying for Sections 1420 through 1424 (Simple Systems), including field fabricated and constructed of system components, shall comply with Sections 1430 through 1438. Simple systems may also comply with Sections 1430 through 1438.

1431.1 Field-Assembled Equipment and Components: Field-assembled equipment and components from more than one manufacturer shall show compliance with this section and Section 1411 through calculations of total on-site energy input and output. The combined component efficiencies as measured per Section 1411.2, shall be in compliance with the requirements of Section 1411.1.

Total on-site energy input to the equipment shall be determined by combining the energy inputs to all components, elements and accessories such as compressor(s), internal circulating pump(s), purge devices, viscosity control heaters and controls.

138

1432 Controls

1432.1 Setback and Shut-Off: Systems that serve zones with different uses, as defined in Table 15-1,

- 1. shall be served by separate systems, or
- shall include isolation devices and controls to shut-off or set back the supply of heating and cooling to each zone independently.

Exception: Isolation or separate systems are not required for zones expected to operate continuously or expected to be inoperative only when all other zones are inoperative.

1432.2 Systems Temperature Reset Controls

1432.2.1 Air Systems for Multiple Zones: Systems supplying heated or cooled air to multiple zones shall include controls which automatically reset supply air temperatures by representative building loads or by outside air temperature. Temperature shall be reset by at least 25% of the design supply-air-to-room-air temperature difference.

Exception: Where specified humidity levels are required to satisfy process needs, such as computer rooms or museums.

1432.2.2 Hydronic Systems: Systems with a design capacity of 600,000 Btu/h or greater supplying heated water to comfort conditioning systems shall include controls which automatically reset supply water temperatures by representative building loads (including return water temperature) or by outside air temperature. Temperature shall be reset by at least 25% of the design supply-to-return water temperature differences.

1433 Economizers: Economizers meeting the requirements of Section 1413 shall be installed on the following systems:

- Packaged roof top fan-cooling units with a supply capacity of greater than 1,900 cfm or a total cooling capacity greater than 54,000 Btu/h.
- Other individual fan-cooling units with a supply capacity of greater than 2,800 cfm or a total cooling capacity greater than 84,000 Btu/h.

The total capacity of all units without economizers shall not exceed 240,000 Btu/h per building.

Exceptions:

 Systems with air or evaporatively cooled condensers and that either one of the following can be demonstrated to the satisfaction of the enforcing agency :

- Special outside air filtration and treatment, for the reduction and treatment of unusual outdoor contaminants, makes an air economizer infeasible.
- b. The use of outdoor air cooling affects the operation of other systems (such as humidification, dehumidification and supermarket refrigeration systems) so as to increase the overall building energy consumption.
- Systems for which at least 75% of the annual energy used for mechanical cooling is provided from site-recovery or site-solar energy source.
- 3. A water economizer system, which is capable of cooling supply air by indirect evaporation. Such a system shall be designed and capable of being controlled to provide 100% of the expected system cooling load at outside air temperatures of 50°F dry-bulb / 45°F wet-bulb and below. For this calculation, all factors including solar and internal load shall be the same as those used for peak load calculations, except for the outside air temperatures.

1434 Separate Air Distribution Systems: Zones with special process temperature requirements and/or humidity requirements shall be served by separate air distribution systems from those serving zones requiring only comfort conditions; or shall include supplementary control provisions so that the primary systems may be specifically controlled for comfort purposes only.

Exception: Zones requiring only comfort heating or comfort cooling that are served by a system primarily used for process temperature and humidity control provided that:

- The total supply air to those comfort zones is no more than 25% of the total system supply air, or
- 2. The total conditioned floor area of the zones is less than 1,000 ft2.

1435 Simultaneous Heating and Cooling: Systems which provide heating and cooling simultaneously to a zone are prohibited. Zone thermostatic and humidistatic controls shall be capable of operating in sequence the supply of heating and cooling energy to the zone. Such controls shall prevent:

- a. Reheating for temperature control.
- b. Recooling for temperature control.
- c. Mixing or simultaneous supply of air that has been previously mechanically heated and air that has been previously cooled, either by economizer systems, for all air in excess of that required by the Washington State Ventilation and Indoor Air Quality Code (WAC 51-13) or by mechanical refrigeration.
- Other simultaneous operation of heating and cooling systems to the same zone.

Exceptions:

- Variable air volume systems which have fan-powered terminal units on the perimeter zones controlled to utilize plenum heat prior to new energy being used for morning warm-up; and which, during periods of occupancy, are designed to reduce the air supply to each zone to a minimum before reheating, recooling or mixing takes place. The minimum volume of air from the main supply duct shall be no greater than the minimum required to meet ventilation requirements of the Washington State Ventilation and Indoor Air Quality Code (WAC 51-13).
- Zones having special pressurization relationships or crosscontamination requirements.
- Where at least 75% of the energy for reheating or for providing warm air in mixing systems is provided from a site-recovered or site-solar energy source.
- 4. Zones where specific humidity levels are required.
- 5. Zones with a peak supply air quantity of 300 cfm or less.

1436 Heat Recovery: Fan systems which have both a capacity of 5,000 cfm or greater and which have a minimum outside air supply of 70% or greater of the total air circulation shall have a heat recovery system with at least 50% recovery effectiveness. Fifty percent heat recovery effectiveness shall mean an increase in the outside air supply temperature at design heating conditions of one half the difference between the outdoor design air temperature and 65 °F. Provision shall be made to bypass or control the heat recovery system to permit air economizer operation as required by Section 1433. Heat recovery energy may be provided from any site-recovered or site-solar source.

Exceptions:

- Laboratory systems equipped with both variable air volume supply and variable air volume or two-speed exhaust fume hoods.
- 2. Systems serving spaces heated to less than 60 °F.
- Systems which can be shown to use as much energy with the addition of heat recovery equipment as without it.
- Systems exhausting toxic, flammable, paint exhaust or corrosive fumes making the installation of heat recovery equipment impractical.
- 5. Type I commercial kitchen hoods.

1437 Electric Motor Efficiency: Design A & B squirrel-cage, T-frame induction permanently wired polyphase motors of 1 hp or more having synchronous speeds of 3,600, 1,800 and 1,200 rpm shall have a nominal full-load motor efficiency no less than the corresponding values for energy efficient motors provided in Table 14-4.

Exceptions:

- Motors used in systems designed to use more than one speed of a multi-speed motor.-
- Motors used as a component of the equipment meeting the minimum equipment efficiency requirements of Section 1411 and Tables 14-1 and 14-2 provided that the motor input is included when determining the equipment efficiency.
- 3. Motors that are an integral part of specialized process equipment.
- Where the motor is integral to a listed piece of equipment for which no complying motor has been approved.

1438 Variable Flow Systems: For fans and pumps greater than 10 hp, where the application involves variable flow, there shall be variable frequency drives or variable flow devices installed. Acceptable variable flow devices include variable inlet vanes, variable blade pitch and variable fan geometry. Throttling valves (dampers), scroll dampers or bypass circuits shall not be allowed.

SECTION 1440 -- SERVICE WATER HEATING

1441 Water Heater Installation: Electric water heaters in unconditioned spaces or on concrete floors shall be placed on an incompressible, insulated surface with a minimum thermal resistance of R-10.

1442 Shut Off Controls: Systems designed to maintain usage temperatures in hot water pipes, such as circulating hot water systems or heat traced pipes shall be equipped with automatic time switches or other controls to turn off the system during periods of non-use.

SECTION 1450 -- HEATED POOLS

1451 General: The requirements in this section apply to "general and limited use pools" as defined in the Washington Water Recreation Facilities Regulations (WAC 246-260).

1452 Pool Water Heaters: Pool water heaters using electric resistance heating as the primary source of heat are prohibited for pools over 2,000 gallons.

1453 Controls: All pool heaters shall be equipped with a readily accessible ON/OFF switch to allow shutting off the operation of the heater without adjusting the thermostat setting. Controls shall be provided to allow the water temperature to be regulated from the maximum design temperature down to 65 °F.

1454 Pool Covers: Heated pools shall be equipped with a vapor retardant pool cover on or at the water surface. Pools heated to more than 90 °F shall have a pool cover with a minimum insulation value of R-12.

TABLE 14-1

Standard Rating Conditions and Minimum Performance for Air Cooled Unitary Air Conditioners, Heat Pumps, Packaged Terminal Air Conditioners, Warm Air Furnaces, Duct Furnaces and Unit Heaters

Equipment	Category	Sub-category &	Minimum	Rating	Standard
Type & Rating		Rating Conditions	Steady State	Seasonal or Part Load	
	<65,000 Btu/h	Split Systems	NA	10.0 SEER	ARI 210/240-
	Cooling Capacity	Single Package	NA	9.7 SEER	1989
Air Conditioners	>65,000 and <135,000 Btu/h	All Unitary	8.9 EER	8.3 IPLV	
and Heat Pumps	Cooling Capacity	Standard Ratings:	95°F db	80°F db	
Cooling	>135,000 and <760,000 Btu/h ¹	Air Conditioners	8.5 EER	7.5 IPLV	ARI 360-1986
Ratings	Cooling Capacity	Heat Pumps	8.5 EER	7.5 IPLV	
	> 760,000 Btu/h ¹ Cooling Canacity	Air Conditioners Heat Pumps	8.2 EER 8.7 EER	7.5 IPLV 7.5 IPLV	
Packaged Term. Air Conditioners & Heat Pumps Cooling Ratings	All Capacities	Air Conditioners and Heat Pumps Standard/Low Temp:	10.0 - (0.16 x Cap/1000) ³ EER 95°F	12.2 - (0.20 x Cap/1000) ^{2,3} EER 82°F	ARI 310-1990
<u> </u>	<65.000 Btu/h	Split Systems		6.8 HSPF	ARI 210/240-
	Cooling Capacity	Single Package		6.6 HSPF	1989
Heat Pump	>65,000 and <135,000 Btu/h	All Unitary	3.0 COP	2.0 COP	
Heating	Cooling Capacity	Standard Ratings:	47°F dh/43°F wh	17°F dh/15°F wb	
Ratings	> 135,000 Btu/h Cooling Capacity	Standard Ratings:	2.9 COP 47 °F	2.0 COP 17 °F	ARI 365-1986
Packaged Term. Heat Pumps Heating Ratings	All Capacities	Heat Pumps Standard Ratings:	2.9 - (0.026x 47°F db/	Cap/1000) ³ EER (43°F wh	ARI 380-1990
Warm Air	<225,000 Btu/h	Gas and Oil Fired Seasonal Ratings:	80% Et4	78% AFUE5	DOE 10CFR Part430 AppN
Furnaces & Combination	≥225,000 Btu/h	Gas, Max Rating ⁶ Gas, Min Rating ⁶	80% Et ⁴ 78% Et ⁴	NA NA	ANSI 221.47- 1983
Furnace/A.C.	≥225,000 Btu/h	Oil, Max Rating ⁶ Oil, Min Rating ⁶	81% E _L ⁴ 81% E _L ⁴	NA	UL 727-1986
Warm Air	All Size Gas Duct Furnaces	Max Rated Capacity6	78% Et ⁴	NA	ANSI Z83.9- 1986
Duct Furnaces	All Size Gas Unit Heaters	Max Rated Capacity6	78% Et ⁴	NA	ANSI 283.8- 1985
and Unit Heaters		Min Rated Capacity6	74% E14	NA	
	All Size Oil Unit Heaters	Max Rated Capacity6	81% Et ⁴	NA	UL 731-1988
	Manager and the second second	Min Rated Capacity6	81% Er4	NA	

1. For units that have a heating section, deduct 0.2 from all required EER's and IPLV's.

For multi-capacity equipment the minimum performance shall apply to each step provided Multicapacity refers to manufacturer published rating for more than one capacity mode allowed by the product's controls.

- 3. Capacity (Cap) means the rated cooling capacity of the product in Btu/h in accordance with the cited ARI standard. If the unit's capacity is less than 7,000 Btu/h, use 7,000 Btu/h in the calculation. If the unit's capacity is greater than 15,000 Btu/h, use 15,000 Btu/h in the calculation.
- These values apply to non-NAECA equipment. See referenced standard for definition of Thermal efficiency (Et), (100% - flue losses).
- To be consistent with National Appliance Energy Conservation Act (NAECA) of 1987 (Public Law 100-12). These values apply to furnace and combination units covered by NAECA.
- 6. Minimum and maximum ratings as provided for and allowed by the unit's controls.

TABLE 14-2

Standard Rating Conditions and Minimum Performance for Water and Evaporatively Cooled Unitary Air Conditioners, Heat Pumps, Water Source and Ground Source Heat Pumps, Condensing Units, and Water Chilling Packages

Equipment	Category	Sub-category &	Minimum	Rating	Standard
Type & Rating		Rating Conditions	Steady State	Seasonal or Part Load	
Evaporatively Cooled A/Cs &	≤65,000 Btu/h Cooling Capacity	Standard Conditions ¹ :	9.3 EER	8.5 IPLV	ARI 210/240- 1989
Heat Pumps Cooling Ratings	>65,000 and <135,000 Btu/h Cooling Capacity	Outdoor Conditions: 95°F db/75°F wb	10.5 EER	9.7 IPLV	CTI 201-1986
Water Source Heat Pump	≤ 65,000 Btu/h Cooling Capacity	Standard Conditions ¹ : Entering Water	9.3 EER 85°F ewt ²	10.2 EER 75°F ewt ²	ARI 320-1986
Cooling Ratings	>65,000 and <135,000 Btu/h Cooling Capacity	Standard Conditions ¹ : Entering Water	10.5 EER 85°F ewt ²	NA	CTI 201-1986
Ground Water Heat Pump Cooling Ratings	< 135,000 Btu/h Cooling Capacity	Standard Conditions ¹ : Entering Water	11.0 EER 70°F ewt ²	11.5 EER 50°F ewt ²	ARI 325-1985
Water Cooled Unitary Air	<65,000 Btu/h Cooling Capacity	Standard Conditions ¹ : Entering Water	9.3 EER 85°F ewt ²	8.3 IPLV 75°F ewt ²	ARI 210/240- 1989
Conditioners	> 65,000 and <135,000 Btu/h Cooling Canacity	Standard Conditions ¹ : Entering Water	10.5 EER 85°F ewt ²	NA	CTI 201-1986
Water/Evap Cooled Air Cond. and Heat Pumps Cooling Ratings	> 135,000 Btu/h Cooling Capacity	Standard Conditions ¹ :	9.6 EER	9.0 IPLV	ARI 360-1986 CTI 201-1986
Air and Water/ Evap Cooled Condensing Units Cooling Ratings ³	> 135,000 Btu/h Cooling Capacity	Air Cooled Water/Evap Cooled	9.9 EER 12.9 EER	11.0 IPLV 12.9 IPLV	ARI 365-1987 CTI 201-1986
Air and Water Cooled Water Chilling	< 150 Tons > 150 and < 300 Tons > 300 Tons	Water Cooled	3.8 COP 4.2 COP 5.2 COP ⁴	3.9 IPLV 4.5 IPLV 5.3 IPLV ⁴	ARI 550-90 ARI 590- 86pN
Packages Cooling Ratings	< 150 Tons ≥ 150 Tons	Air Cooled with Condenser	2.7 COP 2.5 COP	2.8 IPLV 2.5 IPLV	CTI 201-1986
	All Capacities	Air Cooled Condenserless	3.1 COP	3.2 IPLV	
Water & Ground- Water Source	< 135,000 Btu/h Cooling Capacity	Water Source Standard Conditions ¹ :	3.8 COP 70°F ewt ²	NA NA	ARI 320-1986
Heat Pumps Heating Ratings		Ground Water Source Standard Conditions ¹ :	3.4 COP 70°F ewt ²	3.0 COP 50°F ewt ²	ARI 325-1985

1. Standard Indoor Conditions: 80°F dry bulb and 67°F wet bulb.

2. ewt: Entering Water Temperature for water cooled heat pumps and air conditioners.

 Condensing unit requirements are based on single - number rating defined in paragraph 5.1.3.2 of ARI Standard 365.

 These requirements are reduced to 4.7 COP and 4.8 IPLV, where refrigerants with ozone depletion factors of 0.05 or less are used. No reduction is allowed for standard design systems analyzed under Standard RS-29.

TABLE 14-3 Standard Rating Conditions and Minimum Performance, Gas- and Oil-Fired Boilers

Reference	Calegory	Rating Condition	Minimum Performance	
DOE Test Procedure	Gas-Fired	Seasonal	AFUE	
10 CFR, Part 430	< 300,000 Btu/h	Rating	80%1,3	
AppN	Oil-Fired	Seasonal	AFUE	
	<300,000 Btu/h	Rating	80%1	
ANSI Z21.13-87	Gas-Fired	 Max. Rated Capacity²	Ec ⁴	
H.I. Htg. Boiler Std. 86	≥300,000 Btu/h	Steady-State	80%	
ASME PTC4.1-64		 Min. Rated Capacity²	Ec ⁴	
U.L. 795-73		Steady-State	80%	
U.L. 726-75	Oil-Fired	 Max. Rated Capacity²	Ec ⁴	
H.I. Htg. Boiler Std. 86	>300,000 Btu/h	Steady-State	83%	
ASME PTC4.1-64		 Min. Rated Capacity² Steady-State 	Ec ⁴ 83%	
H.I. Htg. Boiler Std. 86	Oil-Fired (Residual)	 Max. Rated Capacity² Steady-State 	Ec ⁴ 83%	
ASME PTC4.1-64	≥300,000 Btu/h	 Min. Rated Capacity² Steady-State 	Ec ⁴ 83%	

1. To be consistent with National Appliance Energy Conservation Act of 1987 (P.L. 100-12).

2. Provided and allowed by the controls.

3. Except for gas-fired steam boilers for which minimum AFUE is 75%.

 E_C = combustion efficiency, 100% - flue losses. See reference document for detailed information.

TABLE 14-4 Energy Efficient Electric Motors Minimum Nominal Full-Load Efficiency

		Open Motor	s	Closed Motors		
Synchronous Speed (RPM)	3,600	1,800	1,200	3,600	1,800	1,200
HP	Efficiency	Efficiency	Efficiency	Efficiency	Efficiency	Efficiency
1.0	-	82.5	80.0	75.5	82.5	80.0
1.5	82.5	84.0	84.0	82,5	84.0	85.5
2.0	84.0	84.0	85.5	84.0	84.0	86.5
3.0	84.0	86.5	86.5	85.5	87.5	87.5
5.0	85.5	. 87.5	87.5	87.5	. 87.5	87.5
7.5	87.5	88.5	88.5	88.5	89.5	89.5
10.0	88.5	89.5	90.2	89.5	89.5	89.5
15.0	89.5	91.0	90.2	90.2	91.0	90.2
20.0	90.2	91.0	91.0	90.2	91.0	90.2
25.0	91.0	91.7	91.7	91.0	92.4	91.7
30.0	91.0	92.4	92.4	91.0	92.4	91.7
40.0	91.7	93.0	93.0	91.7	93.0	93.0
50.0	92.4	93.0	93.0	92.4	93,0	93.0
60.0	93.0	93.6	93.6	93.0	93.6	93.6
75.0	93.0	94.1	93.6	93.0	94.1	93.6
100.0	93.0	94.1	94.1	93.6	94.5	94.1
125.0	93.6	94.5	94.1	94.5	94.5	94.1
150.0	93.6	95.0	94.5	94.5	95.0	95.0
200.0	94.5	95.0	94.5	95.0	95.0	95.0

TABLE 14-5 Duct Insulation

Duct Location	Insulation R-Value
Not within conditioned space: On exterior of building, on roof, in attic, in enclosed ceiling space, in walls, in garage, in crawl spaces	R-7 ¹
Not within conditioned space: in concrete, in ground	R-5.3
Supply air ducts within conditioned space with HVAC equipment supply air temperature <55 or >105°F	R-3.3

•

Note: Requirements apply to both supply and return ducts, whether heated or mechanically cooled. Mechanically cooled ducts requiring insulation shall have a vapor retarder, with a perm rating not greater than 0.5 and all joints sealed.

1. With approved weatherproof barrier.

INSULATION TYPES: Minimum densities and out of package thickness. Nominal R-values are for the insulation as installed and do not include air film resistance.

INSTALLED:

- R-3.3 1.0 inch 1.5 to 3.0 lb/cu.ft. duct liner, mineral or glass fiber blanket or equivalent to provide an installed total thermal resistance of at least R-3.3.
- R-5.3 2.0 inch 0.75 lb/cu.ft.mineral or glass fiber blanket, 1.5 inch 1.5 to 3.0 lb/cu.ft. duct liner, mineral or glass fiber blanket, 1.5 inch 3.0 to 7.0 lb/cu.ft. mineral or glass fiber board or equivalent to provide an installed total thermal resistance of at least R-5.3.
- R-7 3.0 inch 0.75 lb/cu.ft. mineral or glass fiber blanket, 2.0 inch 1.5 to 3.0 lb/cu.ft. duct liner, mineral or glass fiber blanket, 2.0 inch 3.0 to 7.0 lb/cu.ft. mineral or glass fiber board or equivalent to provide an installed total thermal resistance of at least R-7.

	INI	SLE 14-0	
Minimum	Pipe	Insulation	(inches) ¹

Fluid Design	Insulation Conduc	ctivity Nominal Pipe Diameter (in.)						
Operating	Conductivity Range	Mean	Runouts ²	1 and	> 1	> 2	>4	> 6
Temp. Range,	Btu \cdot in./(h \cdot ft ² \cdot °F)	Rating	up to 2	less	to 2	to 4	to 6	
oF		Temp. °F						-
Heating systems (Steam, Steam	Nominal Insulation Thickness						
Condensate and H	lot water)							
Above 350	0.32-0.34	250	1.5	2.5	2.5	3.0	3.5	3.5
251-350	0.29-0.31	200	1.5	2.0	2.5	2.5	3.5	3.5
201-250	0.27-0.30	150	1.0	1.5	1.5	2.0	2.0	3.5
141-200	0.25-0.29	125	0.5	1.5	1.5	1.5	1.5	1.5
105-140	0.24-0.28	100	0.5	1.0	1.0	1.0	1.5	1.5
Domestic and Service Hot Water Systems								
105 and Greater	0.24-0.28	100	0.5	1.0	1.0	1.5	1.5	1.5
Cooling Systems (Chilled Water, Brine and Refrigerant)								
40-55	0.23-0.27	75	0.5	0.5	0.75	1.0	1.0	1.0
Below 40	0.23-0.27	75	1.0	1.0	1.5	1.5	1.5	1.5

 Alternative Insulation Types. Insulation thicknesses in Table 14-6 are based on insulation with thermal conductivities within the range listed in Table 14-6 for each fluid operating temperature range, rated in accordance with ASTM C 335-84 at the mean temperature listed in the table. For insulation that has a conductivity outside the range shown in Table 14-6 for the applicable fluid operating temperature range at the mean rating temperature shown (when rounded to the nearest 0.01 Btu • in./(h • ft² • °F)), the minimum thickness shall be determined in accordance with the following equation:

$$T = PR[(1 + t/PR)K/k - 1]$$

Where

2.

- T = Minimum insulation thickness for material with conductivity K, inches.
- PR = Pipe actual outside radius, inches
- t = Insulation thickness from Table 14-6, inches
- K = Conductivity of alternate material at the mean rating temperature indicated in Table 14-6 for the applicable fluid temperature range, Btu • in/(h • ft² • °F)
- k = The lower value of the conductivity range listed in Table 14-6 for the applicable fluid temperature range, Btu • in/(h • ft² • °F)

Runouts to individual terminal units not exceeding 12 ft. in length.









CHAPTER 15 LIGHTING AND MOTORS

1501 Scope: Interior and exterior lighting and electric motors shall comply with the requirements of this chapter.

SECTION 1510 – GENERAL REQUIREMENTS: Lighting and motors shall comply with Sections 1511 through 1513. Lighting systems shall comply with one of the following paths:

- a. Prescriptive Lighting Option: Interior Section 1521, or Exterior Section 1522.
- Lighting Power Allowance Option: Interior Section 1531, or Exterior Section 1532.

•

c. Systems Analysis. See Section 1141.4.

The compliance path selected for interior and exterior lighting need not be the same. However, interior and exterior lighting cannot be traded.

Section Number	Subject	Prescriptive Lighting Option	Lighting Power Allowance Option	Systems Analysis Option
1510	General Requirements	х	X	х
1511	Electric Motors	X	Х	X
1512	Exempt Lighting	х	Х	х
1513	Lighting Controls	X	X	X
1520	Prescriptive Lighting Option	Х		
1521	Prescriptive Interior Lighting Requirements	X		
1522	Prescriptive Exterior Lighting Requirements	Sec. 1532		
1530	Lighting Power Allowance Option		X	
1531	Interior Lighting Power Allowance		X	
1532	Exterior Lighting Power Allowance	-	X	
RS-29	Systems Analysis			X

Figure 15A Lighting and Motor Compliance Options

1511 Electric Motors: All permanently wired polyphase motors of 1 hp or more, which are not part of an HVAC system, shall comply with Section 1437.

Exceptions:

- 1. Motors that are an integral part of specialized process equipment.
- Where the motor is integral to a listed piece of equipment for which no complying motor has been approved.

1512 Exempt Lighting

1512.1 Exempt Spaces: The following rooms, spaces and areas, are exempt from the lighting power requirements in Sections 1520 and 1530 but shall comply with all other requirements of this chapter.

- 1. Areas in which medical or dental tasks are performed.
- High risk security areas or any area identified by safety officials as requiring additional lighting.
- Spaces designed for primary use by the visually impaired, hard of hearing (lip-reading) or by senior citizens.
- 4. Food preparation areas.
- 5. Outdoor manufacturing, greenhouses and processing areas.
- 6. Electrical/mechanical equipment rooms.
- 7. Outdoor athletic facilities.
- 8. Inspection and restoration areas in galleries and museums.

1512.2 Exempt Lighting Equipment: The following lighting equipment and tasks are exempt from the lighting requirements of Section 1520 and need not be included when calculating the installed lighting power under Section 1530 but shall comply with all other requirements of this chapter. All other lighting in areas that are not exempted by Section 1512.2, where exempt tasks and equipment are used, shall comply with all of the requirements of this chapter.

- 1. Special lighting needs for research.
- Emergency lighting that is automatically OFF during normal building operation.
- Lighting for signs, and ballasted lighting for walkways and pathways.
- 4. Lighting that is part of machines, equipment or furniture.
- Lighting that is used solely for indoor plant growth during the hours of 10:00 p.m. to 6:00 a.m.
- Lighting for theatrical productions, television broadcasting (including sports facilities), audio-visual presentations and special effects lighting for stage areas and dance floors in entertainment facilities.
- Lighting for art exhibits, non-retail displays, portable plug in display fixtures and show case lighting.
- 8. Exterior lighting for public monuments.

1513 Lighting Controls

1513.1 Local Control and Accessibility: Each space, enclosed by walls or ceiling-height partitions, shall be provided with lighting controls located within that space. The lighting controls, whether one or more, shall be capable of turning off all lights within the space. The controls shall be readily accessible, at the point of entry/exit, to personnel occupying or using the space.

Exceptions: The following lighting controls may be centralized in remote locations:

- 1. Lighting controls for spaces which must be used as a whole.
- 2. Automatic controls.
- 3. Controls requiring trained operators.
- 4. Controls for safety hazards and security.

1513.2 Area Controls: The maximum lighting power that may be controlled from a single switch or automatic control shall not exceed that which is provided by a 20 ampere circuit loaded to not more than 80%. A master control may be installed provided the individual switches retain their capability to function independently. Circuit breakers may not be used as the sole means of switching.

Exceptions:

- Industrial or manufacturing process areas, as may be required for production.
- Areas less than 5% of the building footprint for footprints over 100,000 ft².

1513.3 Daylight Zone Control: All daylighted zones, as defined in Chapter 12, both under overhead glazing and adjacent to vertical glazing, shall be provided with individual controls, or daylight- or occupant-sensing automatic controls, which control the lights independent of general area lighting.

1513.4 Display, Exhibition and Specialty Lighting Controls: All display, exhibition or specialty lighting shall be controlled independently of general area lighting.

1513.5 Automatic Shut-off Controls, Exterior: Exterior lighting not intended for 24-hour continuous use shall be automatically switched by timer, photocell or a combination of timer and photocell. Automatic time switches shall also have program back-up capabilities, which prevent the loss of program and time settings for at least 10 hours, if power is interrupted.

1513.6 Automatic Shut-Off Controls, Interior: Office buildings greater than 25,000 ft², and all school classrooms shall be equipped with separate automatic controls to shut off the lighting during unoccupied hours. Automatic controls may be an occupancy sensor, time switch or other device capable of automatically shutting off lighting.

Exceptions:

- Areas that must be continuously illuminated, or illuminated in a manner requiring manual operation of the lighting.
- 2. Emergency lighting systems.
- Switching for industrial or manufacturing process facilities as may be required for production.

1513.6.1 Occupancy Sensors: Occupancy sensors shall be capable of automatically turning off all the lights in an area, no more than 30 minutes after the area has been vacated.

1513.6.2 Automatic Time Switches: Automatic time switches shall have a minimum 7 day clock and be capable of being set for 7 different day types per week and incorporate an automatic holiday "shut-off" feature, which turns off all loads for at least 24 hours and then resumes normally scheduled operations. Automatic time switches shall also have program back-up capabilities, which prevent the loss of program and time settings for at least 10 hours, if power is interrupted.

Automatic time switches shall incorporate an over-ride switching device which:

- a. is readily accessible;
- b. is located so that a person using the device can see the lights or the areas controlled by the switch, or so that the area being illuminated is annunciated;
- c. is manually operated;
- allows the lighting to remain on for no more than 2 hours when an over-ride is initiated; and
- controls an area not exceeding 5,000 ft² or 5% of footprint for footprints over 100,000 ft², whichever is greater.

SECTION 1520 -- PRESCRIPTIVE LIGHTING OPTION

1521 Prescriptive Interior Lighting Requirements: Spaces for which the Unit Lighting Power Allowance in Table 15-1 is 0.80 W/ft² or greater may use unlimited numbers of lighting fixtures and lighting energy, provided that the installed lighting fixtures are one- or two-lamp (hut not three- or more lamp) non-lensed, fluorescent fixtures fitted with type T-5, T-6, T-8 or PL type lamps from 5 to 50 watts and electronic ballasts.

Exception: Up to a total of 5% of installed lighting fixtures need not be ballasted and may use any type of lamp.

1522 Prescriptive Exterior Lighting Requirements: See Section 1532.

SECTION 1530 -- LIGHTING POWER ALLOWANCE OPTION: The installed lighting wattage shall not exceed the lighting power allowance. Lighting wattage includes lamp and ballast wattage. Wattage for fluorescent lamps and ballasts shall be tested per ANSI Standard C82.2-1984.

The wattage used for any unballasted fixture shall be the maximum UL listed wattage for that fixture regardless of the lamp installed. The wattage used for track lighting shall be the maximum of actual luminaire wattage or 50 watts per lineal foot of track.

No credit towards compliance with the lighting power allowances shall be given for the use of any controls, automatic or otherwise.

1531 Interior Lighting Power Allowance: The interior lighting power allowance shall be calculated by multiplying the gross interior floor area, in square feet, by the appropriate unit lighting power allowance, in watts per square foot, for the use as specified in Table 15-1. Accessory uses, including corridors, lobbies and toilet facilities shall be included with the primary use.

If multiple uses are intended, the lighting power allowance for each type of use shall be separately calculated and summed to obtain the interior lighting power allowance.

In cases where a lighting plan for only a portion of a building is submitted, the interior lighting power allowance shall be based on the gross floor area covered by the plan. Plans submitted for common areas only, including corridors, lobbies and toilet facilities shall use the lighting power allowance for common areas in Table 15-1.

When insufficient information is known about the specific use of the space, the allowance shall be based on the apparent intended use of the space.

1532 Exterior Lighting Power Allowance: The exterior lighting power allowance shall be the sum of the calculated allowances for parking, outdoor areas and building exteriors. The lighting allowance for covered parking, open parking and outdoor areas shall be 0.20 W/ft². The lighting allowance for building exteriors shall be calculated either by multiplying the building facade area by 0.25 W/ft² or multiplying the building perimeter in feet by 7.5 watts per lineal foot.

Exception: Group M occupancy accessory to Group R occupancy.

LPA2 (W/ft2)Painting, welding, carpentry, machine shops2.30Barber shops, beauty shops2.00Hotel banquet/conference/exhibition hall3,42.00Laboratories2.00Aircraft repair hangars1.50Cafeterias, fast food establishments51.50Factories, workshops, handling areas1.50Gas stations, auto repair shops61.50Institutions1.50Libraries51.50Mursing homes1.50Wholesale stores (pallet rack shelving)1.50Mall concourses1.40School buildings, school classrooms, day care centers1.30Laundries1.30Office buildings, office/administrative areas in facilities of other use types (including but not limited to schools, hospitals, institutions, museums, banks, churches)5,71.00Police and fire stations81.20Atria (atriums)1.00Assembly spaces9, auditoriums, gymnasia9, theaters1.00Restaurants/bars51.00Restaurants/bars50.80Warehouses11, storage areas0.50Aircraft storage hangars0.40Parking garagesSee Section 1532Plans Submitted for Common Areas Only70.80Common area, corridors, lobbies (except mall concourse)0.80	Unit Lighting Power Anowance (L	(A)
Painting, welding, carpentry, machine shops2.30Barber shops, beauty shops2.00Hotel banquet/conference/exhibition hall3,42.00Laboratories2.00Aircraft repair hangars1.50Cafeterias, fast food establishments51.50Factories, workshops, handling areas1.50Gas stations, auto repair shops61.50Institutions1.50Libraries51.50Nursing homes1.50Wholesale stores (pallet rack shelving)1.50Mall concourses1.40School buildings, school classrooms, day care centers1.30Office buildings, office/administrative areas in facilities of other use types (including but not limited to schools, hospitals, institutions, museums, banks, churches)5,71.00Police and fire stations81.20Atria (atriums)1.00Assembly spaces9, auditoriums, gymnasia9, theaters1.00Restaurants/bars51.00Retail A101.00Retail B10, retail banking1.50Locker and/or shower facilities0.80Warehouses11, storage areas0.50Aircraft storage hangars0.40Parking garagesSee Section 1532Plans Submitted for Common Areas Only70.80Common area, corridors, lobbies (except mall concourse)0.80	Use1	LPA ² (W/ft ²)
Barber shops, beauty shops2.00Hotel banquet/conference/exhibition hall3,42.00Laboratories2.00Aircraft repair hangars1.50Cafeterias, fast food establishments51.50Factories, workshops, handling areas1.50Gas stations, auto repair shops61.50Institutions1.50Libraries51.50Nursing homes1.50Wholesale stores (pallet rack shelving)1.50Mall concourses1.40School buildings, school classrooms, day care centers1.30Office buildings, office/administrative areas in facilities of other use types (including but not limited to schools, hospitals, institutions, museums, banks, churches)5,71.00Police and fire stations81.20Atria (atriums)1.00Assembly spaces9, auditoriums, gymnasia9, 	Painting, welding, carpentry, machine shops	2.30
Hotel banquet/conference/exhibition hall3,42.00Laboratories2.00Aircraft repair hangars1.50Cafeterias, fast food establishments51.50Factories, workshops, handling areas1.50Gas stations, auto repair shops61.50Institutions1.50Libraries51.50Nursing homes1.50Wholesale stores (pallet rack shelving)1.50Mall concourses1.40School buildings, school classrooms, day care centers1.30Office buildings, office/administrative areas in facilities of other use types (including but not limited to schools, hospitals, institutions, museums, banks, churches)5,71.00Police and fire stations81.20Atria (atriums)1.00Assembly space59, auditoriums, gymnasia9, theaters1.00Restaurants/bars51.00Retail A10 Parking garages1.50Locker and/or shower facilities0.80Warehouses11, storage areas0.50Aircraft storage hangars0.40Parking garagesSee Section 1532Plans Submitted for Common Areas Only70.80Common area, corridors, lobbies (except mall concourse) Toilet facilities, substrooms0.80	Barber shops, beauty shops	2.00
Laboratories2.00Aircraft repair hangars1.50Cafeterias, fast food establishments ⁵ 1.50Factories, workshops, handling areas1.50Gas stations, auto repair shops ⁶ 1.50Institutions1.50Libraries ⁵ 1.50Nursing homes1.50Wholesale stores (pallet rack shelving)1.50Mall concourses1.40School buildings, school classrooms, day care centers1.30Office buildings, office/administrative areas in facilities of other use types (including but not limited to schools, hospitals, institutions, museums, banks, churches) ^{5,7} 1.20Police and fire stations ⁸ 1.20Atria (atriums)1.00Assembly spaces ⁹ , auditoriums, gymnasia ⁹ , theaters1.00Process plants1.00Retail B ¹⁰ , retail banking1.50Locker and/or shower facilities0.80Warehouses ¹¹ , storage areas0.50Aircraft storage hangars0.40Parking garagesSee Section 1532Plans Submitted for Common Areas Only ⁷ 0.80Common area, corridors, lobbies (except mall concourse)0.80	Hotel banquet/conference/exhibition hall3,4	2.00
Aircraft repair hangars1.50Cafeterias, fast food establishments ⁵ 1.50Factories, workshops, handling areas1.50Gas stations, auto repair shops ⁶ 1.50Institutions1.50Libraries ⁵ 1.50Nursing homes1.50Wholesale stores (pallet rack shelving)1.50Mall concourses1.40School buildings, school classrooms, day care centers1.30Office buildings, office/administrative areas in facilities of other use types (including but not limited to schools, hospitals, institutions, museums, banks, churches) ^{5,7} 1.20Police and fire stations ⁸ 1.20Atria (atriums)1.00Assembly spaces ⁹ , auditoriums, gymnasia ⁹ , theaters1.00Restaurants/bars ⁵ 1.00Retail Al01.00Retail Bl0, retail banking1.50Locker and/or shower facilities0.80Warehouses ¹¹ , storage areas0.50Aircraft storage hangars0.40Parking garagesSee Section 1532Plans Submitted for Common Areas Only ⁷ 0.80Common area, corridors, lobbies (except mall concourse)0.80	Laboratories	2.00
Cafeterias, fast food establishments1.50Factories, workshops, handling areas1.50Gas stations, auto repair shops1.50Institutions1.50Libraries1.50Nursing homes1.50Wholesale stores (pallet rack shelving)1.50Mall concourses1.40School buildings, school classrooms, day care centers1.30Laundries1.30Office buildings, office/administrative areas in facilities of other use types (including but not limited to schools, hospitals, institutions, museums, banks, churches)1.00Astia (atriums)1.00Astendy spaces1.00Restaurants/bars1.00Restaurants/bars1.00Retail B10, retail banking1.50Locker and/or shower facilities0.80Warehouses1.storage areas0.500.80Parking garagesSee Section 1532Plans Submitted for Common Areas Only0.80Common area, corridors, lobbies (except mall concourse)0.80	Aircraft repair hangars	1.50
Factories, workshops, handling areas1.50Gas stations, auto repair shops1.50Institutions1.50Institutions1.50Libraries1.50Nursing homes1.50Wholesale stores (pallet rack shelving)1.50Mall concourses1.40School buildings, school classrooms, day care centers1.35Laundries1.30Office buildings, office/administrative areas in facilities of other use types (including but not limited to schools, hospitals, institutions, museums, banks, churches)1.20Atria (atriums)1.00Assembly spaces1.00Restaurants/bars1.00Restaurants/bars1.00Retail B10, retail banking1.50Locker and/or shower facilities0.80Warehouses1. storage areas0.500.40Parking garagesSee Section 1532Plans Submitted for Common Areas Only70.80Common area, corridors, lobbies (except mall concourse) Toilet facilities, washrooms0.80	Cafeterias, fast food establishments ⁵	1.50
Gas stations, auto repair shops ⁶ 1.50 Institutions 1.50 Libraries ⁵ 1.50 Nursing homes 1.50 Wholesale stores (pallet rack shelving) 1.50 Mall concourses 1.40 School buildings, school classrooms, day care centers 1.30 Diffice buildings, office/administrative areas in facilities of other use types (including but not limited to schools, hospitals, institutions, museums, banks, churches) ^{5,7} 1.20 Police and fire stations ⁸ 1.20 Atria (atriums) 1.00 Assembly spaces ⁹ , auditoriums, gymnasia ⁹ , theaters 1.00 Process plants 1.00 Restaurants/bars ⁵ 1.00 Retail A ¹⁰ 1.00 Retail B ¹⁰ , retail banking 1.50 Locker and/or shower facilities 0.80 Warehouses ¹¹ , storage areas 0.50 Aircraft storage hangars 0.40 Parking garages See Section 1532 Plans Submitted for Common Areas Only ⁷ 0.80 Common area, corridors, lobbies (except mall concourse) 0.80	Factories, workshops, handling areas	1.50
Institutions 1.50 Libraries ⁵ 1.50 Nursing homes 1.50 Wholesale stores (pallet rack shelving) 1.50 Mall concourses 1.40 School buildings, school classrooms, day care centers 1.35 Laundries 1.30 Office buildings, office/administrative areas in facilities of other use types (including but not limited to schools, hospitals, institutions, museums, banks, churches) ^{5,7} 1.20 Atria (atriums) 1.00 Assembly spaces ⁹ , auditoriums, gymnasia ⁹ , theaters 1.00 Process plants 1.00 Restaurants/bars ⁵ 1.00 Retail A ¹⁰ 1.00 Retail B ¹⁰ , retail banking 1.50 Locker and/or shower facilities 0.80 Warehouses ¹¹ , storage areas 0.50 Aircraft storage hangars 0.40 Parking garages See Section 1532 Plans Submitted for Common Areas Only ⁷ 0.80 Common area, corridors, lobbies (except mall concourse) 0.80	Gas stations, auto repair shops6	1.50
Libraries51.50Nursing homes1.50Wholesale stores (pallet rack shelving)1.50Mall concourses1.40School buildings, school classrooms, day care centers1.35Laundries1.30Office buildings, office/administrative areas in facilities of other use types (including but not limited to schools, hospitals, institutions, museums, banks, churches)5,71.20Atria (atriums)1.00Assembly spaces9, auditoriums, gymnasia9, theaters1.00Restaurants/bars51.00Restaurants/bars51.00Retail B10, retail banking1.50Locker and/or shower facilities0.80Warehouses11, storage areas0.50Aircraft storage hangars0.40Parking garagesSee Section 1532Plans Submitted for Common Areas Only70.80Common area, corridors, lobbies (except mall concourse) Toilet facilities, washrooms0.80	Institutions	1.50
Nursing homes 1.50 Wholesale stores (pallet rack shelving) 1.50 Mall concourses 1.40 School buildings, school classrooms, day care centers 1.35 Laundries 1.30 Office buildings, office/administrative areas in facilities of other use types (including but not limited to schools, hospitals, institutions, museums, banks, churches) ^{5,7} 1.20 Atria (atriums) 1.00 Assembly spaces ⁹ , auditoriums, gymnasia ⁹ , theaters 1.00 Process plants 1.00 Restaurants/bars ⁵ 1.00 Restaurants/bars ⁵ 1.00 Retail A ¹⁰ 1.00 Nateraft storage areas 0.50 Aircraft storage hangars 0.40 Parking garages See Section 1532 Plans Submitted for Common Areas Only ⁷ 0.80 Common area, corridors, lobbies (except mall concourse) 0.80	Libraries ⁵	1.50
Wholesale stores (pallet rack shelving) 1.50 Mall concourses 1.40 School buildings, school classrooms, day care centers 1.35 Laundries 1.30 Office buildings, office/administrative areas in facilities of other use types (including but not limited to schools, hospitals, institutions, museums, banks, churches)5,7 1.20 Atria (atriums) 1.00 Assembly spaces ⁹ , auditoriums, gymnasia ⁹ , theaters 1.00 Process plants 1.00 Restaurants/bars ⁵ 1.00 Retail B ¹⁰ , retail banking 1.50 Locker and/or shower facilities 0.80 Warehouses ¹¹ , storage areas 0.50 Aircraft storage hangars 0.40 Parking garages See Section 1532 Plans Submitted for Common Areas Only ⁷ 0.80 Common area, corridors, lobbies (except mall concourse) 0.80	Nursing homes	1,50
Mall concourses 1.40 School buildings, school classrooms, day care centers 1.35 Laundries 1.30 Office buildings, office/administrative areas in facilities of other use types (including but not limited to schools, hospitals, institutions, museums, banks, churches)5,7 1.20 Police and fire stations8 1.20 Atria (atriums) 1.00 Assembly spaces9, auditoriums, gymnasia9, theaters 1.00 Process plants 1.00 Retail A10 1.00 Retail B10, retail banking 1.50 Locker and/or shower facilities 0.80 Warehouses11, storage areas 0.50 Aircraft storage hangars 0.40 Parking garages See Section 1532 Toilet facilities, washrooms 0.80	Wholesale stores (pallet rack shelving)	1.50
School buildings, school classrooms, day care centers 1.35 Laundries 1.30 Office buildings, office/administrative areas in facilities of other use types (including but not limited to schools, hospitals, institutions, museums, banks, churches) ^{5,7} 1.20 Atria (atriums) 1.00 Assembly spaces ⁹ , auditoriums, gymnasia ⁹ , theaters 1.00 Process plants 1.00 Restaurants/bars ⁵ 1.00 Restaurants/bars ⁵ 1.00 Retail A ¹⁰ 1.00 Retail B ¹⁰ , retail banking 1.50 Locker and/or shower facilities 0.80 Warehouses ¹¹ , storage areas 0.50 Aircraft storage hangars 0.40 Parking garages See Section 1532 Plans Submitted for Common Areas Only ⁷ 0.80 (except mall concourse) 0.80	Mall concourses	1.40
Laundries 1.30 Office buildings, office/administrative areas in facilities of other use types (including but not limited to schools, hospitals, institutions, museums, banks, churches)5,7 1.20 Police and fire stations ⁸ 1.20 Atria (atriums) 1.00 Assembly spaces ⁹ , auditoriums, gymnasia ⁹ , theaters 1.00 Process plants 1.00 Restaurants/bars ⁵ 1.00 Retail B ¹⁰ , retail banking 1.50 Locker and/or shower facilities 0.80 Warehouses ¹¹ , storage areas 0.50 Aircraft storage hangars 0.40 Parking garages See Section 1532 Plans Submitted for Common Areas Only ⁷ Common area, corridors, lobbies (except mall concourse) Toilet facilities, washrooms 0.80	School buildings, school classrooms, day care centers	1.35
Office buildings, office/administrative areas in facilities of other use types (including but not limited to schools, hospitals, institutions, museums, banks, churches)5,7 1.20 Atria (atriums) 1.00 Assembly spaces ⁹ , auditoriums, gymnasia ⁹ , theaters 1.00 Process plants 1.00 Restaurants/bars ⁵ 1.00 Retail A ¹⁰ 1.00 Retail B ¹⁰ , retail banking 1.50 Locker and/or shower facilities 0.80 Warehouses ¹¹ , storage areas 0.50 Aircraft storage hangars 0.40 Parking garages See Section 1532 Plans Submitted for Common Areas Only ⁷ 0.80 Common area, corridors, lobbies (except mall concourse) 0.80	Laundries	1.30
facilities of other use types (including but not limited to schools, hospitals, institutions, museums, banks, churches)5,7 Police and fire stations ⁸ 1.20 Atria (atriums) 1.00 Assembly spaces ⁹ , auditoriums, gymnasia ⁹ , theaters 1.00 Process plants 1.00 Restaurants/bars ⁵ 1.00 Retail A ¹⁰ 1.00 Retail B ¹⁰ , retail banking 1.50 Locker and/or shower facilities 0.80 Warehouses ¹¹ , storage areas 0.50 Aircraft storage hangars 0.40 Parking garages See Section 1532 Plans Submitted for Common Areas Only ⁷ 0.80 (except mall concourse) 0.80	Office buildings, office/administrative areas in	1.20
Police and fire stations ⁸ 1.20 Atria (atriums) 1.00 Assembly spaces ⁹ , auditoriums, gymnasia ⁹ , theaters 1.00 Process plants 1.00 Restaurants/bars ⁵ 1.00 Retail A ¹⁰ 1.00 Retail B ¹⁰ , retail banking 1.50 Locker and/or shower facilities 0.80 Warehouses ¹¹ , storage areas 0.50 Aircraft storage hangars 0.40 Parking garages See Section 1532 Plans Submitted for Common Areas Only ⁷ Common area, corridors, lobbies (except mall concourse) Toilet facilities, washrooms 0.80	facilities of other use types (including but not limited to schools, hospitals, institutions, museums, banks, churches) ^{5,7}	
Atria (atriums) 1.00 Assembly spaces ⁹ , auditoriums, gymnasia ⁹ , theaters 1.00 Process plants 1.00 Restaurants/bars ⁵ 1.00 Retail A ¹⁰ 1.00 Retail B ¹⁰ , retail banking 1.50 Locker and/or shower facilities 0.80 Warehouses ¹¹ , storage areas 0.50 Aircraft storage hangars 0.40 Parking garages See Section 1532 Plans Submitted for Common Areas Only ⁷ Common area, corridors, lobbies (except mall concourse) Toilet facilities, washrooms 0.80	Police and fire stations ⁸	1.20
Assembly spaces ⁹ , auditoriums, gymnasia ⁹ , theaters 1.00 Process plants 1.00 Restaurants/bars ⁵ 1.00 Retail A ¹⁰ 1.00 Retail B ¹⁰ , retail banking 1.50 Locker and/or shower facilities 0.80 Warehouses ¹¹ , storage areas 0.50 Aircraft storage hangars 0.40 Parking garages See Section 1532 Plans Submitted for Common Areas Only ⁷ Common area, corridors, lobbies (except mall concourse) Toilet facilities, washrooms 0.80	Atria (atriums)	1.00
Process plants 1.00 Restaurants/bars ⁵ 1.00 Retail A ¹⁰ 1.00 Retail A ¹⁰ 1.00 Retail B ¹⁰ , retail banking 1.50 Locker and/or shower facilities 0.80 Warehouses ¹¹ , storage areas 0.50 Aircraft storage hangars 0.40 Parking garages See Section 1532 Plans Submitted for Common Areas Only ⁷ Common area, corridors, lobbies (except mall concourse) Toilet facilities, washrooms 0.80	Assembly spaces ⁹ , auditoriums, gymnasia ⁹ , theaters	1.00
Restaurants/bars ⁵ 1.00 Retail A ¹⁰ 1.00 Retail B ¹⁰ , retail banking 1.50 Locker and/or shower facilities 0.80 Warehouses ¹¹ , storage areas 0.50 Aircraft storage hangars 0.40 Parking garages See Section 1532 Plans Submitted for Common Areas Only ⁷ 0.80 (except mall concourse) 0.80 Toilet facilities, washrooms 0.80	Process plants	1.00
Retail A10 1.00 Retail B10, retail banking 1.50 Locker and/or shower facilities 0.80 Warehouses11, storage areas 0.50 Aircraft storage hangars 0.40 Parking garages See Section 1532 Plans Submitted for Common Areas Only7 Common area, corridors, lobbies (except mall concourse) Toilet facilities, washrooms 0.80	Restaurants/bars ⁵	1.00
Retail B10, retail banking 1.50 Locker and/or shower facilities 0.80 Warehouses11, storage areas 0.50 Aircraft storage hangars 0.40 Parking garages See Section 1532 Plans Submitted for Common Areas Only7 Common area, corridors, lobbies (except mall concourse) Toilet facilities, washrooms 0.80	Retail A10	1.00
Locker and/or shower facilities 0.80 Warehouses II, storage areas 0.50 Aircraft storage hangars 0.40 Parking garages See Section 1532 Plans Submitted for Common Areas Only ⁷ Common area, corridors, lobbies (except mall concourse) Toilet facilities, washrooms 0.80	Retail B10, retail banking	1.50
Warehouses11, storage areas 0.50 Aircraft storage hangars 0.40 Parking garages See Section 1532 Plans Submitted for Common Areas Only7 Common area, corridors, lobbies (except mall concourse) Toilet facilities, washrooms 0.80	Locker and/or shower facilities	0.80
Aircraft storage hangars 0.40 Parking garages See Section 1532 Plans Submitted for Common Areas Only ⁷ Common area, corridors, lobbies (except mall concourse) Toilet facilities, washrooms 0.80	Warehouses ¹¹ , storage areas	0.50
Parking garages Sec Section 1532 Plans Submitted for Common Areas Only ⁷ Common area, corridors, lobbies (except mall concourse) 0.80 Toilet facilities, washrooms 0.80	Aircraft storage hangars	0.40
Plans Submitted for Common Areas Only7 Common area, corridors, lobbies 0.80 (except mall concourse) 7 Toilet facilities, washrooms 0.80	Parking garages	See Section 1532
Common area, corridors, lobbies 0.80 (except mall concourse) 0.80 Toilet facilities, washrooms 0.80	Plans Submitted for Common Areas Only7	
Toilet facilities, washrooms 0.80	Common area, corridors, lobbies	0.80
U.U.U	Toilet facilities, washrooms	0.80

TABLE 15-1 Unit Lighting Power Allowance (LPA)

Footnotes for Table 15-1

- In cases in which a use is not mentioned specifically, the Unit Power Allowance shall be determined by the building official. This determination shall be based upon the most comparable use specified in the table. See Section 1512 for exempt areas.
- The watts per square foot may be increased, by 2% per foot of ceiling height above 20 feet, unless specifically directed otherwise by subsequent footnotes.
- The watts per square foot of room may be increased by 2% per foot of ceiling height above 12 feet.
- For all other spaces, such as seating and common areas, use the Unit Light Power Allowance for assembly.
- The watts per square foot of room may be increased by 2% per foot of ceiling height above 9 fect.
- 6. Includes pump area under canopy.
- 7. In cases in which a lighting plan is submitted for only a portion of a floor, a Unit Lighting Power Allowance of 1.35 may be used for usable office floor, area and 0.80 W/ft² shall be used for the common areas, which may include elevator space, lobby area and rest rooms. Common areas, as herein defined do not include mall concourses.
- For the fire engine room, the Unit Lighting Power Allowance is 1.00 W/ft².
- For indoor sport tournament courts with adjacent spectator seating, the Unit Lighting Power Allowance for the court area is 2.60 W/ft².
- For both Retail A and Retail B, light for free-standing display, building showcase illumination and display window illumination installed within 2 feet of the window are exempt.

Retail A allows a Unit Lighting Power Allowance of 1.00 W/ft². Ceiling mounted adjustable tungsten halogen and HID merchandise display luminaires are exempt.

Retail B allows a Unit Lighting Power Allowance of 1.5 W/ft², including all ceiling mounted merchandise display luminaires.

11. Provided that a floor plan, indicating rack location and height, is submitted, the square footage for a warehouse may be defined, for computing the interior Unit Lighting Power Allowance, as the floor area not covered by racks plus the vertical face area (access side only) of the racks. The height allowance defined in footnote 2 applies only to the floor area not covered by racks.

CHAPTER 16 (RESERVED)

.

.

•

¥

-

CHAPTER 17 STANDARDS

1701 Scope: The following standards shall apply to Chapters 11 through 20.

The standards and portions thereof, which are referred to in various parts of this Code shall be part of the Washington State Energy Code and are hereby declared to be a part of this Code.

CODE STANDARD NO.

۲

TITLE AND SOURCE

RS-1 through RS-8 (Reserved)

- RS-9 ASHRAE/IES Standard 90.1-1989, Efficient Design of Buildings Except New Low-Rise Residential Buildings.
- RS-10 Standard for Packaged Terminal Air Conditioners, ARI Standard 310-87.

RS-11 through RS-17 (Reserved)

RS-18 SMACNA Duct Metal and Flexible Construction Standards, 1st Edition.

RS-19 through RS-24 (Reserved)

RS-25 Thermal Bridges in Sheet Metal Construction from Appendix E of RS-9.

RS-26 Super Good Cents Buider's Field Guide.

RS-27 1993 ASHRAE Fundamentals Handbook.

RS-28 1992 ASHRAE HVAC Systems and Equipment Handbook.

RS-29 Commercial Building Design by Systems Analysis.

RS-30 Title 10, Code of Federal Regulations (CFR), Part 430 (March 14, 1988).

RS-31 National Fenestration Rating Council (NFRC) Standard 100-91.

ACCREDITED AUTHORITATIVE AGENCIES

ANSI refers to the American National Standards Institute, Inc., 1430 Broadway, New York, NY 10018

ARI refers to the Air Conditioning and Refrigeration Institute, 4301 North Fairfax Drive, Suite 425, Arlington, VA 22203

ASHRAE refers to the American Society of Heating, Refrigerating and Air Conditioning Engineers, Inc., 1791 Tullie Circle, N.E., Atlanta, GA 30329

ASTM refers to the American Society for Testing and Materials, 1916 Race Street, Philadelphia, PA 19103

CTI refers to the Cooling Tower Institute, P.O.Box 73383, Houston, TX 77273

NFRC refers to the National Fenestration Rating Council, 1300 Spring Street, Suite 120, Silver Spring, MD 20910

SMACNA refers to the Sheet Metal and Air Conditioning Contractors National Association, Inc., 4201 Lafayette Center Drive, Chantilly, VA 22021-1209

CHAPTER 18 (RESERVED)

.

-

CHAPTER 19 (RESERVED)
1994 FIRST EDITION

CHAPTER 20 DEFAULT HEAT LOSS COEFFICIENTS

2001 General

2001.1 Scope: The following defaults will apply to Chapters 11 through 20. This chapter includes tables of seasonal average heat loss coefficients for specified nominal insulation. The heat loss coefficients may also be used for heating system sizing.

2001.2 Description: These coefficients were developed primarily from data and procedures from Standard RS-27, and taken specifically from Standard RS-26, listed in Chapter 17.

Coefficients not contained in this chapter may be computed using the procedures listed in these references if the assumptions in the following sections and Standard RS-26, listed in Chapter 17, are used, along with data from the sources referenced above.

2001.3 Air Films: Default R-values used for air films shall be as follows:

R-Value	Condition
0.17	All exterior surfaces
0.61	Interior horizontal surfaces, heat flow up
0.72	Interior horizontal surfaces, heat flow down
0.68	Interior vertical surfaces

2001.4 Compression of Insulation: Insulation which is compressed shall be rated in accordance with Table 20-A or reduction in value may be calculated in accordance with the procedures in Standard RS-27, listed in Chapter 17.

	Insulation R-Value at Standard Thickness											
R-V	atue	38	30	22	21	19	15	13	11	8	5	3
Standard	Thickness	12"	9-1/1"	6-34"	5-1/1"	6-1/4"	3-1/2"	3-5/8"	3-1/2"	2-1/2"	1-1/2"	3/4 **
Nominal Lumber Sizes, Inches	Actual Depth of Cavity, Inches		1	nsulatio	n R-Val	ucs whe	en Instal	led in a	Confine	d Cavit	у	
2 x 12	11-1/4	37				-						
2 x 10	9-1/4	32	30			**			**			
2 x 8	7-1/4	27	26			-						
2 x 6	5-1/2		21	20	21	18						
2 x 4	3-1/2			14		13	15	13	11			
2 x 3	2-1/2				-			9.8				
2" x 2"	1-1/2"					**		6.3	6.0	5.7	5.0	
2" x 1"	3/4"										3.2	3.0

TABLE 20-A

R-Value of Fiberglass Batts Compressed within Various Depth Cavities

2002 Below Grade Walls And Slabs

2002.1 General: Table 20-1 lists heat loss coefficients for below-grade walls and floors.

Coefficients for below-grade walls are given as U-factors (Btu/h \cdot ft² \cdot °F of wall area). Coefficients for below-grade slabs are listed as F-factors (Btu/h \cdot ft \cdot °F per lineal foot of slab perimeter).

Below-grade wall U-factors are only valid when used with the accompanying below-grade slab F-factor, and vice versa.

2002.2 Component Description: All below-grade walls are assumed to be 8 inch concrete. The wall is assumed to extend from the slab upward to the top of the mud sill for the distance specified in Table 20-1, with 6 inches of concrete wall extending above grade.

Interior insulation is assumed to be fiberglass batts placed in the cavity formed by 2x4 framing on 24 inch centers with 1/2 inch gypsum board as the interior finish material. Exterior insulation is assumed to be applied directly to the exterior of the below-grade wall from the top of the wall to the footing. The exterior case does not assume any interior framing or sheetrock.

In all cases, the entire wall surface is assumed to be insulated to the indicated nominal level with the appropriate framing and insulation application. Coefficients are listed for wall depths of 2, 3-1/2 and 7 feet below grade. Basements shallower than 2 feet should use on-grade slab coefficients.

Heat loss calculations for wall areas above grade should use above-grade wall U-factors, beginning at the mudsill.

2002.3 Insulation Description: Coefficients are listed for the following four configurations:

- 1. Uninsulated: No insulation or interior finish.
- Interior insulation: Interior 2x4 insulated wall without a thermal break between concrete wall and slab.
- Interior insulation with thermal break: Interior 2x4 insulated wall with R-5 rigid board providing a thermal break between the concrete wall and the slab.
- Exterior insulation: Insulation applied directly to the exterior surface of the concrete wall.

TABLE 20-1 Default Wall U-Factors and Slab F-Factors for Basements

4

0

and the second	Below Grade Wall U-factor	Below Grade Slab F-factor
2-Foot Depth		
Below Grade		
Uninsulated	0.350	0.59
R-11 Interior	0.066	0.68
R-11 Interior w/tb	0.070	0.60
R-19 Interior	0.043	0.69
R-19 Interior w/tb	0.045	0.61
R-10 Exterior	0.070	0.60
R-12 Exterior	0.061	0.60
	and the second s	
3.5-Foot Depth		
Below Grade		
Uninsulated	0.278	0.53
R-11 Interior	0.062	0.63
R-11 Interior w/tb	0.064	0.57
R-19 Interior	0.041	0.64
R-19 Interior w/tb	0.042	0.57
R-10 Exterior	0.064	0.57
R-12 Exterior	0.057	0.57
7-Foot Depth		
Below Grade		
	Contraction of the second	
Uninsulated	0.193	0.46
R-11 Interior	0.054	0.56
R-11 Interior w/tb	0.056	0.42
R-19 Interior	0.037	0.57
R-19 Interior w/tb	0.038	0.43
R-10 Exterior	0.056	0.42
R-12 Exterior	0.050	0.42

2003 On-Grade Slab Floors

2003.1 General: Table 20-2 lists heat loss coefficients for unheated and heated on-grade slab floors, in units of Btu/h • °F per lineal foot of perimeter.

2003.2 Component Description: All on-grade slab floors are assumed to be 6 inch concrete poured directly onto the earth. The bottom of the slab is assumed to be at grade line. Monolithic and floating slabs are not differentiated.

Soil is assumed to have a conductivity of 0.75 Btu/h • ft² • °F. Slabs 2 feet or more below grade should use basement coefficients.

2003.3 Insulation Description: Coefficients are provided for the following three configurations:

Two Foot (or Four Foot) vertical: Insulation is applied directly to the slab exterior, extending downward from the top of the slab to a depth of 2 feet (or 4 feet) below grade.

Two Foot (or Four Foot) horizontal: Insulation is applied directly to the underside of the slab, and run horizontally from the perimeter inward for 2 feet (or 4 feet). The slab edge is exposed in this configuration.

Fully insulated slab: Insulation extends from the top of the slab, along the entire perimeter and completely covers the area under the slab. Thicker perimeter insulation covers the slab edge and extends 2 feet under the slab.

Insulation type	R-0	R-5	R-10	R-15
	Unheated Slab			
Uninsulated slab	0.73			**
2-ft Horizontal (No thermal break)		0.70	0.70	0.69
4-ft Horizontal (No thermal break)		0.67	0.64	0.63
2-ft Vertical		0.58	0.54	0.52
4-ft Vertical		0.54	0.48	0.45
Fully insulated slab			0.36	
		Heated S	lah	1
Uninsulated slab	0.84			-
Fully insulated slab		0.74	0.55	0.44
R-5 Center (With perimeter insulation)			0.66	0.62
R-10 Center (With perimeter insulation)			-	0.51
3-ft Vertical			0.78	

TABLE 20-2 Default F-Factors for On-Grade Slabs

2004 Floors Over Unconditioned Space

2004.1 General: Tables 20-3, 20-4 and 20-4a list heat loss coefficients for floors over unconditioned spaces in units of $Btu/h \cdot ft^2 \cdot {}^{\circ}F$.

They are derived from procedures listed in standard RS-27, listed in Chapter 17, assuming an average outdoor temperature of 45°F, an average indoor temperature of 65°F, and a crawlspace area of 1350 ft² and 100 feet of perimeter. The crawlspace is assumed to be 2-1/2 feet high, with 24 inches below grade and 6 inches above grade.

2004.2 Category Description: Four configurations are considered: vented crawlspace, unvented crawlspace, heated plenum crawlspace and exposed floor.

Vented crawlspaces: Assumed to have 3.0 air changes per hour, with at least 1.0 ft² of net-free ventilation in the foundation for every 300 ft² of crawlspace floor area. The crawlspace is not actively heated.

Floors over unheated areas, such as garages, may only use those values which have R-0 perimeter insulation.

Unvented crawlspaces: Assumed to have 1.5 air changes per hour, with less than 1.0 ft² of net-free ventilation in the foundation for every 300 ft² of crawlspace floor area. The crawlspace is not actively heated. Floors over unheated basements may only use those values which have R-0 perimeter insulation.

Heated-plenum crawlspaces: Assumed to have 0.25 air changes per hour, with no foundation vents. Heated supply air from central furnace is blown into a crawlspace and allowed to enter the living space unducted via holes cut into the floor.

Exposed floors: Assumes no buffer space, and a covering of 1/2 inch of T1-11 on the exterior of the cavity exposed to the outside air or rigid insulation below a concrete floor, such as over parking garages.

2004.3 Construction Description: Floors are assumed to be either joisted floors framed on 16 inch centers, or post and beam on 4 foot by 8 foot squares. Insulation is assumed to be installed under the subflooring between the joists or beams with no space between the insulation and the subfloor. Insulation is assumed to be uncompressed. Exposed floors also include concrete with continuous rigid insulation assumed.

Perimeter insulation is assumed to extend from the top of the rim joist to the crawlspace floor and then inward along the ground (on top of the ground cover) for at least 24 inches.

Floor coverings are assumed to be light carpet with rubber pad.

TABLE 20-3

Default U-Factors for Floors Over Crawlspace or Unheated Basement

Nomina	I R-value	U-Factor		
Floor	Perimeter	Post & Beam	Joists	
0	0	0.112	0.134	
	11	0.100	0.116	
	19	0.098	0.114	
-	30	0.093	0.107	
11	0	0.052	0.056	
	11	0.048	0.052	
19	0	0.038	0.041	
	11 0.036		0.038	
22	0	0.034	0.037	
	11	0.033	0.035	
25	0	0.032	0.034	
	11	0.031	0.033	
30	0	0.028	0.029	
	11	0.027	0.028	
38	0	0.024	0.025	
	11	0.024	0.024	

TABLE 20-4 Default U-factors for Floors Over Heated Plenum Crawlspace

Nominal R-value Perimeter	U-Factor
11	0.085
19	0.075
30	0.069

Note: Crawlspaces used as heated plenums have approximately 30% higher heat loss rate than unvented crawlspaces with the same assumed ACH. Default U-factors in Table 20-4 reflect this higher rate of heat loss.

TABLE 20-4A Exposed Floors

Nominal	U-factor				
R-value	Concrete	Wood Joist	Metal Joist		
R-11	0.077	0.088	0.14		
R-15	0.059	0.076	0.12		
R-19	0.048	0.062	0.11		
R-21	0.043	0.057	0.11		
R-25	0.037	0.051	0.10		
R-30	0.031	0.040	0.09		
R-38	0.025	0.034	0.08		

168

2005 Above Grade Walls

2005.1 General: Tables 20-5, 20-5A and 20-5B list heat loss coefficients for the opaque portion of above-grade wood stud frame walls, metal stud frame walls and concrete masonry walls (Btu/h \cdot ft² \cdot °F) respectively. They are derived from procedures listed in Standard RS-27, listed in Chapter 17.

2005.2 Framing Description: For wood stud frame walls, three framing types are considered, and defined as follows:

Standard: Studs framed on 16 inch centers with double top plate and single bottom plate. Corners use 3 studs and each opening is framed using 2 studs. Headers consist of double 2X or single 4X material with an air space left between the header and the exterior sheathing. Interior partition wall/exterior wall intersections use two 2 in the exterior wall.

Standard framing weighting factors:

Studs and plates	0.19
Insulated cavity	0.77
Headers	0.04

Intermediate: Studs framed on 16 inch centers with double top plate and single bottom plate. Corners use 2 studs or other means of fully insulating corners, and each opening is framed by 2 studs. Headers consist of double 2X material with R-10 insulation between the header and exterior sheathing. Interior partition wall/exterior wall intersections are fully insulated in the exterior wall.

Intermediate framing weighting factors:

Studs and plates	0.18
Insulated cavity	0.78
Headers	0.04

Advanced: Studs framed on 24 inch centers with double top plate and single bottom plate. Corners use 2 studs or other means of fully insulating corners, and one stud is used to support each header. Headers consist of double 2X material with R-10 insulation between the header and exterior sheathing. Interior partition wall/exterior wall intersections are fully insulated in the exterior wall.

Advanced Framing Weighting Factors:

Studs and plates	0.13
Insulated cavity	0.83
Headers	0.04

2005.3 Component Description: For wood stud frame walls, default coefficients for three types of walls are listed: single-stud walls, strap walls and double-stud walls.

Single-Stud Wall: Assumes either 2x4 or 2x6 studs framed on 16 or 24 inch centers. Headers are solid for 2x4 walls and double 2X for 2x6 walls, with either dead-air or rigid-board insulation in the remaining space.

Strap Wall: Assumes 2x6 studs framed on 16 or 24 inch centers. 2x3 or 2x4 strapping is run horizontally along the interior surface of the wall to provide additional space for insulation.

Double-Stud Wall: Assumes an exterior structural wall and a separate interior, non-structural wall. Insulation is placed in both wall cavities and in the space between the 2 walls. Stud spacing is assumed to be on 24 inch centers for both walls.

TABLE 20-5 Default U-factors for Above-Grade Walls

2 x 4 Single Wood Stud: R-11 Batt

NOTE:

Nominal Batt R-value: R-11 at 3.5 inch thickness

Installed Batt R-value: R-11 in 3.5 inch cavity

Siding Material/Framing Type						
	Lappe	d Wood	T1	-11		
R-value of Foam Board	STD	ADV	STD	ADV		
0	0.088	0.084	0.094	0.090		
1	0.080	0.077	0.085	0.082		
2	0.074	0.071	0.078	0.075		
3	0.069	0.066	0.072	0.070		
4	0.064	0.062	0.067	0.065		
5	0.060	0.058	0.063	0.061		
6	0.056	0.055	0.059	0.057		
7	0.053	0.052	0.055	0.054		
8	0.051	0.049	0.052	0.051		
9	0.048	0.047	0.050	0.049		
10	0.046	0.045	0.047	0.046		
11	0.044	0.043	0.045	0.044		
12	0.042	0.041	0.043	0.042		

2 x 4 Single Wood Stud: R-13 Batt

NOTE: Nominal Batt R-value: R-13 at 3.63 inch thickness

Installed Batt R-value: R-12.7 in 3.5 inch cavity

Siding Material/Framing Type						
	Lappe	d Wood	T1-11			
R-value of Foam Board	STD ADV		STD	ADV		
0	0.082	0.078	0.088	0.083		
1	0.075	0.072	0.080	0.076		
2	0.069	0.066	0.073	0.070		
3	0.065	0.062	0.068	0.065		
4	0.060	0.058	0.063	0.061		
5	0.057	0.055	0.059	0.057		
6	0.053	0.052	0.056	0.054		
7	0.051	0.049	0.052	0.051		
8	0.048	0.047	0.050	0.048		
9	0.046	0.045	0.047	0.046		
10	0.044	0.043	0.045	0.044		
11	0.042	0.041	0.043	0.042		
12	0.040	0.039	0.041	0.040		

2 x 4 Single Wood Stud: R-15 Batt

NOTE: Nominal Batt R-value: R-15 at 3.5 inch thickness

Installed Batt R-value: R-15 in 3.5 inch cavity

Siding Material/Framing Type									
	Lapped	Wood	T1-11						
R-value	-								
of Foam									
Board	STD	ADV	STD	ADV					
0	0.076	0.071	0.081	0.075					
1	0.069	0.065	0.073	0.069					
2	0.064	0.061	0.068	0.069					
3	0.060	0.057	0.063	0.059					
4	0.056	0.053	0.059	0.056					
5	0.053	0.051	0.055	0.052					
6	0.050	0.048	0.052	0.050					
7	0.047	0.046	0.049	0.047					
8	0.045	0.044	0.047	0.045					
9	0.043	0.042	0.044	0.043					
10	0.041	0.040	0.042	0.041					
11	0.039	0.038	0.041	0.039					
12	0.038	0.037	0.039	0.038					

2 x 6 Single Wood Stud: R-19 Batt

	Siding Material/Framing Type						
		La	pped W	bod	T1-11		
NOTE:	R-value of Foam Board	STD	INT	ADV	STD	INT	ADV
Nominal Batt R-value:	0	0.062	0.058	0.055	0.065	0.061	0.058
R-19 at 6 inch thickness	1	0.058	0.055 -	0.052	0.060	0.057	0.055
	2	0.054	0.052	0.050	0.056	0.054	0.051
nstalled Batt R-value:	3	0.051	0.049	0.047	0.053	0.051	0.049
R-18 in 5.5 inch cavity	4	0.048	0.046	0.045	0.050	0.048	0.046
	5	0.046	0.044	0.043	0.048	0.046	0.044
	6	0.044	0.042	0.041	0.045	0.044	0.042
	7	0.042	0.040	0.039	0.043	0.042	0.040
	8	0.040	0.039	0.038	0.041	0.040	0.039
	9	0.038	0.037	0.035	0.039	0.038	0.037
	10	0.037	0.036	0.035	0.038	0.037	0.036
	11	0.036	0.035	0.034	0.036	0.035	0.035
	112	0.034	0.033	0.033	0.035	0.034	0.033



•

2 x 6 Single Wood Stud: R-21 Batt



.

NOTE: Nominal Batt R-value: R-21 at 5.5 inch thickness



Installed Batt R-value: R-21 in 5.5 inch cavity

Siding Material/Framing Type								
1. S.	La	pped We	boo		T1-11			
R-value of Foam Board	STD	INT	ADV	STD	INT	ADV		
0	0.057	0.054	0.051	0.060	0.056	0.053		
1	0.054	0.051	0.048	0.056	0.053	0.050		
2	0.050	0.048	0.045	0.052	0.050	0.047		
3	0.048	0.045	0.043	0.049	0.047	0.045		
4	0.045	0.043	0.041	0.047	0.045	0.043		
5	0.043	0.041	0.040	0.044	0.042	0.041		
6	0.041	0.039	0.038	0.042	0.041	0.039		
7	0.039	0.038	0.036	0.040	0.039	0.037		
8	0.038	0.036	0.035	0.039	0.037	0.036		
9	0.036	0.035	0.034	0.037	0.036	0.035		
10	0.035	0.034	0.033	0.036	0.035	0.033		
11	0.033	0.033	0.032	0.034	0.033	0.032		
12	0.032	0.031	0.031	0.033	0.032	0.031		

2 x 6 Single Wood Stud: R-22 Batt



Nominal Batt R-value: R-22 at 6.75 inch thickness

NOTE:

Installed Batt R-value: R-20 in 5.5 inch cavity

Siding Material/Framing Type									
	La	pped Wo	bod		T1-11				
R-value of Foam					INTE				
Board	STD	INT	ADV	STD	INI	ADV			
0	0.059	0.055	0.052	0.062	0.058	0.054			
1	0.055	0.052	0.049	0.057	0.054	0.051			
2	0.052	0.049	0.047	0.054	0.051	0.048			
3	0.049	0.046	0.044	0.050	0.048	0.046			
4	0.046	0.044	0.042	0.048	0.046	0.044			
5	0.044	0.042	0.041	0.045	0.043	0.042			
6	0.042	0.040	0.039	0.043	0.042	0.040			
7	0.040	0.039	0.037	0.041	0.040	0.038			
8	0.038	0.037	0.036	0.039	0.038	0.037			
9	0.037	0.036	0.035	0.038	0.037	0.035			
10	0.035	0.034	0.033	0.036	0.035	0.034			
11	0.034	0.033	0.032	0.035	0.034	0.033			
12	0.033	0.032	0.031	0.034	0.033	0.032			

2 x 6 Single Wood Stud: Two R-11 Batts

	Siding M	Siding Material/Framing Type							
	1	Lapped Wood			T1-11				
NOTE:	R-value of Foam Board	STD	INT	ADV	STD	INT	ADV		
Nominal Batt R-value:	0	0.060	0.057	0.054	0.063	0.059	0.056		
R-22 at 7 inch thickness	1	0.056	0.053	0.051	0.059	0.056	0.053		
	2	0.053	0.050	0.048	0.055	0.052	0.050		
Installed Batt R-value:	3	0.050	0.048	0.046	0.052	0.049	0.047		
R-18.9 in 5.5 inch cavity	4	0.047	0.045	0.044	0.049	0.047	0.045		
	5	0.045	0.043	0.042	0.046	0.045	0.043		
	6	0.043	0.041	0.040	0.044	0.043	0.041		
	7	0.041	0.040	0.038	0.042	0.041	0.039		
	8	0.039	0.038	0.037	0.040	0.039	0.038		
	9	0.038	0.037	0.036	0.039	0.038	0.036		
	10	0.036	0.035	0.034.	0.037	0.036	0.035		
	11	0.035	0.034	0.033	0.036	0.035	0.034		
	12	0.034	0.033	0.032	0.034	0.034	0.033		

2 x 8 Single Stud: R-25 Batt

	Siding Ma	Siding Material/Framing Type					
		La	pped W	ood		T1-11	
NOTE:	R-value of Foam Board	STD	INT	ADV	STD	INT	ADV
Iominal Batt R-value:	0	0.051	0.047	0.045	0.053	0.049	0.046
1-25 at 8 inch thickness	1	0.048	0.045	0.043	0.049	0.046	0.044
	2	0.045	0.043	0.041	0.047	0.044	0.042
nstalled Batt R-value:	3	0.043	0.041	0.039	0.044	0.042	0.040
1-23.6 in 7.25 inch cavity	4	0.041	0.039	0.037	0.042	0.040	0.038
	5	0.039	0.037	0.036	0.040	0.038	0.037
	6	0.037	0.036	0.035	0.038	0.037	0.036
	7	0.036	0.035	0.033	0.037	0.035	0.034
	8	0.035	0.033	0.032	0.035	0.034	0.033
	9	0.033	0.032	0.031	0.034	0.033	0.032
	10	0.032	0.031	0.030	0.033	0.032	0.031
	11	0.031	0.030	0.029	0.032	0.031	0.030
	12	0.030	0 029	0.028	0.031	0.030	0.029













2 x 6: Strap Wall

.

•

	Siding M	Siding Material/Frame Type					
	Lapped	d Wood	T1	-11			
	STD	ADV	STD	ADV			
R-19 + R-11 Batts	0.036	0.035	0.038	0.036			
R-19 + R-8 Batts	0.041	0.039	0.042	0.040			

2 x 6 + 2 x 4: Double Wood Stud

			Siding N	laterial/F	rame Typ	e
Batt Configuration		Lappe	Lapped Wood		-11	
Exterior	Middle	Interior	STD	ADV	STD	ADV
R-19		R-11	0.040	0.037	0.041	0.038
R-19		R-19	0.034	0.031	0.035	0.032
R-19	R-8	R-11	0.029	0.028	0.031	0.029
R-19	R-11	R-11	0.027	0.026	0.028	0.027
R-19	R-11	R-19	0.024	0.023	0.025	0.023
R-19	R-19	R-19	0.021	0.020	0.021	0.020

2 x 4 + 2 x 4: Double Wood Stud

			Sliding N	Aaterial/F	rame Typ	be
Batt Configuration		Lapped	Lapped Wood		-11	
Exterior	Middle	Interior	STD	ADV	STD	ADV
R-11		R-11	0.050	0.046	0.052	0.048
R-19		R-11	0.039	0.037	0.043	0.039
R-11	R-8	R-11	0.037	0.035	0.036	0.036
R-11	R-11	R-11	0.032	0.031	0.033	0.032
R-13	R-13	R-13	0.029	0.028	0.029	0.028
R-11	R-19	R-11	0.026	0.026	0.027	0.026

Log Walls

	Diameter, Inches	U-value
NOTE:		
R-value of wood:	6	0.148
R-1.25 per inch thickness	8	0.111
	10	0.089
Average wall thickness	12	0.074
90% average log diameter	14	0.063
	16	0.056

-

Stress Skin Panel

	Thickness, Inches	U-value
NOTE:		
R-value of expanded	3 1/2	0.071
polystyrene: R-3.85 per inch	5 1/2	0.048
	7 1/4	0.037
Framing: 6%	9 1/4	0.030
Spline: 8%	11 1/4	0.025

 Spline: 8%
 11 1/4
 0.025

 No thermal bridging between interior and exterior splines

Metal Stud Walls: The nominal R-values in Table 20-5A may be used for purposes of calculating metal stud wall section U-factors in lieu of the ASHRAE zone calculation method as provided in Chapter 22 of Standard RS-27.

TABLE 20-5A

Default U-Factors and Effective R-Values for Metal Stud Walls

0

OVERALL ASSEMBLY U-FACTORS FOR METAL STUD WALLS

Nominal Wall Thickness,	Nominal Insulation R-Value	Overall A U-Fa	ssembly ctors
Inches	ACCESSION OF A	16" O.C.	24" O.C.
4	R-11	0.14	0.13
4	R-13	0.13	0.12
4	R-15	0.12	0.11
6	R-19	0.11	0.10
6	R-21	0.11	0.09
8	R-25	0.10	0.09

EFFECTIVE R-VALUES FOR METAL STUD AND INSULATED CAVITY ONLY

Cavity		Insulation			
		Effective R-		R-value	
Nominal Depth, Inches	Actual Depth, Inches	Nominal R-Value	16" O.C.	24" O.C.	
4	3-1/2	R-11	5.5	6.6	
4	3-1/2	R-13	6.0	7.2	
4	3-1/2	R-15	6.4	7.8	
6	5-1/2	R-19	7,1	8.6	
6	5-1/2	R-21	7.4	9.0	
8	7-1/4	R-25	7.8	9.6	

Concrete Masonry Walls: The nominal R-values in Table 20-5B may be used for purposes of calculating concrete masonry wall section U-factors in lieu of the ASHRAE isothermal planes calculation method as provided in Chapter 22 of Standard RS-27.

TABLE 20-5B

Default U-Factors for Concrete and Masonry Walls

WALL DESCRIPTION	CORE TREATMENT			
	Partial Grout with Ungrouted Cores			
	Empty Loose-fill insulated Soli		Solid Grout	
		Perlite	Vermiculite	
Exposed Block, Both Sides	0.40	0.23	0.24	0.43
R-5 Interior Insulation, Wood Furring	0.14	0.11	0.12	0.15
R-6 Interior Insulation, Wood Furring	0.14	0.11	0.11	0.14
R-10.5 Interior Insulation, Wood Furring	0.11	0.09	0.09	0.11
R-8 Interior Insulation, Metal Clips	0.11	0.09	0.09	0.11
R-6 Exterior Insulation	0.12	0.10	0.10	0.12
R-10 Exterior Insulation	0.08	0.07	0.07	0.08
R-9.5 Rigid Polystyrene Integral				
Insulation, Two Webbed Block	0.11	0.09	0.09	0.12

8" CONCRETE MASONRY

12" CONCRETE MASONRY

WALL DESCRIPTION	CORE TREATMENT			
A DOWNER OF A DOWN	Partial Grout with Ungrouted Cores			
a construction of the second	Empty	Loose-fill insulated		Solid Grout
the second s		Perlite	Vermiculite	1.00
Exposed Block, Both Sides	0.35	0.17	0.18	0.33
R-5 Interior Insulation, Wood Furring	0.14	0.10	0.10	0.13
R-6 Interior Insulation, Wood Furring	0.13	0.09	0.10	0.13
R-10.5 Interior Insulation, Wood Furring	0.11	0.08	0.08	0.10
R-8 Interior Insulation, Metal Clips	0.10	0.08	0.08	0.09
R-6 Exterior Insulation	0.11	0.09	0.09	0.11
R-10 Exterior Insulation	0.08	0.06	0.06	0.08
R-9.5 Rigid Polystyrene Integral				
Insulation, Two Webbed Block	0.11	0.08	0.09	0.12



1994 FIRST EDITION

8" CLAY BRICK

WALL DESCRIPTION	CORE TREATMENT				
	Partial Grout with Ungrouted Cores			ALC: NOT THE OWNER OF	
	Empty	Loose-fill insulated		Solid Grout	
		Perlite	Vermiculite	CONTRACTOR	
Exposed Block, Both Sides	0.50	0.31	0.32	0.56	
R-5 Interior Insulation, Wood Furring	0.15	0.13	0.13	0.16	
R-6 Interior Insulation, Wood Furring	0.15	0.12	0.12	0.15	
R-10.5 Interior Insulation, Wood Furring	0,12	0.10	0.10	0.12	
R-8 Interior Insulation, Metal Clips	0.11	0.10	0.10	0.11	
R-6 Exterior Insulation	0.12	0.11	0.11	0.13	
R-10 Exterior Insulation	0.08	0.08	0.08	0.09	

6" CONCRETE POURED OR PRECAST

WALL DESCRIPTION	CORE TREATMENT				
	Partial Grout with Ungrouted Cores			1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	
	Empty	Loose-fill insulated		Solid Grout	
		Perlite	Vermiculite		
Exposed Concrete, Both Sides	NA	NA	NA	0.61	
R-5 Interior Insulation, Wood Furring	NA	NA	NA	0.16	
R-6 Interior Insulation, Wood Furring	NA	NA	NA	0.15	
R-10.5 Interior Insulation, Wood Furring	NA	NA	NA	0.12	
R-8 Interior Insulation, Metal Clips	NA	NA	NA	0.12	
R-6 Exterior Insulation	NA	NA	NA	0.13	
R-10 Exterior Insulation	NA	NA	NA	0.09	



- Grouted cores at 40" x 48" on center vertically and horizontally in partial grouted walls.
- 2. Interior insulation values include 1/2" gypsum board on the inner surface.
- Furring and stud spacing is 16" on center. Insulation is assumed to fill furring space and is not compressed.
- Intermediate values may be interpolated using this table. Values not contained in this table may be computed using the procedures listed in Standard RS-27.



1



2006 Default U-Factors for Glazing and Doors

2006.1 Untested Glazing and Doors: Untested glazing and doors shall be assigned the following U-factors:

TABLE 20-6

Default U-Factors for Vertical Glazing, Overhead Glazing and Opaque Doors

Vertical Glazing

	U-Factor
Single	1.45.
Double	0.90
1/2 Inch Air, Fixed	0.75
1/2 Inch Air, Low-e ^(0.40) , Fixed	0.60
1/2 Inch Argon, Low-e ^(0.10) , Fixed	0.50

Overhead Glazing

	U-Fa	U-Factor		
1 () () () () () () () () () (Any Frame	Vinyl/Wood Frame		
Single	2.15	2.15		
Double	1.45	1.00		
Low-e(0.40) or Argon	1.40	0.95		
$Low-e^{(0.40)} + Argon$	1.30	0.85		
Low-e(0.20) Air	1.30	0.90		
Low-e ^(0.20) + Argon	1.25	0.80		
Triple	1.25	0.80		

Opaque Doors

	U-Factor
Uninsulated Metal	1.20
Insulated Metal (Including Fire Door and Smoke Vent)	0.60
Wood	0.50

NOTES:

Where a gap width is listed (i.e.: 1/2 inch), that is the minimum allowed.

Where a low-emissivity emittance is listed (i.e.: 0.40, 0.20, 0.10), that is the maximum allowed. Where a gas other than air is listed (i.e.: argon), the gas fill shall be a minimum of 90%. Where an operator type is listed (i.e.: fixed), the default is only allowed for that operator type. Where a frame type is listed (i.e.: wood/vinyl), the default is only allowed for that frame type. Wood/Vinyl frame includes reinforced vinyl and aluminum-clad wood.

1994 FIRST EDITION

2007 Ceilings

2007.1 General: Table 20-7 lists heat loss coefficients for the opaque portion of exterior ceilings below vented attics, vaulted ceilings and roof decks in units of Btu/h \cdot ft² \cdot °F of ceiling.

They are derived from procedures listed in Standard RS-27, listed in Chapter 17. Ceiling U-factors are modified for the buffering effect of the attic, assuming an indoor temperature of 65 °F and an outdoor temperature of 45 °F.

2007.2 Component Description: The three types of ceilings are characterized as follows:

Ceilings Below a Vented Attic: Attic insulation is assumed to be blown-in, loose-fill fiberglass with a K-value of 2.6 ($h \cdot ft^2 \cdot {}^\circ$ F)/Btu per inch. Full bag count for specified R-value is assumed in all cases. Ceiling dimensions for flat ceiling calculations are 45 by 30 feet, with a gabled roof having a 4/12 pitch. The attic is assumed to vent naturally at the rate of 3.0 air changes per hour through soffit and ridge vents. A void fraction of 0.002 is assumed for all attics with insulation baffles. Standard-framed, unbaffled attics assume a void fraction of 0.008.

Attic framing is either standard or advanced. Standard framing assumes tapering of insulation depth around the perimeter with resultant decrease in thermal resistance. An increased R-value is assumed in the center of the ceiling due to the effect of piling leftover insulation. Advanced framing assumes full and even depth of insulation extending to the outside edge of exterior walls. Advanced framing does not change from the default value.

U-factors for flat ceilings below vented attics with standard framing may be modified with the following table:

<u>30 R-38</u>
0.031
0.030
0.029
0.029
0.028
0.028
0.028
0.027
0.027

Vented scissors truss attics assume a ceiling pitch of 2/12 with a roof pitch of either 4/12 or 5/12. Unbaffled standard framed scissors truss attics are assumed to have a void fraction of 0.016.

Vaulted Ceilings: Insulation is assumed to be fiberglass batts installed in roof joist cavities. In the vented case, at least 1.5 inches between the top of the batts and the underside of the roof sheathing is left open for ventilation in each cavity. A ventilation rate of 3.0 air changes per hour is assumed. In the unvented or dense pack case, the ceiling cavity is assumed to be fully packed with insulation, leaving no space for ventilation.

Roof Decks: Rigid insulation is applied to the top of roof decking with no space left for ventilation. Roofing materials are attached directly on top of the insulation. Framing members are often left exposed on the interior side.

Ceilings Below Vented Attics	Standard Frame	Advanced Frame	
Flat Ceiling	Baffled		
R-19	0.049	0.047	
R-30	0.036	0.032	
R-38	0.031	0.026	
R-49	0.027	0.020	
R-60	0.025	0.017	
Scissors Truss			
R-30 (4/12 roof pitch)	0.043	0.031	
R-38 (4/12 roof pitch)	0.040	0.025	
R-49 (4/12 roof pitch)	0.038	0.020	
R-30 (5/12 roof pitch)	0.039	0.032	
R-38 (5/12 roof pitch)	0.035	0.026	
R-49 (5/12 roof pitch)	0.032	0.020	

TABLE 20-7 Default U-factors for Ceilings

Vaulted Ceilings	16" O.C.	24" O.C.	
Vented			
R-19 2x10 joist	0.049	0.048	
R-30 2x12 joist	0.034	0.033	
R-38 2x14 joist	0.027	0.027	
Unvented			
R-30 2x10 joist	0.034	0.033	
R-38 2x12 joist	0.029	0.027	
R-21 + R-21 2x12 joist	0.026	0.025	

182

TABLE 20-7 (Continued) Default U-factors for Ceilings

Roof Deck	U-factor
R-15 Rigid Insulation	0.063
R-21 Rigid Insulation	0.045
R-25 Rigid Insulation	0.038
R-30 Rigid Insulation	0.032
R-38 Rigid Insulation	0.025
R-50 Rigid Insulation	0.019

2008 (Reserved)

2009 Mass

.

•

2009.1 General: Table 20-10 lists default mass values for concrete masonry construction. Calculations are based on standard ASHRAE values for heat-storage capacity as listed in Standard RS-27, Chapter 22.

TABLE 20-10 HEAT CAPACITY

	Partial Grout	Solid Grout			
8" CMU	9.65	15.0			
12" CMU	14.5	23.6			
8" Brick	10.9	16.4			
6" Concrete	NA	14.4			



APPENDIX

.

•

•

•

•

REFERENCE STANDARD 29 (RS-29)

COMMERCIAL BUILDING DESIGN BY SYSTEMS ANALYSIS



REFERENCE STANDARD

COMMERCIAL BUILDING DESIGN BY SYSTEMS ANALYSIS

SECTION 1 SCOPE
1.1 General
SECTION 2 - GENERAL PRINCIPLES AND REQUIREMENTS.1
2.1 Energy Analysis
2.2 Design
2.4 Calculation Procedure
2.5 Documentation
SECTION 3 SPECIFIC MODELING ASSUMPTIONS4
3.1 Orientation and Shape
3.2 I Decurrance
3.2.2.1 Occupancy
3.2.3 Receptacle
3.3 Envelope
3.3.1 Insulation and Glazing5
3.3.2 Infiltration5
3.3.3 Envelope and Ground Absorptivities
3.3.4 Window Treatment
3.3.5 Shading
3.4 HVAC Systems and Equipment
3.4.1 HVAC Zones
3 4 3 HVAC Equipment Sizing
3.4.4 Variable Speed
3.5 Service Water Heating
3.6 Controls
3.6.1
3.6.2
3.6.3
3.6.4
TABLE 3-1 - Acceptable Occupancy Densities, Receptacle
Power Densities and Service Hot Water Consumption9
TABLE 3-2A Assembly Occupancy
TABLE 3-2B Health Occupancy 11
TABLE 3-2C Hotel/Motel Occupancy 12
TABLE 3-2D Light Manufacuring Occupancy
TABLE 3-2E Office Occupancy
TABLE 3-2F Parking Garage Occupancy 15

i

TABLE 3-2G Restaurant Occupancy	16					
TABLE 3-2H Retail Occupancy	. 17					
TABLE 3-2I School Occupancy	. 18					
TABLE 3-2J Warehouse Occupancy						
TABLE 3-3 HVAC Systems of Prototype Buildings	. 20					
TABLE 3-3 (cont.) HVAC System Descriptions for Prototype Buildings	. 21					
TABLE 3-3 (cont.) HVAC System Descriptions for Prototype Buildings	. 22					
SECTION 4 SUGGESTED SOFTWARE FOR SYSTEMS ANALYSIS APPROACH	. 24					
Full-Year Hourly Analysis						
4.2 Programs only Acceptable for Commercial Buildings 25,000 Square Feet or Less	. 25					

1994 Edition

REFERENCE STANDARD COMMERCIAL BUILDING DESIGN BY SYSTEMS ANALYSIS

SECTION 1 - SCOPE

1.1 General: This Standard establishes design criteria in terms of total energy consumption of a building, including all of its systems. General principles and requirements are outlined in Section 2. Specific modeling assumptions are listed in Section 3.

The building permit application for projects utilizing this Standard shall include in one submittal all building and mechanical drawings and all information necessary to verify that the design for the project corresponds with the annual energy analysis. If credit is proposed to be taken for lighting energy savings, then electrical drawings shall also be included with the building permit application.

Due to the various assumptions that are necessary, the results of the analysis shall not be construed as a guarantee of the actual energy performance of the project.

SECTION 2 - GENERAL PRINCIPLES AND REQUIREMENTS

2.1 Energy Analysis: Compliance with this Standard will require an analysis of the annual energy usage, hereinafter called an annual energy analysis.

A building designed in accordance with this Standard will be deemed as complying with this Code, if

 The calculated annual energy consumption is not greater than that of a corresponding "standard design," as defined below and in Section 3,

and;

b. Whose enclosure elements and energy-consuming systems comply with Sections 1310 through 1314, 1410 through 1415, 1440 through 1442, 1450 through 1454 and 1510 through 1513. Buildings shall only vary from those requirements in Sections 1330 through 1334, 1432 through 1438 and 1530 through 1532 where those variations have been accurately and completely modeled. Where variations are not specifically analyzed, the building shall comply with these requirements.

Systems Analysis

For a proposed building design to be considered similar to a "standard design," it shall utilize the same energy source(s) for the same functions and have equal floor area and the same ratio of envelope area to floor area, environmental requirements, occupancy, climate data and usage operational schedule. Inputs to the energy analysis relating to occupancy and usage shall correspond to the expected occupancy and usage of the building.

Except as noted below, the systems identified, and, to the extent possible, the assumptions made in assigning energy inputs to each system, shall be the same for the standard design and the proposed design. When electrically driven heat pumps, other than multiple units connected to a common water loop, are employed to provide all or part of the heat for the proposed design, the standard design shall also, for the purposes of the analysis, assume that electrically driven heat pump, in conformance with Chapter 14 of the Code and having capacity at least as great as those used in the proposed design are employed.

2.2 Design: The standard design and the proposed design shall be designed on a common basis as specified herein:

- a. The comparison shall be expressed as kBtu input per square foot of conditioned floor area per year at the building site. Buildings which use electricity as the only fuel source, comparisons may be expressed in kWh. When converting electricity in kWh to kBtu a multiplier of 3.413 kWh/kBtu shall be used.
- b. If the proposed design results in an increase in consumption of one energy source and a decrease in another energy source, even though similar sources are used for similar purposes, the difference in each energy source shall be converted to equivalent energy units for purposes of comparing the total energy used.

2.3 Analysis Procedure: The analysis of the annual energy usage of the standard and the proposed building and system design shall meet the following criteria:

- a. The building heating/cooling load calculation procedure used for annual energy consumption analysis shall be detailed to permit the evaluation of effect of factors specified in Section 2.4.
- b. The calculation procedure used to simulate the operation of the building and its service systems through a full-year operating period shall be detailed to permit the evaluation of the effect of system design, climatic factors, operational characteristics and mechanical equipment on annual energy usage. Manufacturer's data or comparable field test data shall be used when available in the simulation of systems and equipment. The calculation procedure shall be based upon 8,760 hours of operation of the building and its service systems and shall utilize the design methods, specified in Standards RS-27, -11, -12 and -13 listed in Chapters 7 and 17 of the Code or in other programs approved by the building official.

2.4 Calculation Procedure: The calculation procedure shall cover the following items:

- a. Design requirements--Design heating conditions and design cooling conditions as defined in Chapter 12 of the Code.
- Climatic data—Coincident hourly data for temperatures, solar radiation, wind and humidity of typical days in the year representing seasonal variation.
- c. Building data--Orientation, size, shape, mass, air and heat transfer characteristics.
- Operational characteristics--Temperature, humidity, ventilation, illumination and control mode for occupied and unoccupied hours.
- e. Mechanical equipment--Design capacity and part load profile.
- Building loads--Internal heat generation, lighting, equipment and number of people during occupied and unoccupied periods.

Exception: Proposed designs having an area of 25,000 square feet or less are exempt from the full-year energy analysis described in Section 2.3(b). However, comparison of energy consumption between the proposed design and the standard design shall be provided based on one of the programs suggested in Section 4.2 for these buildings.

2.5 Documentation: All analyses submitted shall be accompanied by an energy analysis comparison report. The report shall provide technical detail on the two building and system designs and on the data used in and resulting from the comparative analysis to verify that both the analysis and the designs meet the criteria of Section 1.

The calculation procedure for the standard design and the proposed design shall separately identify the calculated annual energy consumption for each different occupancy type, if possible, for each of the following end uses:

- a. Interior lighting;
- b. Parking lighting;
- c. Exterior lighting;
- d. Space heating:
- e. Space cooling;
- f. Interior ventilation/fans;
- g. Parking ventilation/fans;
- h. Exhaust fans;
- i. Service water heating;
- j. Elevators;
- k. Appliances.

Energy consumption of the following items shall be included but is not required to be separated out by each individual item.

- a. Office equipment;
- b. Refrigeration other than comfort cooling;
- c. Cooking; and
- d. Any other energy-consuming equipment.

The specifications of the proposed building project used in the analysis shall be as similar as is reasonably practical to those in the plans submitted for a building permit.



Systems Analysis

SECTION 3 -- SPECIFIC MODELING ASSUMPTIONS

The specific modeling assumptions consist of methods and assumptions for calculating the standard energy consumption for the standard building and the proposed energy consumption of the proposed design. In order to maintain consistency between the standard and the proposed design energy consumptions, the input assumptions in this section shall be used.

"Prescribed" assumptions shall be used without variation. "Default" assumptions shall be used unless the designer can demonstrate that a different assumption better characterizes the building's use over its expected life. Any modification of a default assumption shall be used in modeling both the standard building and the proposed design unless the designer demonstrates a clear cause to do otherwise.

3.1 Orientation and Shape: The standard building shall consist of the same number of stories and gross floor area for each story as the proposed design. Each floor shall be oriented exactly as the proposed design. The geometric form shall be the same as the proposed design.

3.2 Internal Loads: Internal loads shall be modeled as noted in the following parts of Section 3.2. The systems specified for calculating the standard energy consumption in Section 3.2 are intended only as constraints in calculating the consumption. They are not intended as requirements or recommendations for systems to be used in the proposed building or for the calculation of the proposed energy consumption.

3.2.1 Occupancy: Occupancy schedules shall be default assumptions. The same assumptions shall be made in computing proposed energy consumption as were used in calculating the standard energy consumption. Occupancy levels vary by building type and time of day. Table 3-1 establishes the density presented as ft^2 /person of conditioned floor area that will be used by each building type. Table 3-2 establishes the percentage of the people that are in the building by hours of the day for each building type.

3.2.2 Lighting: The interior and exterior lighting power allowance for calculating the standard energy consumption shall be determined from Sections 1531 and 1532. The lighting power used to calculate the proposed energy consumption shall be the actual lighting power of the proposed lighting design. Exempt lighting in the standard design shall be equal to the exempt lighting in the proposed design.

Lighting levels in buildings vary based on the type of uses within buildings, by area and by time of day. Table 3-2 contains the lighting energy profiles which establish the percentage of the lighting load that is switched ON in each prototype or reference building by hour of the day. These profiles are default assumptions and can be changed if required when calculating the standard energy consumption to provide, for example, a 12 hour rather than an 8 hour work day or to reflect the use of automatic lighting controls. The lighting schedules used in the standard and proposed designs shall be identical and shall reflect the type of controls to be installed in the proposed design. The controls in the proposed design shall comply with the requirements in Section 1513 and no credit shall be given for the use of any additional controls, automatic or otherwise.

3.2.3 Receptacle: Receptacle loads and profiles are default assumptions. The same assumptions shall be made in calculating proposed energy consumption as were used in calculating the standard energy consumption. Receptacle loads include all general service loads that are typical in a building. These loads should include additional process electrical usage but exclude HVAC primary or auxiliary electrical usage. Table 3-1 establishes the density in W/ft² to be used. The receptacle energy profiles shall be the same as the lighting energy profiles in Table 3-2. This profile establishes the percentage of the receptacle load that is switched ON by hour of the day and by building type.

3.3 Envelope

3.3.1 Insulation and Glazing: Glazing area and U-factor of the standard building envelope shall be determined by using the Target UA requirements of Equation 13-1 and U-factor values in Table 13-1 or 13-2. The glazing solar heat gain coefficient (SHGC) or shading coefficient of the standard building shall be the lesser of 0.65 and the SHGC required by Table 13-1 or 13-2 for the vertical or overhead glazing area for the appropriate wall type. The opaque area U-factors of the standard building shall be determined by using the Target UA requirements from Equation 13-1 including the appropriate mass for walls. The insulation characteristics and glazing area are prescribed assumptions for the standard building for calculating the standard energy consumption. In the calculation of the proposed energy consumption of the proposed design, the envelope characteristics of the proposed design shall be used. The standard design shall use the maximum glazing areas listed in Tables 13-1 or 13-2 for the appropriate use. The distribution of vertical glazing in the gross wall area of the standard design shall be equal to the distribution of vertical glazing in the proposed design or shall constitute an equal percentage of gross wall area on all sides of the standard building. The distribution of overhead glazing in the gross roof/ceiling area of the standard design shall be equal to the distribution of overhead glazing in the proposed design. The distribution of doors in the gross opaque wall area of the standard design shall be identical to the distribution of doors in the proposed design.

3.3.2 Infiltration: For standard and proposed buildings, infiltration assumptions shall be equal.

3.3.3 Envelope and Ground Absorptivities: For the standard building, absorptivity assumptions shall be default assumptions for computing the standard energy consumption and default assumptions for computing the proposed energy consumption. The solar absorptivity of opaque elements of the building envelope shall be assumed to be 70%. The solar absorptivity of ground surfaces shall be assumed to be 80% (20% reflectivity).

Systems Analysis

3.3.4 Window Treatment: No draperies or blinds shall be modeled for the standard or proposed building.

3.3.5 Shading: For standard building and the proposed design, shading by permanent structures and terrain shall be taken into account for computing energy consumption whether or not these features are located on the building site. A permanent fixture is one that is likely to remain for the life of the proposed design. Credit may be taken for external shading devices that are part of the proposed design.

3.4 HVAC Systems and Equipment: For the standard building, the HVAC system used shall be the system type used in the proposed design. If the proposed HVAC system type does not comply with Sections 1432 through 1438, the standard design system shall comply in all respects with those sections.

Exception: When approved by the building official, a prototype HVAC system may be used, if the proposed design system cannot be modified to comply with Sections 1422 and 1432 through 1438, as a standard design. Use of prototype HVAC systems shall only be permitted for the building types listed below. For mixed-use buildings, the floor space of each building type is allocated within the floor space of the standard building. The specifications and requirements for the HVAC systems of prototype buildings shall be those in Table 3-3.

- 1. assembly
- 2. health/institutional
- 3. hotel/motel
- 4. light manufacturing
- 5. office (business)
- 6. restaurant
- 7. retail (mercantile)
- 8. school (educational)
- 9. warehouse (storage)

3.4.1 HVAC Zones: HVAC zones for calculating the standard energy consumption and proposed energy consumption shall consist of at least four perimeter and one interior zone per floor, with at least one perimeter zone facing each orientation. The perimeter zones shall be fifteen feet in width or one-third the narrow dimension of the building when this dimension is between 30 and 45 feet inclusive or half the narrow dimension of the building when this dimension is less than 30 feet.

Exceptions:

- Building types such as assembly or warehouse may be modeled as a single zone if there is only one space.
- Thermally similar zones, such as those facing one orientation on different floors, may be grouped together for the purposes of either the standard or proposed building simulation.

3.4.2 Process Equipment Sizing: Process sensible and latent loads shall be equal in calculating both the standard energy consumption and the proposed energy consumption. The designer shall document the installation of process equipment and the size of process loads.

3.4.3 HVAC Equipment Sizing: The equipment shall be sized to include the capacity to meet the process loads. For calculating the proposed energy consumption, actual air flow rates and installed equipment size shall be used in the simulation. Equipment sizing in the simulation of the proposed design shall correspond to the equipment intended to be selected for the design and the designer shall not use equipment sized automatically by the simulation tool.

Equipment sizing for the standard design shall be based on the same as the proposed design or lesser sizing ratio of installed system capacity to the design load for heating and for cooling.

Chilled water systems for the standard building shall be modeled using a reciprocating chiller for systems with total cooling capacities less than 175 tons, and centrifugal chillers for systems with cooling capacities of 175 tons or greater. For systems with cooling capacities of 600 tons or more the standard energy consumption shall be calculated using two centrifugal chillers, lead/lag controlled. Chilled water shall be assumed to be controlled at a constant 44°F temperature rise, from 44°F to 56°F, operating at 65% combined impeller and motor efficiency. Condenser water pumps shall be sized using a 10°F temperature rise, operating at 60% combined impeller and motor efficiency. The cooling tower shall be an open circuit, centrifugal blower type sized for the larger of 85°F leaving water temperature or 10°F approach to design wetbulb temperature. The tower shall be controlled to provide a 65°F leaving water temperature whenever weather conditions permit, floating up to design leaving water temperature at design conditions.

3.4.4 Variable Speed: The energy of the combined fan system per air volume at design conditions (w/cfm) of the proposed design shall be equal to that of the standard design. Variable air volume fan systems in the standard building shall be variable speed.

3.5 Service Water Heating: The service water heating loads for prototype buildings are defined in terms of Btu/person-hour in Table 3-1. The values in the table refer to energy content of the heated water. The service water heating loads from Table 3-1 are default for all buildings. The same service-water-heating load assumptions shall be made in calculating proposed energy consumption as were used in calculating the standard energy consumption. The service water heating system for the standard building shall be modeled as closely as possible as if it were designed in accordance with the ASHRAE Handbook, 1987 HVAC Systems and Applications Volume and meeting all the requirements of Sections 1440 through 1442.

3.6 Controls

3.6.1: All occupied conditioned spaces in standard and proposed design buildings in all climates shall be simulated as being both heated and cooled.

Systems Analysis

Exceptions:

- If a building or portion of a building is to be provided with only heating or cooling, both the standard building and the proposed design shall be simulated using the same assumptions.
- If warehouses are not intended to be mechanically cooled, both the standard and proposed energy consumption shall be modeled assuming no mechanical cooling.

3.6.2: Space temperature controls for the standard building, shall be set at 70°F for space heating and 75°F for space cooling, with a deadband in accordance with Section 1412.2. The system shall be OFF during off-hours according to the appropriate schedule in Table 3-2, except that the heating system shall cycle ON if any space should drop below the night setback setting 55°F. There shall be no similar setpoint during the cooling season. Lesser deadband ranges may be used in calculating the proposed energy consumption.

Exceptions:

- Setback shall not be modeled in determining either the standard or proposed energy consumption if setback is not realistic for the proposed design such as a facility being operated 24 hours/day. For instance, health facilities need not have night setback during the heating season.
- If deadband controls are not to be installed, the proposed energy consumption shall be calculated with both heating and cooling thermostat setpoints set to the same value between 70°F and 75°F inclusive, assumed to be constant for the year.

•

3.6.3: When providing for outdoor air ventilation when calculating the standard energy consumption, controls shall be assumed to close the outside air intake to reduce the flow of outside air to 0.0 cfm during "setback" and "unoccupied" periods. Ventilation using inside air may still be required to maintain scheduled setback temperature. Outside air ventilation, during occupied periods, shall be as required by the Washington State Ventilation and Indoor Air Quality Code (WAC 51-13).

3.6.4: If humidification is to be used in the proposed design, the same level of humidification and system type shall be used in the standard building.

Building Type	Occupancy Density ² Sq. Ft./Person (Btu/h·ft ²)	Receptable Power Density ³ Watts/Sq. Ft. (Btu/h·ft ²)	Service Hot Water Quantities ⁴ Btu/h-person		
Assembly	50 (4.60)	0.25 (0.85)	215		
Health/Institutional	200 (1.15)	1.00 (3.41)	135		
Hotel/Motel	250 (0.92)	0.25 (0.85)	1,110		
Light Manufacturing	750 (0.31)	0.20 (0.68)	225		
Office	275 (0.84)	0.75 (2.56)	175		
Parking Garage	N.A.	N.A.	N.A.		
Restaurant	100 (2.30)	0.10 (0.34)	390		
Retail	300 (0.77)	0.25 (0.85)	135		
School	75 (3.07)	0.50 (1.71)	215		
Warehouse	15,000 (0.02)	0.10 (0.34)	225		

TABLE 3-1 Acceptable Occupancy Densities, Receptacle Power Densities and Service Hot Water Consumption¹

 The occupancy densities, receptacle power densities and service hot water consumption values are from ASHRAE Standard 90.1-1989 and addenda.

 Values are in square feet of conditioned floor area per person. Heat generation in Btu per person per hour is 230 sensible and 190 latent. Figures in parentheses are equivalent Btu per hour per square foot.

3. Values are in Watts per square foot of conditioned floor area. Figures in parentheses are equivalent Btu per hour per square foot. These values are the minimum acceptable. If other process loads are not input (such as for computers, cooking, refrigeration, etc.), it is recommended that receptacle power densities be increased until total process energy consumption is equivalent to 25% of the total.

4. Values are in Btu per person per hour.

9

	Scl	redule ccupan	for	Sch L Re	iedule lightin ceptad	for g :le	Schedule for HVAC System			Schedule for Service Hot Water			Schedule for Elevator		
Hour of	P	ercent	of	Pe	ercent	of	Part and a		Percent of			Percent of			
Day	Max	imum	Load	Maxi	mum	Load	4.0		-	Maxi	mum	Load	Maxi	mum	Load
(time)	Wk	Sat	Sun	Wk	Sat	Sun	Wk	Sat	Sun	Wk	Sat	Sun	Wk	Sat	Sun
1 (12-1am)	0	0	0	5	5	5	off	off	off	0	0	0	0	0	0
2 (1-2am)	0	0	0	5	5	5	off	off	off	0	0	0	0	0	0
3 (2-3am)	0	0	0	5	5	5	off	off	off	0	0	0	0	0	0
4 (3-4am)	0	0	0	5	5	5	off	off	off	0	0	0	0	0	0
5 (4-5am)	0	0	0	5	5	5	off	off	off	0	0	0	0	0	0
6 (5-6am)	0	0	0	5	5	5	on	off	off	0	0	0	0	0	0
7 (6-7am)	0	0	0	40	5	5	on	on	on	0	0	0	0	0	0
8 (7-8am)	0	0	0	40	30	30	on	on	on	0	0	0	0	0	0
9 (8-9am)	20	20	10	40	30	30	on	on	on	0	0	0	0	0	0
10 (9-10am)	20	20	10	75	50	30	on	on	on	5	5	5	0	0	0
11 (10-11am)	20	20	10	75	50	30	on	on	on	5	5	5	0	0	0
12 (11-12pm)	80	60	10	75	50	30	on	on	on	35	20	10	0	0	0
13 (12-1pm)	80	60	10	75	50	65	on	on	on	5	0	0	0	0	0
14 (1-2pm)	80	60	70	75	50	65	on	on	on	5	0	0	0	0	0
15 (2-3pm)	80	60	70	75	50	65	ол	on	on	5	0	0	0	0	0
16 (3-4pm)	80	60	70	75	50	65	on	on	on	5	0	0	0	0	0
17 (4-5pm)	80	60	70	75	50	65	on	on	on	5	0	0	0	0	0
18 (5-6pm)	80	60	70	75	50	65	on	on	on	0	0	0	0	0	0
19 (6-7pm)	20	60	70	75	50	65	on	on	on	0	0	0	0	0	0
20 (7-8pm)	20	60	70	75	50	65	on	OR	on	0	65	65	0	0	0
21 (8-9pm)	20	60	70	75	50	65	on	on	on	0	30	30	0	0	0
22 (9-10pm)	20	80	70	75	50	65	on	on	on	0	0	0	0	0	0
23 (10-11pm)	10	10	20	25	50	5	on	on	on	0	0	0	0	0	0
24 (11-12am)	0	0	0	5	5	5	off	off	off	0	0	0	0	0	0
Total/Day	710	750	700	1155	800	845	1800	1700	1700	70	125	115	0	0	0
Total/Week		50.50	hours		74.20	hours		124	hours		5.9	hours		0	hours
Total/Year	-	2633	hours	-	3869	hours		6465	hours		308	hours	-	0	hours

TABLE 3-2A Assembly Occupancy¹

Wk = Weekday

 Schedules for occupancy, lighting, receptacle, HVAC system and service hot water are from ASHRAE Standard 90.1-1989 and addendums, except that 5% emergency lighting has been added for all off hours. Elevator schedules, except for restaurants, are from the U.S. Department of Energy Standard Evaluation Techniques except changed to 0% when occupancy is 0%. THESE VALUES MAY BE USED ONLY IF ACTUAL SCHEDULES ARE NOT KNOWN.

•
TABLE 3-2B Health Occupancy¹

		Sc	hedule	for ncy	Sc	hedule Lightin ecepta	for ng icle	Sc HV	heduk AC Sy	for stem	S	chedule ervice Wate	for Hot	Sc	hedule Elevat	or
H	our of Day	Max	cimum	Load	May	imum	Load				Ma	rercent	lond	Mar	ercent	lond
1	(time)	Wk	Sat	Sun	Wk	Sat	Sun	Wk	Sat	Sun	Wk	Sat	Sun	Wk	Sat	Sun
1	(12-1am)	0	0	0	10	10	5	on	on	00	1	1	1	0	0	0
2	(1-2am)	0	0	0	10	10	5	on	on	on	li	- i	1	0	0	0
3	(2-3am)	0	0	0	10	10	5	on	on	on	li	i	i	0	0	0
4	(3-4am)	0	0	0	10	10	5	on	on	on	1	1	î.	0	0	0
5	(4-5am)	0	0	0	10	10	5	on	on	OT	li	1	1	0	0	0
6	(5-6am)	0	0	0	10	10	5	on	on	on	i	1	1	0	0	0
7	(6-7am)	0	0	0	10	10	5	on	on	on	1	1	1	0	0	0
8	(7-8am)	10	10	0	50	20	5	on	on	on	17	1	1	2	2	0
9	(8-9am)	50	30	5	90	40	10	on	on	on	58	20	1	75	46	2
10	(9-10am)	80	40	5	90	40	10	on	on	on	66	28	1	100	70	2
11	(10-11am)	80	40	5	90	40	10	on	on	on	78	30	1	100	70	2
12	(11-12pm)	80	40	5	90	40	10	on	on	on	82	30	1	100	70	2
13	(12-1pm)	80	40	5	90	40	10	on	OB	on	71	24	1	75	51	2
14	(1-2pm)	80	40	5	90	40	10	on	on	on	82	24	1	100	51	2
15	(2-3pm)	80	40	5	90	40	10	on	on	ол	78	23	1	100	51	2
16	(3-4pm)	80	40	5	90	40	10	on	on	on	74	23	1	100	51	2
17	(4-5pm)	80	40	0	30	40	5	on	on	on	63	23	1	100	51	0
18	(5-6pm)	50	10	0	30	40	5	on	on	on	41	10	1	100	25	0
19	(6-7pm)	30	10	0	30	10	5	on	on	on	18	1	1	.52	2	0
20	(7-8pm)	30	0	0	30	10	5	on	on	on	18	1	1	52	0	0
21	(8-9pm)	20	0	0	30	10	5	on	on	on	18	1	1	52	0	0
22	(9-10pm)	20	0	0	30	10	5	on	on	on	10	1	1	28	0	0
23	(10-11pm)	0	0	0	30	10	5	on	on	on	1	1	1	0	0	0
24	(11-12am)	0	0	0	10	10	5	on	on	on	1	1	1	0	0	0
Tot	al/Day	850	380	40	1060	550	160	2400	2400	2400	783	249	24	1136	540	16
Tol	al/Week		46.70	hours		60.10	hours		168	hours		41.88	hours		62.36	hours
Tot	al/Year		2435	hours		3134	hours		8760	hours		2148	hours		3251	hours

Wk = Weekday

•

1

•

 Schedules for occupancy, lighting, receptacle, HVAC system and service hot water are from ASHRAE Standard 90.1-1989 and addendums, except that 5% emergency lighting has been added for all off hours. Elevator schedules, except for restaurants, are from the U.S. Department of Energy Standard Evaluation Techniques except changed to 0% when occupancy is 0%. THESE VALUES MAY BE USED ONLY IF ACTUAL SCHEDULES ARE NOT KNOWN.

	Sche	edule f	or y	Sch L Re	edule f ighting ceptac	or	Scho HVA	edule f C Syst	or tem	Sch	edule f vice H Water	or	Sch	edule f levator	or
	Per	rcent o	f	Pe	rcent o	r				Pe	rcent o	h	Pe	rcent o	ſ
Hour of Day	Maxi	mum I	load	Maxi	mum I	oad				Maxi	mum I	Load	Maxi	num I	Cum
(time)	Wk	Sat	Sun	Wk	Sat	Sun	Wk	Sat	Sun	WK	Sat	Sun	WK	Sat	Sun
1 (12-1am)	90	90	70	20	20	30	on	on	on	20	20	25	40	44	22
2 (1-2am)	90	90	70	15	20	30	on	on	on	15	15	20	33	35	22
3 (2-3am)	90	90	70	10	10	20	on	on	on	15	15	20	33	35	43
4 (3-4am)	90	90	70	10	10	20	on	on	on	15	15	20	22	35	43
5 (4-5am)	90	90	70	10	10	20	on	on	on	20	20	20	33	33	43
6 (5-6am)	90	90	70	20	10	20	on	011	on	25	25	30	33	33	43
7 (6-7am)	70	70	70	40	30	30	on	on	on	50	40	50	42	33	52
8 (7-8am)	40	50	70	50	30	40	on	on	on	00	50	50	57	45	65
9 (8-9am)	40	50	50	40	40	40	on	on	on	22	50	55	52	45	65
10 (9-10am)	20	30	50	40	40	30	on	on	on	40	45	50	40	42	53
11 (10-11am)	20	30	50	25	30	30	on	on	on	40	50	50	51	60	60
12 (11-12pm)	20	30	30	25	25	30	on	on	on	40	50	40	51	65	53
13 (12-1pm)	20	30	30	25	25	30	on	on	on	35	45	40	51	65	51
14 (1-2pm)	20	30	20	25	25	20	on	00	on	30	40	30	51	65	50
15 (2-3pm)	20	30	20	25	23	20	00	00	on	30	40	30	51	65	44
16 (3-4pm)	30	30	20	25	25	20	00	on	on	30	35	30	63	65	64
17 (4-5pm)	50	50	10	25	25	20	00	on	00	40	40	40	80	75	62
18 (5-opm)	50	50	40	60	60	50	00	on	on	55	55	50	86	80	65
19 (6-7pm)	70	60	60	80	70	70	00	on	on	60	55	50	70	80	63
20 (7-8pm)	70	60	60	90	70	80	on	on	on	50	50	40	70	75	63
21 (0-9pm)	80	70	80	80	70	60	00	on	on	55	55	50	70	75	63
22 (0-10pm)	00	70	80	60	60	50	on	on	on	45	40	40	45	55	40
23 (10-11pm)	00	70	80	30	30	30	on	on	on	25	30	20	45	55	40
24 (11-12am)	10									1					
Total/Day	1390	1390	1300	855	785	810	2400	2400	2400	915	930	900	1217	1303	1287
Total/Week	1000	96.40	hours		58.70	hours		168.0	hours		64.05	hours		86.75	hours
Total/Year		5026	hours		3061	hours		8760	hours		3340	hours	1	4523	hours

TABLE 3-2C Hotel/Motel Occupancy¹

Wk = Weekday

 Schedules for occupancy, lighting, receptacle, HVAC system and service hot water are from ASHRAE Standard 90.1-1989 and addendums, except that 5% emergency lighting has been added for all off hours. Elevator schedules, except for restaurants, are from the U.S. Department of Energy Standard Evaluation Techniques except changed to 0% when occupancy is 0%. THESE VALUES MAY BE USED ONLY IF ACTUAL SCHEDULES ARE NOT KNOWN.

1	

•

TABLE 3-2D Light Manufacuring Occupancy¹

	1	Scl	edule ccupan	for cy	Sch L Re	edule ightin; ceptac	for g	Sch IIV/	edule AC Sys	for item	Sci Se	edule rvice F Water	for lot	Sch F	iedule Clevato	for r
	Hour of Day	P	ercent	of	Pe Maxi	rcent	of			in.	Pe Maxi	ercent	of Load	P	ercent	of Load
	(time)	Wk	Sat	Sun	Wk	Sat	Sun	Wk	Sat	Sun	Wk	Sat	Sun	Wk	Sat	Sun
	(12-1am)	0	0	0	5	5	5	off	off	off	5	5	4	0	0	0
ł	2 (1-2am)	0	0	0	5	5	5	off	off	off	5	5	4	0	0	0
ł	3 (2-3am)	0	0	0	5	5	5	off	off	off	5	5	4	0	0	0
1	4 (3-4am)	0	0	0	5	5	5	off	off	off	5	5	4	0	0	0
	5 (4-5am)	0	0	0	5	5	5	off	off	off	5	5	4	0	0	0
	6 (5-6am)	0	0	0	10	5	5	off	off	off	8	8	7	0	0	0
	7 (6-7am)	10	10	5	10	10	5	оп	on	off	7	7	4	0	0	0
	8 (7-8am)	20	10	5	30	10	5	on	on	off	19	11	4	35	16	0
	9 (8-9am)	95	30	5	90	30	5	on	on	off	35	15	4	69	14	0
	10 (9-10am)	95	30	5	90	30	5	on	on	off	38	21	4	43	21	0
	11 (10-11am)	95	30	5	90	30	5	on	on	off	39	19	4	37	18	0
	12 (11-12pm)	95	30	5	90	30	5	оп	on	off	47	23	6	43	25	0
	13 (12-1pm)	50	10	5	80	15	5	on	on	off	57	20	6	58	21	0
	14 (1-2pm)	95	10	5	90	15	5	on	on	off	54	19	9	48	13	0
	15 (2-3pm)	95	10	5	90	15	5	on	on	off	34	15	6	37	8	0
	16 (3-4pm)	95	10	5	90	15	5	on	on	off	33	12	4	37	4	0
	17 (4-5pm)	95	10	5	90	15	5	on	on	off	44	14	4	46	5	0
	18 (5-6pm)	30	5	5	50	5	5	on	on	off	26	7	4	62	6	0
	19 (6-7pm)	10	5	0	30	5	5	on	off	off	21	7	4	20	0	0
	20 (7-8pm)	10	0	0	30	5	5	on	off	off	15	7	4	12	0	0
	21 (8-9pm)	10	0	0	20	5	5	on	off	off	17	7	4	4	0	0
	22 (9-10pm)	10	0	0	20	5	5	on	off	off	8	9	7	4	0	0
1	23 (10-11pm)	5	0	0	10	5	5	off	off	off	5	5	4	0	0	0
	24 (11-12am)	5	0	0	5	5	5	off	off	off	5	5	4	0	0	0
	Total/Day	920	200	60	1040	280	120	1600	1200	0	537	256	113	555	151	0
	Total/Week		48.60	hours		56.00	hours		92.00	hours		30.54	hours		29.26	hours
	Total/Year		2534	hours		2920	hours		4797	hours		1592	hours	_	1526	hours

Wk = Weekday

 Schedules for occupancy, lighting, receptacle, HVAC system and service hot water are from ASHRAE Standard 90.1-1989 and addendums, except that 5% emergency lighting has been added for all off hours. Elevator schedules, except for restaurants, are from the U.S. Department of Energy Standard Evaluation Techniques except changed to 0% when occupancy is 0%. THESE VALUES MAY BE USED ONLY IF ACTUAL SCHEDULES ARE NOT KNOWN.



		Sc	hedule ecupa	for ncy	Sc 1 R	hedule Lightin ecepta	for ng icle	Sc HV	hedule AC Sy	for stem	Sc	hedule ervice Wate	for Hot r	Sc	hedule Elevat	for or
н	our of Day	P Max	ercent	of Load	P Max	ercent	of Load				F	ercent	of Load	F Max	ercent	of Load
	(time)	Wk	Sat	Sun	Wk	Sat	Sun	Wk	Sat	Sun	Wk	Sat	Sun	Wk	Sat	Sun
1	(12-1am)	0	0	0	5	5	5	off	off	off	5	5	4	0	0	0
2	(1-2am)	0	0	0	5	5	5	off	off	off	5	5	4	0	0	0
3	(2-3am)	0	0	0	5	5	5	off	off	off	5	5	4	0	0	0
4	(3-4am)	0	0	0	5	5	5	off	off	off	5	5	4	0	0	0
5	(4-5am)	0	0	0	5	5	5	off	off	off	5	5	4	0	0	0
6	(5-6am)	0	0	0	10	5	5	off	off	off	8	8	7	0	0	0
7	(6-7am)	10	10	5	10	10	5	on	on	off	7	7	4	0	0	0
8	(7-8am)	20	10	5	30	10	5	on	on	off	19	11	4	35	16	0
9	(8-9am)	95	30	5	90	30	5	on	on	off	35	15	4	69	14	0
10	(9-10am)	95	30	5	90	30	5	on	on	off	38	21	4	43	21	0
11	(10-11am)	95	30	5	90	30	5	on	on	off	39	19	4	37	18	0
12	(11-12pm)	95	30	5	90	30	5	on	on	off	47	23	6	43	25	0
13	(12-1pm)	50	10	5	80	15	5	on	on	off	57	20	6	58	21	0
14	(1-2pm)	95	10	5	90	15	5	on	on	off	54	19	9	48	13	0
15	(2-3pm)	95	10	5	90	15	5	on	on	off	34	15	6	37	8	0
16	(3-4pm)	95	10	5	90	15	5	on	on	off	33	12	4	37	4	0
17	(4-5pm)	95	10	5	90	15	5	on	on	off	44	14	4	46	5	0
18	(5-6pm)	30	5	5	50	5	5	on	on	off	26	7	4	62	6	0
19	(6-7pm)	10	5	0	30	5	5	on	off	off	21	7	4	20	0	0
20	(7-8pm)	10	0	0	30	5	5	on	off	off	15	7	4	12	0	0
21	(8-9pm)	10	0	0	20	5	5	on	off	off	17	7	4	4	0	0
22	(9-10pm)	10	0	0	20	5	5	on	off	off	8	9	7	4	0	0
23	(10-11pm)	5	0	0	10	5	5	off	off	off	5	5	4	0	0	0
24	(11-12am)	5	0	0	5	5	5	off	off	off	5	5	4	0	0	0
То	tal/Day	920	200	60	1040	280	120	1600	1200	0	537	256	113	555	151	0
To	tal/Week		48.60	hours		56.00	hours		92.00	hours		30.54	hours		29.26	hours
To	tal/Year		2534	hours		2920	hours		4797	hours		1592	hours		1526	hours

TABLE 3-2E Office Occupancy¹

Wk = Weekday

 Schedules for occupancy, lighting, receptacle, HVAC system and service hot water are from ASHRAE Standard 90.1-1989 and addendums, except that 5% emergency lighting has been added for all off hours. Elevator schedules, except for restaurants, are from the U.S. Department of Energy Standard Evaluation Techniques except changed to 0% when occupancy is 0%. THESE VALUES MAY BE USED ONLY IF ACTUAL SCHEDULES ARE NOT KNOWN.

U

•

	FABLE	3-2F	
Parking	Garage	Occu	pancy

	Sch	edule	for ncy	Sch L Re	edule ightir cepta	for ng cle	Sch HVA	edule C Sy	for stem	Sch Sei	edule vice Wate	for Hot r	Sch	dule	for or
1. 1. 1. 1.	Pe	ercent	of	Pe	rcent	of				Pe	rcent	of	Pe	rcent	of
Hour of Day	Maxi	mum	Load	Maxi	mum	Load		0.	0	Maxi	mum	Load	Maxi	mum	Load
(time)	Wk	Sat	Sun	Wk	Sat	Sun	Wk	Sat	Sun	WK	Sat	Sun	WK	Sat	Sun
1 (12-1am)				100	100	100									
2 (1-2am)				100	100	100									
3 (2-3am)				100	100	100									
4 (3-4am)				100	100	100									
5 (4-Jam)				100	100	100									
7 (6-7am)				100	100	100									
8 (7-8am)				100	100	100									
9 (8-9am)				100	100	100									
10 (9-10am)				100	100	100		Base	ď					Inclu	ded
11 (10-11am)				100	100	100		on						with	
12 (11-12pm)		N/A		100	100	100		likely			N/A			other	
13 (12-1pm)				100	100	100		use						occupa	ancies
14 (1-2pm)				100	100	100									
15 (2-3pm)				100	100	100							1.0		
16 (3-4pm)				100	100	100									
17 (4-5pm)				100	100	100									
18 (5-6pm)				100	100	100									
19 (6-7pm)				100	100	100									
20 (7-8pm)				100	100	100									
21 (8-9pm)				100	100	100									
22 (9-10pm)				100	100	100									
23 (10-11pm)				100	100	100									
24 (11-12am)				100	100	100									
				-											
Total/Day				2400	2400	2400									
Total/Week					168	hours									
[Total/Year					8760	hours	-					-			

Wk = Weekday

.

 Schedules for occupancy, lighting, receptacle, HVAC system and service hot water are from ASHRAE Standard 90.1-1989 and addendums, except that 5% emergency lighting has been added for all off hours. Elevator schedules, except for restaurants, are from the U.S. Department of Energy Standard Evaluation Techniques except changed to 0% when occupancy is 0%. THESE VALUES MAY BE USED ONLY IF ACTUAL SCHEDULES ARE NOT KNOWN.

[に作	Scl	hedule	for icy	Sch I Re	ightin cepta	for g	Sch HV/	edule AC Sys	for stem	Sci	nedule rvice I Water	for lot	Sch	nedule Clevato	for or
	lour of Day	P	ercent	of	Pa	ercent	of				P	ercent	of	P	ercent	of
1	(time)	Wk	Sat	Sun	Wk	Sat	Sun	Wk	Sat	Sun	Wk	Sat	Sun	Wk	Sat	Sun
1	(12-1am)	15	30	20	15	20	20	on	on	on	20	20	25	0	0	0
2	(1-2am)	15	25	20	15	15	15	on	on	on	15	15	20	0	0	0
5	(2-3am)	5	5	5	15	15	15	on	on	on	15	15	20	0	0	0
4	(3-4am)	0	0	0	15	15	15	off	off	off	0	0	0	0	0	0
5	(4-5am)	0	0	0	15	15	15	off	off	off	0	0	0	0	0	0
6	(5-6am)	0	0	0	20	15	15	off	off	off	0	0	0	0	0	0
7	(6-7am)	0	0	0	40	30	30	off	off	off	0	0	0	0	0	0
8	(7-8am)	5	0	0	40	30	30	on	off	off	60	. 0	0	0	0	0
9	(8-9am)	5	0	0	60	60	50	on	off	off	55	0	0	0	0	0
10) (9-10am)	5	5	0	60	60	50	on	on	off	45	50	0	0	0	0
11	(10-11am)	20	20	10	90	80	70	on	on	on	40	45	50	0	0	0
12	(11-12pm)	50	45	20	90	80	70	on	on	on	45	50	50	0	0	0
13	(12-1pm)	80	50	25	90	80	70	on	on	по	40	50	40	0	0	0
14	(1-2pm)	70	50	25	90	80	70	on	on	on	35	45	40	0	0	0
15	i (2-3pm)	40	35	15	90	80	70	on	on	on	30	40	30	0	0	0
16	6 (3-4pm)	20	30	20	90	80	70	on	on	on	30	40	30	0	0	0
17	7 (4-5pm)	25	30	25	90	80	60	on	on	on	30	35	30	0	0	0
18	8 (5-6pm)	50	30	35	90	90	60	on	on	on	40	40	40	0	0	0
15	(6-7pm)	80	70	55	90	90	60	on	on	on	55	55	50	0	0	0
20) (7-8pm)	80	90	65	90	90	60	on	on	on	60	55	50	0	0	0
21	(8-9pm)	80	70	70	90	90	60	оп	on	on	50	50	40	0	0	0
22	? (9-10pm)	50	65	35	90	90	60	on	on	On	55	55	50	0	0	0
23	(10-11pm)	35	55	20	50	50	50	ОЛ	on	on	45	40	40	0	0	0
24	(11-12am)	20	35	20	30	30	30	on	on	on	25	30	20	0	0	0
h	otal/Day	750	740	485	1455	1365	1115	2000	1800	1700	790	730	625	0	0	0
h	ntal/Week		49.75	hours		97.55	hours		135	hours		53.05	hours		0	hours
h	otal/Year		2594	hours		5086	hours		7039	hours		2766	hours		0	hours

•

1

TABLE 3-2G Restaurant Occupancy¹

Wk = Weekday

 Schedules for occupancy, lighting, receptacle, HVAC system and service hot water are from ASHRAE Standard 90.1-1989 and addendums, except that 5% emergency lighting has been added for all off hours. Elevator schedules, except for restaurants, are from the U.S. Department of Energy Standard Evaluation Techniques except changed to 0% when occupancy is 0%. THESE VALUES MAY BE USED ONLY IF ACTUAL SCHEDULES ARE NOT KNOWN.

TABLE 3-2H Retail Occupancy¹

Γ		Sch	edule f	or y	Schu Li Re	edule l ighting ceptac	for I le	Scho HVA	edule I C Sys	for tem	Sch Sei	edule i rvice H Water	for lot	Sch E	edule f levator	or
E	-	Pe	ercent o	r	Pe	rcent o	of				Pe	rcent (l	Pe	rcent a	l
H	our of Day	Maxi	mum I	load	Maxi	mum I	load		C-4	Curr	Max	mum I	Sun	WIRXI	Sat	Sun
	(time)	Wk	Sat	Sun	Wk	Sat	Sun	WK	Sat	Sun	WK	Sat	7	0	0	O
1	(12-1am)	0	0	0	5	5	5	110	110	IIO	4	10	2	0	0	0
2	(1-2am)	0	0	0	5	3	2	110	110	110	2	0	7	0	0	ő
p	(2-3am)	0	0	0	3	2	2	off	011	011	2	0	6	0	0	0
4	(3-4am)	0	0	0	2	2	2	011	110	011	4	6	6	0	0	0
p	(4-5am)	0	0	0	2	2	2	011	110	OH	4	6	6	0	0	0
6	(5-6am)	0	0	0	2	2	2	011	OII	off	4	7	7	0	0	ő
2	(6-7am)	0	0	0	3	2	2	on	on	off	15	20	10	12	q	0
8	(7-8am)	10	10	0	20	20	10	on	on	on	22	24	12	22	21	0
2	(8-9am)	20	20	0	00	50	10	On	on	on	32	27	14	64	56	11
10) (9-10am)	50	50	10	90	00	40	on	00	00	41	47	29	74	66	13
	(10-11am)	50	00	20	90	90	40	on	00	on	57	54	31	68	68	35
L	(11-12pm)	70	80	40	00	00	60	00	on	on	62	59	36	68	68	37
1.	(12-1pm)	70	80	40	00	00	60	00	00	00	61	60	36	71	69	37
14	(1-2pm)	70	80	40	00	00	60	00	00	00	50	49	34	72	70	39
15	5 (2-3pm)	00	80	40	00	00	60	00	00	on	45	48	35	72	69	41
10	5 (3-4pm)	20	80	40	00	00	60	00	00	00	46	47	37	73	66	38
1	(4-5pm)	10	60	20	00	00	40	on	00	off	47	46	34	68	58	34
	(5-opm)	50	20	10	50	50	20	00	an	off	42	44	25	68	47	3
	(o-/pm)	20	20	0	60	10	5	00	on	off	34	36	27	58	43	0
E	(7-6pm)	20	20	0	50	30	5	00	00	off	33	29	21	54	43	0
h	(8-9pm)	0	10	0	20	10	5	off	on	off	23	22	16	0	8	0
1º	2 (9-10pm)	0	0	0	5	5	5	off	off	off	13	16	10	0	0	0
h	(10-11pm)	0	0	0	5	5	5	off	off	off	8	13	6	0	0	0
12	+ (11-12am)	0	0	0	1	2	5		2.11	2		-		-		
h	otal/Day	720	750	280	1115	985	525	1500	1600	900	662	690	459	844	761	288
h	otal/Week	1	46.30	hours		70.85	hours		100	hours		44.59	hours		52.69	hours
'n	otal/Year		2414	hours		3694	hours		5214	hours		2325	hours		2747	hours

Wk = Weekday

.

•

 Schedules for occupancy, lighting, receptacle, HVAC system and service hot water are from ASHRAE Standard 90.1-1989 and addendums, except that 5% emergency lighting has been added for all off hours. Elevator schedules, except for restaurants, are from the U.S. Department of Energy Standard Evaluation Techniques except changed to 0% when occupancy is 0%. THESE VALUES MAY BE USED ONLY IF ACTUAL SCHEDULES ARE NOT KNOWN.

17

		Scl	hedule ccupar	for	Scl I R	hedule Lightin ecepta	for g cle	Scl HV	AC Sy	for stem	Sci Se	rvice I Water	for lot	Scl	hedule Elevato	for or
н	our of Day	p Max	ercent	of Load	P Max	ercent Imum	of Load	103	1.51		P Max	ercent	of Load	P Max	ercent imum	of Load
	(time)	Wk	Sat	Sun	Wk	Sat	Sun	Wk	Sat	Sun	Wk	Sat	Sun	Wk	Sat	Sun
1	(12-lam)	0	0	0	5	5	5	off	off	off	5	3	3	0	0	0
2	(1-2am)	0	0	0	5	5	5	off	off	off	5	3	3	0	0	0
3	(2-3am)	0	0	0	5	5	5	off	off	off	5	3	3	0	0	0
4	(3-4am)	0	0	0	5	5	5	off	off	off	5	3	3	0	0	0
5	(4-5am)	0	0	0	5	5	5	off	off	off	5	3	3	0	0	0
6	(5-6am)	0	0	0	5	5	5	off	off	off	5	3	3	0	0	0
7	(6-7am)	0	0	0	5	5	5	off	off	off	5	3	3	0	0	0
8	(7-8am)	5	0	0	30	5	5	on	off	off	10	3	3	0	0	0
9	(8-9am)	75	10	0	85	15	5	on	on	off	34	3	5	30	0	0
10	(9-10am)	90	10	0	95	15	5	on	on	off	60	5	5	30	0	0
11	(10-11am)	90	10	0	95	15	5	on	on	off	63	5	5	30	0	0
12	(11-12pm)	80	10	0	95	15	5	on	on	off	72	5	5	30	0	0
13	(12-1pm)	80	10	0	80	15	5	on	on	off	79	5	5	30	0	0
14	(1-2pm)	80	0	0	80	5	5	on	off	off	83	3	5	30	0	0
15	(2-3pm)	80	0	0	80	5	5	on	off	off	61	3	3	30	0	0
16	(3-4pm)	45	0	0	70	5	5	on	off	off	65	3	3	15	0	0
17	(4-5pm)	15	0	0	50	5	5	on	off	off	10	3	3	0	0	0
18	(5-6pm)	5	0	0	50	5	5	on	off	off	10	3	3	0	0	0
19	(6-7pm)	15	0	0	35	5	5	on	off	off	19	3	3	0	0	0
20	(7-8pm)	20	0	0	35	5	5	on	off	off	25	3	3	0	0	0
21	(8-9pm)	20	0	0	35	5	5	on	off	off	22	3	3	0	0	0
22	(9-10pm)	10	0	0	30	5	5	on	off	off	22	3	3	0	0	0
23	(10-11pm)	0	0	0	5	5	5	off	off	off	12	3	3	0	0	0
24	(11-12am)	0	0	0	5	5	5	off	off	off	9	3	3	0	0	0
То	tal/Day	710	50	0	990	170	120	1500	500	0	691	80	84	285	0	0
То	tal/Week		36.00	hours		52.40	hours		80.00	hours		36.19	hours		14.25	hours
To	tal/Year		1877	hours		2732	hours		4171	hours		1887	hours	-	743	hours

TABLE 3-2I School Occupancy¹

Wk = Weekday

 Schedules for occupancy, lighting, receptacle, HVAC system and service hot water are from ASHRAE Standard 90.1-1989 and addendums, except that 5% emergency lighting has been added for all off hours. Elevator schedules, except for restaurants, are from the U.S. Department of Energy Standard Evaluation Techniques except changed to 0% when occupancy is 0%. THESE VALUES MAY BE USED ONLY IF ACTUAL SCHEDULES ARE NOT KNOWN.

18

•





TABLE 3-2J Warehouse Occupancy¹

				R	ecepta	cle	HV	AC Sy	stem	Se	Water	lot	E	levat	or
Hour of Day	Pe	rcent	logd	P	ercent	load	-		3.2	P	ercent	of	Pe	rcent	of
(time)	Wk	Sat	Sun	Wk	Sat	Sun	Wk	Sat	Sun	Wk	Sat	Sun	Wk	Sat	Sun
1 (12-1am)	0	0	0	5	5	5	off	off	off	2	2	2	0	0	0
2 (1-2am)	0	0	0	5	5	5	off	off	off	2	2	2	0	0	0
3 (2-3am)	0	0	0	5	5	5	off	off	off	2	2	2	0	0	õ
4 (3-4am)	0	0	0	5	5	5	off	off	off	2	2	2	0	0	0
5 (4-5am)	0	0	0	5	5	5	off	off	off	5	2	2	Ő	0	0
6 (5-6am)	0	0	0	5	5	5	off	off	off	7	2	2	0	0	0
7 (6-7am)	0	0	0	5	5	5	off	off	off	7	2	2	0	0	0
8 (7-8am)	15	0	0	40	5	5	on	off	off	10	2	2	0	0	0
9 (8-9am)	70	20	0	70	8	5	on	on	off	30	6	2	0	0	0
10 (9-10am)	90	20	0	90	24	5	on	on	off	36	12	2	0	0	0
11 (10-11am)	90	20	0	90	24	5	on	on	off	36	12	2	30	0	0
12 (11-12pm)	90	20	0	90	24	5	on	on	off	46	17	2	0	0	0
13 (12-1pm)	50	10	0	80	5	5	OR	on	off	57	4	4	0	0	0
14 (1-2pm)	85	10	0	90	5	5	on	ол	off	43	4	4	0	0	0
15 (2-3pm)	85	10	0	90	5	5	on	on	off	38	2	2	0	0	0
16 (3-4pm)	85	10	0	90	5	5	on	on	off	40	2	2	40	0	0
17 (4-5pm)	20	0	0	90	5	5	on	off	off	30	2	2	0	0	0
18 (5-6pm)	0	0	0	30	5	5	off	off	off	18	2	2	0	0	0
19 (6-7pm)	0	0	0	5	5	5	off	off	off	3	2	2	0	0	0
20 (7-8pm)	0	0	0	5	5	5	off	off	off	3	2	2	0	0	0
21 (8-9pm)	0	0	0	5	5	5	off	off	off	3	2	2	0	0	0
22 (9-10pm)	0	0	0	5	5	5	off	off	off	3	2	2	0	0	0
23 (10-11pm)	0	0	0	5	5	5	off	off	off	3	2	2	0	0	0
24 (11-12am)	0	0	0	5	5	5	off	off	off	3	2	2	0	0	0
Total/Day	680	120	0	915	180	120	1000	800	0	479	91	52	70	0	0
Total/Week		35.20	hours		48.75	hours		58.00	hours		22.88	hours		3 50	hours
Total/Year		1835	hours		2542	hours		3024	hours		1193	hours		182	hours

Wk = Weekday

.

•

8

 Schedules for occupancy, lighting, receptacle, HVAC system and service hot water are from ASHRAE Standard 90.1-1989 and addendums, except that 5% emergency lighting has been added for all off hours. Elevator schedules, except for restaurants, are from the U.S. Department of Energy Standard Evaluation Techniques except changed to 0% when occupancy is 0%. THESE VALUES MAY BE USED ONLY IF ACTUAL SCHEDULES ARE NOT KNOWN.

	Use	System #	Remarks
1.	Assembly		-
	a. Churches (any size)	1	
	b. $\leq 50,000 \text{ ft}^2 \text{ or } \leq 3 \text{ floors}$	1 or 3	Note 2
	c. $> 50,000 \text{ ft}^2 \text{ or } > 3 \text{ floors}$	3	
2.	Health		1.00
	a. Nursing Home (any size)	2	
	b. $\leq 15,000 \text{ ft}^2$	1	
	c. > 15,000 ft ² and \leq 50,000 ft ²	4	Note 3
	d. > 50,000 ft ²	5	Note 3,4
3.	Hotel/Motel		
	a. < 3 Stories	2	Note 6
	b. > 3 Stories	6	Note 7
4.	Light Manufacturing	1 or 3	
5.	Office		
	a. $\leq 20,000 \text{ ft}^2$	1	
	b. > 20,000 ft ² and either		
	≤ 3 floors or < 75,000 ft ²	4	
	c. > 75,000 ft ² or > 3 floors	. 5	
6.	Restaurant	1 or 3	Note 2
7.	Retail		
	a. $\leq 50,000 \text{ ft}^2$	1 or 3	Note 2
	b. > 50,000 ft ²	4 or 5	Note 2
8,	Schools		
	a. \leq 75,000 ft ² or \leq 3 floors	1	
	b. > 75,000 ft ² or > 3 floors	3	
9	Warehouse		Note 5

TABLE 3-3 HVAC Systems of Prototype Buildings³

Footnote to TABLE 3-3: The systems and energy types presented in this table are not intended as requirements or recommendations for the proposed design. Floor areas in the table are the total conditioned floor areas for the listed use in the building. The number of floors indicated in the table is the total number of occupied floors for the listed use.

TABLE 3-3 (cont.)			
HVAC System	Descriptions	for Prototype	Buildings ¹

•••

•

HVAC Component	System #1	System #2
System Description	Packaged rooftop single zone, one unit per zone.	Packaged terminal air conditioner with space heater or heat pump, heating or cooling unit per zone.
Fan System Design Supply Circulation Rate	Note 10	Note 11
Supply Fan Control	Constant volume.	Fan cycles with call for heating or cooling.
Return Fan Control	N.A.	NA
Cooling System	Direct expansion air cooled	Direct expansion air cooled.
Heating System	Furnace, heat pump, or electric resistance.	Heat pump with electric resistance auxiliary or air conditioner with space heater.
Remarks	Drybulb economizer per Section 1433, heat recovery if required by Section 1436.	No economizer, if not required by Section 1433.

TABLE 3-3 (cont.) **HVAC System Descriptions for Prototype Buildings**¹

HVAC Component	System #3	System #4
System Description	Air handler per zone with central plant.	Packaged rooftop VAV with perimeter reheat and fan-powered terminal units.
Fan System Design Supply Circulation Rate	Note 10	Note 10
Supply Fan Control	Constant volume.	VAV with forward curved centrifugal fan and variable inlet fans.
Return Fan Control	Constant volume.	VAV with forward curved centrifugal fan and discharge dampers.
Cooling System	Chilled water (Note 12)	Direct expansion air cooled.
Heating System	Hot water (Note 13)	Hot water (Note 13) or electric resistance.
Remarks	Drybulb economizer per Section 1433, heat recovery if required by Section 1436.	Drybulb economizer per Section 1433. Minimum VAV setting per Section 1435 Exception 1, Supply air reset by zone of greatest cooling demand, heat recovery if required by Section 1436.

HVAC Component	System #5	System #6
System Description	Built-up central VAV with perimeter reheat and fan-powered terminal units	Four-pipe fan coil per zone with central plant.
Fan System Design Supply Circulation Rate	Note 10	Note 10
Supply Fan Control	VAV with air-foil centrifugal fan and AC frequency variable speed drive.	Fan cycles with call for heating or cooling.
Return Fan Control	VAV with air-foil centrifugal fan and AC frequency variable speed drive.	NA
Cooling System	Chilled water (Note 12)	Chilled water (Note 12)
Heating System	Hot water (Note 13) or electric resistance.	Hot water (Note 13) or electric resistance.
Remarks	Drybulb economizer per Section 1433. Minimum VAV setting per Section 1435 Exception 1, Supply air rest by zone of greatest cooling demand, heat recovery if remuired by Section 1436.	No economizer, if not required by Section 1433.

TABLE 3-3 (cont.) HVAC System Descriptions for Prototype Buildings¹

Numbered Footnotes for TABLE 3-3 HVAC System Descriptions for Prototype Buildings

- The systems and energy types presented in this Table are not intended as requirements or recommendations for the proposed design.
- 2. For occupancies such as restaurants, assembly and retail that are part of a mixed use building which, according to Table 3-3, includes a central chilled water plant (systems 3,5, or 6), chilled water system type 3 or 5 shall be used as indicated in the table.
- 3. Constant volume may be used in zones where pressurization relationships must be maintained by code. Where constant volume is used, the system shall have heat recovery if required by Section 1436. VAV shall be used in all other areas, in accordance with Sections 1432 through 1438.
- Provide run-around heat recovery systems for all fan systems with a minimum outside air intake greater than 70%. Recovery effectiveness shall be 0.50.
- If a warehouse is not intended to be mechanically cooled, both the standard and proposed designs shall be calculated assuming no mechanical cooling.
- The system listed is for guest rooms only. Areas such as public areas and backof-house areas shall be served by system 4. Other areas such as offices and retail shall be served by systems listed in Table 3-3 for these occupancy types.
- The system listed is for guest rooms only. Areas such as public areas and backof-house areas shall be served by system 5. Other areas such as offices and retail shall be served by systems listed in Table 3-3 for these occupancy types.
- 8. Reserved.
- 9. Reserved.

10. Design supply air circulation rate shall be based on a supply-air-to-room air temperature difference of 20^o F. A higher supply air temperature may be used if required to maintain a minimum circulation rate of 4.5 air changes per hour or 15 cfm per person to each zone served by the system, at design conditions. If return fans are specified, they shall be sized for the supply fan capacity less the required minimum ventilation with outside air, or 75% of the supply fan capacity, whichever is larger. Except where noted, supply and return fans shall be operated continuously during occupied hours.

•

- Fan energy when included in the efficiency rating of the unit as defined in Section 1411, need not be modeled explicitly for this system. The fan shall evcle with calls for heating or cooling.
- 12. Chilled water systems shall be modeled using a reciprocating chiller for systems with total cooling capacities less than 175 tons, and centrifugal chillers for systems with cooling capacities of 175 tons or greater. For systems with cooling capacities of 175 tons or greater. For systems with cooling capacities of exploring controlled capacities of exploring controlled exploring controlled exploring controlled exploring capacities of exploring capacities capacities and explore exploring capacities of exploring capacities explore e
- 13. Hot water system shall include a natural draft fossil fuel or electric boiler. The hot water pump shall be sized based on a 30° F temperature drop, from 180° F to 150° F, operating at a combined impeller and motor efficiency of 60%. Hot water supply temperature shall be reset in accordance with Section 1432.2.2.

SECTION 4 – SUGGESTED SOFTWARE FOR SYSTEMS ANALYSIS APPROACH

4.1 Programs Acceptable for Projects for Full-Year Hourly Analysis

Program Name	Source
ADM-DOE	ADM Associates 3299 Ramos Circle Sacramento, CA 95827 916-363-8383
Micro-Axcess 10.1, PC	Edison Electric Institute PO Box 1235 Roswell, GA 30077 404-993-2406
Blast 3.0 (Level 193)	Blast Support Office University of Illinois Dept. of Mechanical and Industrial Engineering 1206 W. Green Room 30, MEB Urbana, Il 61801 1-800-842-5278
DOE 2.1	Energy Science and Technology Software Center PO Box 1220 Oakridge, TN 37831-1020 615-576-2606
ESAS	Ross Meriweather Consulting, Engineering 3315 Outrider San Antonio, TX 78247-4405 512-490-7081
ESP-II	Automated Procedures for Engineering Consultants, Inc. Miami Valley Tower, Suite 2100 40 W. 4th St Dayton, OH 45402 513-228-2602
HAP 2.02	Carrier Air Conditioning 655 S. Orcas, Suite 10 Seattle, WA 98108 206-767-6340

MICRO-DOE

.

ULTRA 600 Version 11.9

Acrosoft International, Inc. 9745 E. Hampden Ave, Suite 230 Denver, CO 80231 303-368-9225

The Trane Co. 3600 Pammel Creek Rd. Lacrosse, WI 54601 608-787-3926

4.2 Programs only Acceptable for Commercial Buildings 25,000 Square Feet or Less

Source

Program Name

ADM.2

ASEAM

Building Energy Analysis and Easy DOE

ESE

Trakload 4.0 Load Shaper Market Manager

XENCAP 4.5

ADM Associates 3299 Ramos Circle Sacramento, CA 95827 916-363-8383

Advanced Sciences Inc. 2000 N. 15th St., Suite 407 Arlington, VA 22201-2627 703-243-4900

Elite Software PO Drawer 1194 Bryan, TX 77806 409-846-2340

Sea Gate 5001 W. 80th St., Suite 204 Bloomington, MN 55437 612-844-8000

SRC Systems 1300 Clay St., Suite 850 Oakland, CA 94612 510-839-2700

XENERGY 492 9th Street, Suite 220 Oakland, CA 94607 510-891-0446

