



The Passive House Institute US Awards

The Designation of

PHIUS+ 2015 CERTIFIED PROJECT

No. 1482

██████████ Lane

██████████
Bellingham, WA 98226

████████████████████

PROJECT OWNER

November 1, 2019

DATE

██████████

CPHC®

██████████

ARCHITECT

████████████████████

CONSTRUCTION

██████████

ON-SITE VERIFICATION

• INTERIOR CONDITIONED FLOOR AREA	2,532	ft ²
• ANNUAL HEATING DEMAND	5.85	kBTU/ft ² yr
• ANNUAL COOLING DEMAND	0.03	kBTU/ft ² yr
• PEAK HEATING LOAD	3.58	BTU/ft ² hr
• PEAK COOLING LOAD	0.00	BTU/ft ² hr
• AIR-TIGHTNESS TEST RESULTS	0.04	CFM50/ft ²
• SOURCE ENERGY	10259 (w/o PV) 0 (w/PV)	kWh/person.yr
• SITE ENERGY USE INDEX (EUI)	13.12 (w/o PV) 0 (w/PV)	kBTU/ft ² yr


Executive Director

